

YUANJIANG, China

WMO: 569660

Lat: 23.5966N

Lon: 101.9938E

Elev: 1306

StdP: 14.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.6	51.3	37.9	35.1	64.5	40.6	39.1	64.9	22.4	64.7	20.5	63.4	1.8	250	0.338

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	14.9	101.5	72.9	99.4	73.3	97.3	73.8	79.2	90.5	78.5	89.7	77.9	88.9	5.7	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.6	145.7	82.8	76.0	142.8	82.4	75.4	139.7	82.0	44.0	90.7	43.3	90.1	42.7	89.3	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.7	16.4	14.5	43.1	104.6	3.8	2.1	40.4	106.1	38.1	107.3	36.0	108.5	33.2	110.0		
(5)			42.2	80.6	2.8	1.3	40.2	81.5	38.6	82.3	37.0	83.0	35.0	83.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.3	64.4	68.8	75.5	81.6	84.5	86.1	84.9	84.2	82.5	78.2	71.2	65.5		
	DBStd	8.96	4.48	5.91	5.33	5.19	5.68	4.39	3.75	3.38	4.15	4.45	4.39	4.39		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	153	63	31	4	0	0	0	0	0	0	0	7	48		
	CDD50	9972	448	527	789	948	1068	1083	1083	1061	975	876	635	479		
	CDD65	4650	46	138	328	498	603	633	618	596	525	411	192	62		
	CDH74	50072	388	1204	2990	5538	7436	8133	7365	6642	5467	3417	1153	339		
	CDH80	23913	88	472	1379	2988	4078	4305	3490	3034	2427	1300	298	54		
(14) Wind	WSAvg	5.1	6.0	6.8	6.8	6.1	5.5	5.2	4.5	3.6	3.8	4.4	4.0	5.1		
(15) Precipitation	PrecAvg	30.8	0.4	0.6	0.7	1.7	3.8	4.9	4.6	5.6	3.1	2.6	2.2	0.8		
	PrecMax	47.7	2.2	2.6	2.1	4.7	9.8	10.6	10.5	10.9	6.9	7.3	8.1	7.1		
	PrecMin	20.4	0.0	0.0	0.0	0.0	0.4	1.0	1.3	1.7	0.7	0.6	0.0	0.0		
	PrecStd	6.6	0.5	0.7	0.6	1.3	2.6	2.3	2.0	2.0	1.8	1.8	2.2	1.5		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.8	93.6	98.1	102.9	104.4	102.6	101.6	100.1	98.9	95.2	89.7	84.6		
		MCWB	62.5	63.2	66.1	68.9	71.7	76.2	76.6	76.9	76.1	73.8	69.5	64.6		
	2%	DB	82.4	89.9	95.2	100.3	101.8	99.9	97.9	97.1	96.0	92.5	86.3	81.3		
		MCWB	62.5	63.0	65.8	68.8	72.2	75.9	76.5	76.8	75.7	73.3	69.1	64.6		
	5%	DB	78.5	86.3	91.9	97.5	99.0	97.3	95.4	94.5	93.4	89.9	83.7	77.8		
		MCWB	62.2	63.3	66.0	69.5	72.9	76.2	76.8	76.8	75.4	73.0	68.3	63.6		
	10%	DB	74.6	82.1	88.0	94.1	95.9	94.7	92.7	92.0	90.9	87.2	80.7	74.6		
		MCWB	61.1	63.2	66.3	69.7	73.2	76.3	76.9	76.7	75.0	72.5	67.1	62.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.8	67.6	71.1	75.5	78.2	79.8	80.1	80.0	79.1	76.9	73.5	68.4		
		MCDB	79.5	85.0	87.1	92.0	91.6	91.5	90.9	91.5	91.4	89.9	85.8	78.7		
	2%	WB	64.1	66.0	69.8	73.9	77.1	78.8	79.1	79.0	77.9	75.5	71.5	66.3		
		MCDB	77.7	82.7	86.0	89.1	90.7	90.7	89.8	90.3	89.6	87.5	81.1	77.1		
	5%	WB	62.7	64.7	68.6	72.8	76.2	78.1	78.3	78.2	77.0	74.6	69.9	64.5		
		MCDB	75.7	80.8	84.4	87.9	89.4	89.9	88.7	88.9	88.2	85.7	79.2	75.2		
	10%	WB	61.4	63.5	67.5	71.8	75.4	77.4	77.8	77.6	76.2	73.6	68.4	63.0		
		MCDB	73.1	78.8	82.9	87.1	88.1	89.2	87.8	87.6	86.7	83.8	77.4	73.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	20.2	23.8	23.9	22.6	18.5	14.9	14.0	15.3	15.9	15.9	18.9	18.3		
		MCDBR	29.8	33.7	31.9	28.1	23.8	18.7	18.4	19.6	19.9	20.7	24.0	24.9		
	5% WB	MCWBR	11.7	10.6	8.9	7.2	5.3	3.7	4.0	4.1	4.5	5.9	9.1	10.2		
		MCWBR	25.9	27.5	25.6	22.9	17.8	14.8	14.3	15.9	16.1	17.2	19.9	21.7		
(40) Clear-Sky Solar Irradiance	taub		0.441	0.487	0.735	0.699	0.527	0.474	0.486	0.540	0.536	0.533	0.461	0.464		
		taud	2.147	2.016	1.496	1.619	2.088	2.276	2.225	2.049	2.037	2.007	2.155	2.076		
	Ebn at Noon		256	252	199	211	250	261	258	245	243	236	248	242		
		Edh at Noon	44	53	94	84	52	43	45	54	54	53	43	45		
(44) All-Sky Solar Radiation	RadAvg		1226	1573	1656	1777	1672	1448	1378	1403	1322	1144	1219	1063		
	RadStd		121	172	138	141	180	126	92	84	71	136	97	118		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.83	N/A	N/A	+1.66	-0.72	-0.94	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.54	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	+232	+157

Nomenclature: See separate page