

JIANGCHENG, China

WMO: 569770

Lat: 22.6081N

Lon: 101.8570E

Elev: 4117

StdP: 12.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 43.3	(c) 45.6	(d) 38.2	(e) 39.4	(f) 61.7	(g) 40.9	(h) 43.9	(i) 59.0	(j) 9.4	(k) 68.1	(l) 7.8	(m) 67.1	(n) 2.3	(o) 290	(p) 0.222

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	11.2	87.7	67.3	85.8	68.1	84.1	68.7	73.8	81.0	73.2	80.1	72.7	79.1	4.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	137.6	76.7	71.3	134.7	76.0	70.8	132.7	75.5	40.7	81.5	40.0	80.5	39.4	79.4	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 7.8	(b) 7.0	(c) 5.6	(e) 39.4	(f) 90.9	(g) 3.1	(h) 1.8	(i) 37.1	(j) 92.2	(k) 35.3	(l) 93.2	(m) 33.5	(n) 94.2	(o) 31.3	(p) 95.6		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.5	58.7	61.5	66.5	71.3	73.7	74.8	74.3	74.4	72.9	69.6	64.2	59.3		
	DBStd	6.86	4.00	4.79	4.29	3.75	3.49	2.25	2.21	2.11	2.70	3.29	3.89	4.31		
	HDD50	8	3	4	0	0	0	0	0	0	0	0	0	1		
	HDD65	595	197	108	35	5	2	0	0	0	1	6	60	181		
	CDD50	6746	273	326	510	638	734	745	752	756	688	607	427	290		
	CDD65	1856	1	10	80	193	270	295	287	291	239	149	36	5		
	CDH74	9011	14	223	832	1494	1565	1203	1019	1144	915	479	115	8		
	CDH80	1865	0	13	182	495	459	203	154	197	129	32	1	0		
(14) Wind	WSAvg	2.3	2.4	2.7	2.7	2.7	2.4	2.2	2.1	2.0	1.9	2.0	2.1	2.2		
(15) Precipitation	PrecAvg	86.1	1.5	1.1	2.1	3.8	10.4	13.5	18.2	15.3	9.9	6.1	2.8	1.5		
	PrecMax	108.2	5.4	2.2	5.4	6.2	24.4	27.6	29.5	25.4	17.4	12.8	5.7	5.9		
	PrecMin	67.5	0.0	0.0	0.1	0.5	3.2	5.9	11.6	7.0	4.1	2.4	0.2	0.0		
	PrecStd	9.0	1.3	0.7	1.4	1.4	5.0	4.3	4.2	4.9	3.5	2.3	1.5	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.6	81.9	86.7	90.3	90.8	87.0	86.1	86.6	85.5	83.0	79.5	75.1		
		MCWB	58.7	59.0	61.0	64.0	66.6	72.2	73.0	72.5	71.5	69.5	66.3	63.1		
	2%	DB	73.5	79.1	84.2	87.9	87.7	84.4	83.7	84.3	83.4	80.8	77.3	72.9		
		MCWB	58.1	59.0	61.0	64.8	68.4	72.1	72.5	72.2	70.8	68.7	65.4	61.4		
	5%	DB	71.4	77.0	82.0	85.7	85.0	82.3	81.6	82.2	81.5	79.0	75.0	70.7		
		MCWB	58.1	58.5	60.9	65.2	69.2	72.0	72.3	72.1	70.5	68.4	64.1	60.3		
	10%	DB	68.7	74.2	79.2	83.0	82.3	80.3	79.5	80.1	79.4	76.9	72.8	68.2		
		MCWB	57.8	58.4	61.0	65.3	69.2	71.7	72.0	71.7	70.2	67.7	63.1	59.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.9	65.4	67.8	70.4	73.3	74.5	74.6	74.7	73.8	72.0	68.9	65.7		
		MCDB	69.4	73.6	77.1	81.0	82.2	82.0	82.3	82.6	81.1	79.0	76.3	71.5		
	2%	WB	61.2	62.9	65.9	69.2	72.3	73.6	73.6	73.6	72.8	70.7	67.3	63.9		
		MCDB	67.8	70.9	74.7	79.3	80.5	80.7	80.5	80.7	79.7	77.4	73.3	69.0		
	5%	WB	60.0	61.2	64.5	68.2	71.5	72.9	72.9	72.8	72.0	69.8	66.2	62.1		
		MCDB	66.8	70.3	73.5	78.2	79.3	79.3	79.0	79.2	78.2	76.1	71.8	67.6		
	10%	WB	58.7	59.8	63.1	67.1	70.7	72.3	72.3	72.2	71.2	68.8	65.0	60.6		
		MCDB	65.7	69.5	72.9	76.9	77.7	78.1	77.8	78.0	76.7	74.4	70.2	66.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	18.2	22.6	23.2	21.2	15.9	11.2	10.3	11.8	13.1	13.3	16.2	16.3		
		MCDBR	24.7	29.0	29.7	27.3	21.7	14.8	14.4	15.8	16.7	17.1	19.4	20.2		
		MCWBR	10.9	10.9	9.5	7.9	6.0	4.8	5.1	5.6	5.9	6.4	8.6	9.3		
		MCDBR	19.0	22.8	21.2	20.2	15.3	12.2	12.3	13.4	13.6	14.1	15.2	16.4		
	5% WB	MCWBR	9.3	9.9	9.0	7.5	5.3	4.6	4.9	5.4	5.3	5.8	6.9	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.398	0.448	0.677	0.643	0.451	0.413	0.415	0.453	0.459	0.470	0.404	0.410		
	taud		2.220	2.072	1.541	1.664	2.250	2.400	2.375	2.241	2.196	2.117	2.258	2.185		
	Ebn at Noon		272	265	212	224	270	278	277	268	265	255	268	263		
	Edh at Noon		41	50	90	81	45	38	39	45	46	48	39	41		
(44) All-Sky Solar Radiation	RadAvg		1150	1501	1571	1739	1628	1384	1328	1401	1356	1179	1199	1030		
	RadStd		121	186	125	151	159	118	106	103	85	116	89	104		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.49	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.63	N/A	N/A	+1.04	N/A	N/A	-85	+315	+236

Nomenclature: See separate page