

JIANGCHENG, China

WMO: 569770

Lat: 22.6081N

Lon: 101.8570E

Elev: 1255

StdP: 87.13

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.3	7.6	3.4	5.6	16.5	5.0	6.3	15.0	4.2	20.1	3.5	19.5	1.0	290	0.222

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6	6.2	31.0	19.6	29.9	20.1	28.9	20.4	23.2	27.2	22.9	26.7	22.6	26.1	2.0	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.2	19.7	24.9	21.8	19.2	24.5	21.6	19.0	24.2	76.7	27.5	75.2	27.0	73.9	26.3	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
3.5	3.1	2.5	DB	4.1	32.7	1.7	1.0	2.8	33.4	1.8	34.0	0.9	34.6	-0.4	35.3	
			WB	3.7	24.0	1.6	0.5	2.5	24.4	1.5	24.6	0.6	24.9	-0.6	25.3	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	14.8	16.4	19.1	21.8	23.2	23.8	23.5	23.6	22.7	20.9	17.9	15.2
	DBStd	3.81	2.22	2.66	2.38	2.08	1.94	1.25	1.23	1.17	1.50	1.83	2.16	2.39
	HDD10.0	4	2	2	0	0	0	0	0	0	0	0	0	1
	HDD18.3	331	109	60	19	3	1	0	0	0	1	3	33	101
	CDD10.0	3748	152	181	283	354	408	414	418	420	382	337	237	161
	CDD18.3	1031	1	6	44	107	150	164	159	162	133	83	20	3
	CDH23.3	5006	8	124	462	830	869	668	566	636	508	266	64	4
	CDH26.7	1036	0	7	101	275	255	113	86	109	72	18	1	0
Wind	WSAvg	1.0	1.1	1.2	1.2	1.2	1.1	1.0	0.9	0.9	0.9	0.9	1.0	1.0
Precipitation	PrecAvg	2188	37	29	53	96	263	344	463	389	251	155	71	37
	PrecMax	2749	137	57	137	158	619	701	750	645	442	324	146	151
	PrecMin	1715	0	0	2	12	82	149	294	177	103	61	5	1
	PrecStd	229	33	19	36	36	127	109	106	124	90	59	38	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.2	27.7	30.4	32.4	32.6	30.6	30.1	30.3	29.7	28.3	26.4	24.0
		MCWB	14.8	15.0	16.1	17.8	19.2	22.3	22.8	22.5	21.9	20.8	19.1	17.3
	2%	DB	23.1	26.2	29.0	31.1	30.9	29.1	28.7	29.1	28.5	27.1	25.1	22.7
		MCWB	14.5	15.0	16.1	18.2	20.2	22.3	22.5	22.3	21.5	20.4	18.6	16.3
	5%	DB	21.9	25.0	27.8	29.8	29.5	27.9	27.6	27.9	27.5	26.1	23.9	21.5
		MCWB	14.5	14.7	16.1	18.4	20.7	22.2	22.4	22.3	21.4	20.2	17.8	15.7
	10%	DB	20.4	23.4	26.2	28.3	27.9	26.8	26.4	26.7	26.3	25.0	22.7	20.1
		MCWB	14.3	14.7	16.1	18.5	20.7	22.1	22.2	22.1	21.2	19.8	17.3	15.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	18.6	19.9	21.3	23.0	23.6	23.6	23.7	23.2	22.2	20.5	18.7
		MCDB	20.8	23.1	25.1	27.2	27.9	27.8	27.9	28.1	27.3	26.1	24.6	22.0
	2%	WB	16.2	17.2	18.8	20.7	22.4	23.1	23.1	23.1	22.7	21.5	19.6	17.7
		MCDB	19.9	21.6	23.7	26.3	27.0	27.0	26.9	27.1	26.5	25.2	23.0	20.6
	5%	WB	15.5	16.2	18.1	20.1	21.9	22.7	22.7	22.7	22.2	21.0	19.0	16.7
		MCDB	19.3	21.3	23.1	25.7	26.3	26.3	26.1	26.2	25.6	24.5	22.1	19.8
	10%	WB	14.8	15.5	17.3	19.5	21.5	22.4	22.4	22.3	21.8	20.5	18.3	15.9
		MCDB	18.7	20.8	22.7	24.9	25.4	25.6	25.5	25.6	24.8	23.5	21.2	18.9
Mean Daily Temperature Range	5% DB	MDBR	10.1	12.6	12.9	11.8	8.8	6.2	5.7	6.5	7.3	7.4	9.0	9.0
		MCDBR	13.7	16.1	16.5	15.2	12.1	8.2	8.0	8.8	9.3	9.5	10.8	11.2
		MCWBR	6.1	6.0	5.3	4.4	3.3	2.6	2.8	3.1	3.3	3.5	4.8	5.2
	5% WB	MCDBR	10.6	12.7	11.8	11.2	8.5	6.8	6.8	7.4	7.5	7.8	8.5	9.1
		MCWBR	5.1	5.5	5.0	4.2	3.0	2.5	2.7	3.0	3.0	3.2	3.8	4.5
Clear-Sky Solar Irradiance	taub	0.398	0.448	0.677	0.643	0.451	0.413	0.415	0.453	0.459	0.470	0.404	0.410	
	taud	2.220	2.072	1.541	1.664	2.250	2.400	2.375	2.241	2.196	2.117	2.258	2.185	
	Ebn at Noon	859	836	669	705	850	875	874	845	835	805	846	828	
	Edh at Noon	129	159	283	254	141	120	123	141	145	150	123	129	
All-Sky Solar Radiation	RadAvg	3.63	4.73	4.95	5.48	5.13	4.36	4.19	4.42	4.28	3.72	3.78	3.25	
	RadStd	0.38	0.58	0.40	0.48	0.50	0.37	0.33	0.33	0.27	0.36	0.28	0.33	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.27	N/A	N/A	+0.64	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.35	N/A	N/A	+0.58	N/A	N/A	N/A	-47	+175	+131

Nomenclature: See separate page