

BAOJI, China

WMO: 570160

Lat: 34.3524N

Lon: 107.1289E

Elev: 2001

StdP: 13.66

Time Zone: 8.00 (E08)

Period: 94-04

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.7	24.0	2.8	6.8	35.0	6.9	8.4	36.2	13.9	37.8	12.0	37.5	1.1	290	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	95.6	70.9	93.1	70.5	90.7	70.5	76.7	88.0	75.3	86.4	74.0	84.4	7.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.7	135.2	83.2	72.3	128.7	81.5	70.9	122.5	80.5	42.0	88.4	40.5	86.5	39.2	84.3	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
13.9	11.7	9.8	15.4	101.1	2.9	2.0	13.3	102.6	11.6	103.7	10.0	104.8	7.9	106.3		
			13.7	79.0	2.5	1.4	11.9	80.0	10.5	80.9	9.1	81.7	7.3	82.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.0	34.3	39.9	49.1	59.4	69.3	76.6	80.6	77.2	68.2	57.4	46.4	36.5	(6)
(7)		DBStd	17.02	5.44	5.64	7.22	7.70	6.18	5.77	4.86	5.10	6.49	6.09	6.28	5.44	(7)
(8)		HDD50	1460	487	286	102	12	0	0	0	0	10	144	419	(8)	
(9)		HDD65	4107	952	704	494	200	30	2	0	37	246	558	884	(9)	
(10)		CDD50	4380	0	2	74	295	599	797	949	843	547	238	36	0	(10)
(11)		CDD65	1552	0	0	1	33	164	349	484	379	133	9	0	0	(11)
(12)		CDH74	14665	0	0	24	331	1441	3482	5169	3261	884	72	1	0	(12)
(13)		CDH80	6083	0	0	1	83	483	1571	2415	1232	290	8	0	0	(13)
(14)	Wind	WSAvg	3.0	2.5	2.8	3.6	3.6	3.7	3.6	3.9	3.6	2.7	2.2	2.2	(14)	
(15)	Precipitation	PrecAvg	27.2	0.2	0.4	1.1	2.4	2.6	4.7	4.3	5.2	2.7	0.9	0.2	(15)	
(16)		PrecMax	37.4	0.7	1.3	3.3	4.9	7.2	5.6	10.4	16.2	11.3	7.1	2.6	0.9	(16)
(17)		PrecMin	17.0	0.0	0.0	0.0	0.6	0.4	0.2	0.9	0.7	1.1	0.5	0.1	0.0	(17)
(18)		PrecStd	5.4	0.2	0.4	0.7	1.1	1.5	1.6	2.4	3.3	2.6	1.7	0.7	0.2	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.3	61.8	77.2	86.6	93.7	98.7	99.3	96.3	93.9	80.0	70.2	57.5	(19)
(20)		0.4%	MCWB	42.3	45.1	53.4	62.2	64.3	67.6	71.8	73.2	70.5	58.5	53.0	43.8	(20)
(21)		2%	DB	51.6	57.9	70.6	81.7	88.7	95.3	95.6	92.5	87.5	75.5	65.2	53.0	(21)
(22)		2%	MCWB	38.9	42.9	51.7	60.6	63.5	68.8	72.3	72.1	70.3	58.9	51.4	41.2	(22)
(23)		5%	DB	46.2	53.7	65.7	77.6	85.0	92.1	93.4	89.4	82.9	71.1	60.7	49.2	(23)
(24)		5%	MCWB	35.5	41.5	49.8	58.8	62.3	68.0	72.4	71.9	68.7	57.5	49.0	38.8	(24)
(25)		10%	DB	42.9	50.2	61.3	73.3	81.8	89.1	90.9	86.5	78.7	67.2	56.3	45.8	(25)
(26)		10%	MCWB	33.7	39.8	47.9	56.4	62.3	67.3	72.6	72.1	66.4	56.8	47.1	36.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	43.0	46.4	57.6	67.5	69.3	74.7	79.1	78.0	75.4	63.7	55.5	44.7	(27)
(28)		0.4%	MCDWB	58.0	58.4	71.5	77.6	82.4	89.3	90.8	89.1	86.5	72.0	66.7	55.0	(28)
(29)		2%	WB	39.0	44.5	53.2	64.0	67.2	72.8	77.3	76.5	72.5	62.0	52.6	42.1	(29)
(30)		2%	MCDWB	50.8	54.8	66.7	75.2	80.1	86.1	88.5	87.6	82.6	68.1	61.6	50.5	(30)
(31)		5%	WB	36.2	42.7	51.1	60.9	65.4	71.3	75.8	75.1	70.5	60.0	50.2	40.0	(31)
(32)		5%	MCDWB	44.6	51.2	62.5	73.8	79.2	84.2	87.4	84.6	79.8	67.5	58.0	47.4	(32)
(33)		10%	WB	34.4	41.0	49.0	58.5	63.9	70.0	74.5	73.8	68.3	58.2	48.4	38.0	(33)
(34)		10%	MCDWB	41.4	48.9	59.2	70.1	76.8	82.4	86.1	82.4	76.5	65.2	55.4	44.3	(34)
(35)	Mean Daily Temperature Range		MDBR	14.0	14.9	16.3	16.7	18.3	18.0	15.8	13.9	13.2	13.9	14.6	13.2	(35)
(36)		5% DB	MCDBR	21.7	22.0	25.2	25.7	25.8	24.9	20.8	19.6	20.5	21.2	22.1	20.9	(36)
(37)			MCWBR	12.2	11.3	11.3	9.9	9.1	7.5	6.4	6.8	7.4	8.7	10.9	11.8	(37)
(38)			MCDBR	20.2	18.8	21.7	20.4	20.5	18.2	16.0	14.3	16.7	16.9	18.7	19.0	(38)
(39)		5% WB	MCWBR	11.7	10.3	10.6	9.6	8.5	6.8	6.1	5.9	6.9	8.1	10.2	11.2	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.541	0.623	0.659	0.649	0.626	0.625	0.642	0.693	0.647	0.613	0.552	0.495	(40)	
(41)		taud	1.691	1.568	1.543	1.594	1.699	1.750	1.756	1.635	1.693	1.691	1.733	1.801	(41)	
(42)		Ebn at Noon	194	193	202	215	223	223	218	203	204	194	190	199	(42)	
(43)		Edh at Noon	61	76	84	84	76	72	71	79	72	66	58	51	(43)	
(44)	All-Sky Solar Radiation	RadAvg	800	925	1254	1520	1623	1661	1560	1352	1030	901	797	750	(44)	
(45)		RadStd	84	143	119	167	144	136	225	205	125	152	121	100	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page