

FENGXIANG, China

WMO: 570250

Lat: 34.5115N

Lon: 107.3779E

Elev: 2562

StdP: 13.39

Time Zone: 8.00 (E08)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	19.4	-1.6	5.5	26.5	1.7	6.6	28.9	13.5	34.4	12.1	33.1	4.3	340	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	16.0	93.5	69.9	90.7	69.3	87.9	69.2	76.1	85.8	74.5	83.8	73.2	81.9	7.6	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.5	137.2	80.9	71.9	129.9	79.6	70.6	124.0	78.4	41.8	86.4	40.2	84.1	38.9	82.1	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
14.3	12.3	10.9	12.0	98.6	4.8	2.3	8.6	100.3	5.8	101.7	3.1	103.0	-0.4	104.6
			9.7	77.9	4.4	1.6	6.5	79.0	4.0	79.9	1.5	80.8	-1.7	82.0
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	55.5	30.6	37.0	47.8	57.7	65.0	73.9	77.6	74.8	65.5	56.1	44.4	33.8
	DBStd	16.96	6.29	6.94	7.78	6.84	5.72	5.19	4.78	5.39	5.18	5.67	6.38	5.39
	HDD50	1822	601	365	136	16	0	0	0	0	0	13	188	503
	HDD65	4613	1066	784	533	232	73	4	0	3	52	280	618	968
	CDD50	3813	0	2	68	247	466	716	857	770	465	202	20	0
	CDD65	1127	0	0	0	13	73	270	392	307	67	5	0	0
	CDH74	9955	0	0	12	165	741	2594	3683	2408	317	35	0	0
	CDH80	3771	0	0	0	26	194	1105	1562	826	56	2	0	0
Wind	WSAvg	5.2	4.9	5.3	5.7	5.9	5.6	5.6	5.3	4.6	4.7	4.7	4.8	
Precipitation	PrecAvg	23.3	0.2	0.4	0.9	1.5	2.2	2.7	3.9	4.6	4.2	1.9	0.6	0.2
	PrecMax	36.4	1.1	0.9	2.2	4.0	4.8	5.9	7.5	9.1	12.6	3.8	3.1	0.6
	PrecMin	14.5	0.0	0.0	0.0	0.2	0.3	0.6	0.7	1.5	1.1	0.5	0.0	0.0
	PrecStd	4.8	0.2	0.2	0.6	1.0	1.2	1.3	2.1	2.0	2.4	0.8	0.7	0.2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.3	63.6	75.2	83.5	89.1	96.5	98.6	94.4	85.5	78.3	67.9	56.2
		MCWB	39.4	45.9	55.4	60.0	64.0	66.0	72.3	73.0	64.8	60.1	52.6	41.4
	2%	DB	48.7	56.6	70.4	78.7	85.2	92.9	94.0	90.7	81.1	73.2	62.8	50.8
		MCWB	35.9	43.0	52.7	58.7	62.3	66.2	71.5	73.1	66.9	57.8	49.7	38.2
	5%	DB	44.7	52.7	65.7	74.9	81.5	89.8	91.2	87.4	77.6	69.6	57.9	46.6
		MCWB	33.9	40.8	50.2	57.6	62.2	65.4	71.5	72.2	65.1	57.1	47.3	36.0
	10%	DB	40.8	48.2	61.2	71.1	78.1	86.7	88.2	84.8	74.5	65.8	53.9	43.0
		MCWB	31.7	38.4	48.2	56.4	61.9	65.0	71.3	71.9	64.1	55.9	46.1	34.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	40.0	46.9	57.7	64.3	68.6	73.0	78.3	77.4	72.8	63.7	54.6	42.7
		MCDB	52.6	59.7	69.9	77.8	80.7	80.7	87.3	87.5	78.8	70.6	64.3	54.4
	2%	WB	36.6	44.0	54.4	61.6	66.5	70.9	76.4	76.1	69.3	61.4	51.7	39.0
		MCDB	46.7	55.4	66.9	73.7	77.5	81.5	85.7	86.1	75.6	68.2	57.8	49.2
	5%	WB	34.4	41.5	51.3	59.4	64.8	69.3	74.9	74.7	67.2	59.4	49.9	36.7
		MCDB	43.3	50.4	63.6	70.7	75.5	80.4	84.6	83.8	72.7	66.1	55.0	44.9
	10%	WB	32.2	39.4	49.0	57.5	63.3	67.9	73.5	73.5	65.8	57.7	47.6	34.9
		MCDB	40.0	46.6	60.0	68.6	73.7	79.1	83.3	81.7	70.9	63.8	53.1	41.4
Mean Daily Temperature Range	5% DB	MDBR	15.0	15.1	17.2	18.8	19.4	19.3	16.0	13.8	12.2	13.6	14.3	15.3
		MCDBR	22.2	23.8	25.8	26.0	26.9	27.3	22.3	19.0	19.5	21.0	22.0	22.0
		MCWBR	13.2	13.5	13.7	13.4	11.6	7.7	6.6	6.4	7.7	9.0	11.9	13.2
	5% WB	MCDBR	20.6	21.9	23.4	22.4	20.1	17.9	15.7	15.1	12.6	15.7	17.2	20.7
		MCWBR	12.5	12.8	13.2	12.9	10.3	6.5	5.9	5.7	6.1	8.3	9.9	12.8
Clear-Sky Solar Irradiance	taub	0.512	0.593	0.624	0.616	0.595	0.600	0.620	0.669	0.623	0.589	0.527	0.471	
	taud	1.733	1.607	1.588	1.638	1.744	1.785	1.788	1.664	1.720	1.719	1.768	1.838	
	Ebn at Noon	202	201	211	223	230	228	223	208	209	200	197	206	
	Edh at Noon	58	73	81	80	73	70	69	77	69	64	55	49	
All-Sky Solar Radiation	RadAvg	823	958	1284	1541	1645	1691	1590	1356	1051	927	826	773	
	RadStd	85	143	122	166	138	144	230	212	127	154	121	99	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page