

FENGXIANG, China

WMO: 570250

Lat: 34.5115N

Lon: 107.3779E

Elev: 781

StdP: 92.29

Time Zone: 8.00 (E08)

Period: 05-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.6	-7.0	-18.7	0.8	-3.1	-16.8	0.9	-1.7	6.0	1.3	5.4	0.6	1.9	340	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.9	34.2	21.1	32.6	20.7	31.1	20.6	24.5	29.9	23.6	28.8	22.9	27.7	3.4	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.1	19.6	27.1	22.2	18.6	26.5	21.4	17.7	25.8	79.2	30.2	75.6	28.9	72.5	27.8	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
6.4	5.5	4.9	DB	-11.1	37.0	2.7	1.3	-13.0	37.9	-14.6	38.7	-16.1	39.4	-18.0	40.4	
			WB	-12.4	25.5	2.4	0.9	-14.2	26.1	-15.6	26.6	-16.9	27.1	-18.7	27.8	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	13.0	-0.8	2.8	8.8	14.3	18.3	23.3	25.4	23.8	18.6	13.4	6.9	1.0
	DBStd	9.42	3.50	3.86	4.32	3.80	3.18	2.88	2.66	3.00	2.88	3.15	3.55	2.99
	HDD10.0	1012	334	203	76	9	0	0	0	0	0	7	104	279
	HDD18.3	2563	592	436	296	129	41	2	0	2	29	156	343	538
	CDD10.0	2118	0	1	38	137	259	398	476	428	258	112	11	0
	CDD18.3	626	0	0	0	7	41	150	218	171	37	3	0	0
	CDH23.3	5531	0	0	7	92	412	1441	2046	1338	176	19	0	0
	CDH26.7	2095	0	0	0	14	108	614	868	459	31	1	0	0
Wind	WSAvg	2.3	2.2	2.4	2.6	2.6	2.5	2.5	2.5	2.4	2.1	2.1	2.1	2.2
Precipitation	PrecAvg	591	6	9	23	37	57	69	99	116	106	48	16	4
	PrecMax	924	27	24	57	101	123	151	191	231	320	97	78	15
	PrecMin	369	0	0	1	6	8	14	17	39	29	13	0	0
	PrecStd	123	6	6	14	25	31	33	53	51	60	21	19	4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.4	17.6	24.0	28.6	31.7	35.8	37.0	34.7	29.7	25.7	19.9	13.5
		MCWB	4.1	7.7	13.0	15.6	17.8	18.9	22.4	22.8	18.2	15.6	11.4	5.2
	2%	DB	9.3	13.7	21.3	25.9	29.5	33.8	34.5	32.6	27.3	22.9	17.1	10.5
		MCWB	2.2	6.1	11.5	14.9	16.8	19.0	21.9	22.8	19.4	14.3	9.8	3.4
	5%	DB	7.0	11.5	18.7	23.8	27.5	32.1	32.9	30.8	25.3	20.9	14.4	8.1
		MCWB	1.1	4.9	10.1	14.2	16.8	18.5	21.9	22.4	18.4	13.9	8.5	2.2
	10%	DB	4.9	9.0	16.2	21.7	25.6	30.4	31.2	29.3	23.6	18.8	12.2	6.1
		MCWB	-0.2	3.6	9.0	13.6	16.6	18.3	21.8	22.1	17.8	13.3	7.8	1.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.4	8.3	14.3	17.9	20.3	22.8	25.7	25.2	22.7	17.6	12.6	6.0
		MCDB	11.4	15.4	21.0	25.5	27.1	27.0	30.7	30.8	26.0	21.5	17.9	12.4
	2%	WB	2.6	6.7	12.4	16.5	19.1	21.6	24.7	24.5	20.7	16.3	10.9	3.9
		MCDB	8.2	13.0	19.4	23.2	25.3	27.5	29.8	30.1	24.2	20.1	14.3	9.5
	5%	WB	1.3	5.3	10.7	15.2	18.2	20.7	23.8	23.7	19.5	15.2	9.9	2.6
		MCDB	6.3	10.2	17.6	21.5	24.2	26.9	29.2	28.8	22.6	18.9	12.8	7.2
	10%	WB	0.1	4.1	9.4	14.2	17.4	20.0	23.0	23.1	18.8	14.3	8.7	1.6
		MCDB	4.4	8.1	15.6	20.3	23.2	26.2	28.5	27.6	21.6	17.7	11.7	5.2
Mean Daily Temperature Range	5% DB	MDBR	8.4	8.4	9.6	10.5	10.8	10.7	8.9	7.7	6.8	7.6	8.0	8.5
		MCDBR	12.3	13.2	14.3	14.5	14.9	15.1	12.4	10.6	10.9	11.7	12.2	12.2
		MCWBR	7.3	7.5	7.6	7.4	6.4	4.3	3.7	3.6	4.3	5.0	6.6	7.3
	5% WB	MCDBR	11.4	12.2	13.0	12.5	11.2	9.9	8.7	8.4	7.0	8.7	9.6	11.5
		MCWBR	7.0	7.1	7.4	7.1	5.7	3.6	3.3	3.2	3.4	4.6	5.5	7.1
Clear-Sky Solar Irradiance	taub	0.512	0.593	0.624	0.616	0.595	0.600	0.620	0.669	0.623	0.589	0.527	0.471	
	taud	1.733	1.607	1.588	1.638	1.744	1.785	1.788	1.664	1.720	1.719	1.768	1.838	
	Ebn at Noon	638	634	664	702	725	720	702	656	658	631	621	650	
	Edh at Noon	182	231	254	252	229	220	218	243	219	203	174	155	
All-Sky Solar Radiation	RadAvg	2.60	3.02	4.05	4.86	5.19	5.33	5.01	4.28	3.31	2.92	2.60	2.44	
	RadStd	0.27	0.45	0.39	0.52	0.44	0.45	0.72	0.67	0.40	0.48	0.38	0.31	

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	

Nomenclature: See separate page