

HUA SHAN, China

WMO: 570460

Lat: 34.4812N

Lon: 110.0767E

Elev: 2063

StdP: 78.88

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-15.3	-13.3	-28.9	0.3	-6.7	-25.7	0.5	-6.5	16.2	-4.2	14.5	-4.5	6.4	290	0.610

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 4.7	(c) 23.6	(d) 16.5	(e) 22.7	(f) 16.3	(g) 21.7	(h) 15.7	(i) 19.2	(j) 21.8	(k) 18.4	(l) 21.0	(m) 17.6	(n) 20.2	(o) 2.5	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.4	17.1	21.0	17.5	16.2	20.2	16.7	15.4	19.4	65.2	21.8	61.9	21.2	59.0	20.2	24.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 14.3	(b) 12.2	(c) 10.5	(e) -18.1	(f) 25.8	(g) 2.7	(h) 1.3	(i) -20.1	(j) 26.8	(k) -21.6	(l) 27.5	(m) -23.1	(n) 28.3	(o) -25.1	(p) 29.2		
(4) 14.3	(5) 12.2	(6) 10.5	(7) -18.9	(8) 20.8	(9) 2.5	(10) 1.0	(11) -20.8	(12) 21.6	(13) -22.2	(14) 22.1	(15) -23.6	(16) 22.7	(17) -25.5	(18) 23.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	7.2	-5.4	-2.9	2.1	8.0	12.3	16.3	18.4	17.2	12.8	7.6	2.3	-3.5
	DBStd	9.07	4.65	4.64	5.12	4.73	3.74	3.02	2.33	2.69	3.37	3.87	4.54	4.45
	HDD10.0	1954	477	362	248	92	20	1	0	0	11	93	233	418
	HDD18.3	4146	735	595	503	311	188	73	28	53	169	332	482	676
	CDD10.0	915	0	0	4	31	92	191	261	222	94	19	1	0
	CDD18.3	66	0	0	0	0	2	13	31	17	3	0	0	0
	CDH23.3	44	0	0	0	0	1	13	24	5	2	0	0	0
	CDH26.7	2	0	0	0	0	0	1	1	0	0	0	0	0
Wind	WSAvg	4.4	5.0	4.7	4.8	4.7	4.4	3.7	3.5	3.3	3.6	4.2	5.1	5.6
Precipitation	PrecAvg	875	11	19	46	75	90	83	156	129	132	88	35	10
	PrecMax	1262	30	44	116	191	215	257	293	278	300	209	73	36
	PrecMin	659	0	2	0	34	22	20	39	31	40	25	4	0
	PrecStd	145	8	12	25	36	49	55	70	56	71	45	18	9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	8.4	10.5	16.5	20.5	22.1	25.0	25.2	24.0	23.0	17.8	13.4	8.4
		MCWB	0.2	2.9	6.3	9.9	11.7	14.1	17.8	18.3	14.5	10.0	5.7	0.3
	2%	DB	4.7	7.4	13.4	18.3	20.3	23.2	23.8	22.8	20.6	15.4	11.0	5.7
		MCWB	-1.5	0.5	5.4	9.1	10.7	14.5	17.2	18.0	14.3	9.1	4.1	-0.9
	5%	DB	2.9	5.3	11.1	16.1	18.8	22.0	22.9	21.8	18.9	14.1	9.4	4.0
		MCWB	-2.6	-0.4	3.7	8.0	10.3	14.1	16.9	17.2	13.2	8.7	3.4	-1.6
	10%	DB	1.1	3.4	9.0	14.5	17.5	20.8	21.9	20.8	17.5	12.8	8.1	2.4
		MCWB	-3.5	-1.0	2.8	7.2	9.8	13.4	16.5	16.5	12.5	7.6	2.9	-2.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	1.2	3.7	9.0	12.7	14.9	18.5	20.7	20.3	17.8	12.9	7.6	1.8
		MCDB	6.3	7.7	14.3	16.7	18.0	21.6	23.4	22.7	20.4	14.8	10.8	5.0
	2%	WB	-0.7	1.7	6.3	10.8	13.5	17.0	19.4	19.2	16.2	11.1	6.1	0.3
		MCDB	3.5	5.6	10.9	15.1	17.0	20.3	22.3	21.6	18.7	13.4	8.2	4.0
	5%	WB	-2.2	0.4	4.8	9.4	12.4	16.0	18.6	18.4	14.9	10.0	5.1	-0.8
		MCDB	2.3	4.2	9.7	14.1	16.1	19.3	21.3	20.8	17.1	12.7	7.8	3.0
	10%	WB	-3.3	-0.7	3.6	8.2	11.4	15.0	17.9	17.5	13.7	8.8	4.0	-1.9
		MCDB	0.6	2.8	8.2	12.7	15.3	18.6	20.5	19.9	15.9	11.6	7.1	2.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	5.3	5.6	5.9	5.6	5.2	4.7	4.5	4.4	4.8	5.1	5.4
		MCDBR	7.0	7.0	6.9	6.6	6.4	6.2	5.6	5.3	5.4	5.8	6.0	6.7
		MCWBR	4.4	4.4	4.7	4.8	5.1	5.0	4.9	4.7	4.5	4.3	4.2	4.3
	5% WB	MCDBR	6.2	6.1	6.4	6.1	5.8	5.3	5.0	4.9	4.9	5.2	4.8	6.1
		MCWBR	4.3	4.4	4.8	4.7	5.1	4.9	4.3	4.3	4.3	4.1	3.9	4.3
Clear-Sky Solar Irradiance	taub	0.386	0.443	0.459	0.457	0.446	0.479	0.495	0.513	0.470	0.454	0.414	0.365	
	taud	1.992	1.875	1.879	1.938	2.031	1.984	2.000	1.919	1.992	1.945	1.980	2.067	
	Ebn at Noon	781	776	807	833	845	814	798	775	788	756	743	780	
	Edh at Noon	138	175	189	187	172	180	176	188	166	160	139	121	
All-Sky Solar Radiation	RadAvg	2.54	3.02	4.12	4.91	5.25	5.38	5.07	4.52	3.56	3.10	2.58	2.38	
	RadStd	0.28	0.51	0.42	0.43	0.42	0.51	0.58	0.58	0.39	0.46	0.36	0.32	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	+1.85	N/A	+0.45	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	-0.90	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page