

LUSHI, China

WMO: 570670

Lat: 34.0803N

Lon: 111.0728E

Elev: 2164

StdP: 13.58

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.2	19.1	-3.3	5.0	31.1	1.7	6.5	31.5	12.2	36.3	11.1	35.5	1.7	250	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.4	93.9	73.1	91.4	72.6	88.9	71.9	78.1	87.8	76.8	85.8	75.5	83.6	4.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.7	145.9	82.6	74.5	139.8	81.4	73.2	133.9	80.5	43.6	88.2	42.2	85.9	40.9	83.8	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.1	9.9	8.2	10.3	98.8	3.6	2.4	7.7	100.5	5.6	101.9	3.6	103.3	1.0	105.1	
			DB												
			WB	9.0	80.5	3.4	1.5	6.5	81.6	4.5	82.5	2.6	83.3	0.1	84.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	56.6	31.9	37.9	48.1	59.2	66.8	74.1	78.5	76.2	67.4	57.3	45.5	35.0
	DBStd	16.94	5.32	6.60	7.77	7.20	5.36	4.81	4.36	5.08	5.57	5.86	6.64	5.10
	HDD50	1684	562	340	130	13	0	0	0	0	0	10	164	465
	HDD65	4353	1027	759	524	197	45	3	0	2	36	245	585	930
	CDD50	4091	0	1	71	289	520	724	885	812	522	237	30	0
	CDD65	1285	0	0	1	23	100	278	420	348	108	7	0	0
	CDH74	11394	0	0	43	395	1093	2544	3723	2734	755	105	2	0
	CDH80	4480	0	0	7	107	353	1102	1589	1078	232	12	0	0
(14) Wind	WSAvg	2.8	2.7	3.3	3.8	3.7	3.1	2.9	2.6	2.3	2.0	2.0	2.3	2.7
(15) Precipitation	PrecAvg	25.0	0.2	0.4	1.0	1.9	2.5	2.6	5.2	3.8	3.9	2.4	1.0	0.2
	PrecMax	38.8	0.8	1.9	2.6	3.9	6.4	6.3	9.9	7.0	12.7	7.6	2.4	1.0
	PrecMin	17.0	0.0	0.0	0.1	0.6	0.2	0.5	1.7	1.5	1.2	0.3	0.0	0.0
	PrecStd	5.3	0.2	0.4	0.6	0.9	1.5	1.7	2.4	1.7	2.4	1.7	0.6	0.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	56.3	64.9	79.2	88.2	91.7	96.4	97.5	95.4	91.6	81.4	71.7	58.1
		MCWB	41.3	47.1	54.9	62.2	64.0	69.9	74.9	75.7	72.0	62.0	55.1	43.7
	2%	DB	51.1	59.3	73.1	82.8	87.4	93.0	94.0	92.0	86.1	77.0	66.5	53.5
		MCWB	38.1	44.1	52.3	58.9	63.7	69.6	75.4	74.8	69.6	60.7	52.0	41.0
	5%	DB	46.7	54.9	68.0	78.6	84.2	90.0	91.4	89.3	81.9	72.9	62.2	49.4
		MCWB	35.5	41.7	50.2	58.2	63.3	69.3	75.4	74.2	67.7	59.0	49.9	38.3
	10%	DB	42.5	50.5	63.2	74.1	80.4	86.8	88.5	86.2	78.1	68.6	57.5	45.6
		MCWB	33.2	39.6	48.0	56.2	62.4	68.5	74.7	73.2	65.7	57.0	47.3	36.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	42.2	48.6	58.4	67.5	70.3	76.5	80.4	79.3	76.4	65.3	56.9	45.3
		MCDB	54.8	60.7	72.0	80.2	82.5	86.3	91.1	89.2	86.2	74.4	67.2	55.5
	2%	WB	38.7	45.4	54.1	63.0	67.9	74.5	78.6	77.8	72.3	63.0	53.7	42.0
		MCDB	49.8	56.4	68.7	75.9	79.9	85.5	88.5	87.3	81.6	71.8	63.1	51.1
	5%	WB	36.2	43.0	51.7	60.7	66.2	72.6	77.4	76.4	69.8	61.0	51.3	39.5
		MCDB	45.0	52.9	65.4	73.2	77.8	83.4	86.7	84.9	76.8	68.9	60.0	47.1
	10%	WB	34.0	40.6	49.1	58.2	64.6	70.9	76.2	75.1	67.9	59.3	48.9	37.4
		MCDB	41.4	48.8	61.2	70.2	75.7	80.9	84.8	82.2	74.3	66.0	55.7	44.6
(35) Mean Daily Temperature Range	5% DB	MDBR	19.2	19.7	21.7	22.9	22.5	21.3	17.4	16.8	17.1	18.9	19.8	19.2
		MCDBR	28.3	29.6	31.2	32.2	31.5	28.7	23.3	22.3	25.3	27.8	28.4	27.4
		MCWBR	17.4	16.5	14.6	12.8	12.0	9.7	7.6	7.4	9.9	12.6	15.1	16.4
	5% WB	MCDBR	25.9	26.6	28.3	26.5	23.4	22.0	18.5	17.8	19.9	22.2	24.9	24.2
		MCWBR	16.2	15.2	13.9	12.6	10.6	8.8	7.0	6.9	9.0	11.0	13.7	15.1
(40) Clear-Sky Solar Irradiance	taub		0.524	0.604	0.624	0.616	0.604	0.669	0.678	0.703	0.636	0.614	0.560	0.495
	taud		1.715	1.594	1.595	1.651	1.722	1.639	1.672	1.601	1.695	1.660	1.705	1.789
	Ebn at Noon		200	199	211	223	228	213	210	201	207	194	188	199
	Edh at Noon		59	75	80	79	75	81	78	82	72	69	60	52
(44) All-Sky Solar Radiation	RadAvg		783	914	1267	1526	1621	1646	1511	1358	1099	972	799	740
	RadStd		93	179	143	132	141	160	184	190	129	154	124	110

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	-3.53	N/A	-0.77	-1.12	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page