

LUSHI, China

WMO: 570670

Lat: 34.0803N

Lon: 111.0728E

Elev: 660

StdP: 93.65

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.8	-7.2	-19.6	0.7	-0.5	-16.8	0.9	-0.3	5.4	2.4	5.0	1.9	0.7	250	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	9.7	34.4	22.9	33.0	22.6	31.6	22.1	25.6	31.0	24.9	29.9	24.2	28.7	2.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.3	20.8	28.1	23.6	20.0	27.5	22.9	19.1	26.9	83.5	31.2	80.4	29.9	77.3	28.8	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.4	4.4	3.7	-12.1	37.1	2.0	1.3	-13.5	38.1	-14.7	38.9	-15.8	39.6	-17.2	40.6		
(5)			-12.8	27.0	1.9	0.8	-14.2	27.6	-15.3	28.0	-16.3	28.5	-17.7	29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	-0.1	3.3	9.0	15.1	19.3	23.4	25.9	24.5	19.7	14.1	7.5	1.7	(6)
(7)		DBStd	9.41	2.95	3.67	4.32	4.00	2.98	2.67	2.42	2.82	3.09	3.25	3.69	2.83	(7)
(8)		HDD10.0	936	312	189	72	7	0	0	0	0	0	6	91	258	(8)
(9)		HDD18.3	2418	571	422	291	109	25	2	0	1	20	136	325	517	(9)
(10)		CDD10.0	2273	0	1	39	161	289	402	492	451	290	132	17	0	(10)
(11)		CDD18.3	714	0	0	1	13	56	154	233	193	60	4	0	0	(11)
(12)		CDH23.3	6330	0	0	24	219	607	1413	2068	1519	419	58	1	0	(12)
(13)		CDH26.7	2489	0	0	4	59	196	612	883	599	129	7	0	0	(13)
(14)	Wind	WSAvg	1.2	1.2	1.5	1.7	1.7	1.4	1.3	1.2	1.0	0.9	0.9	1.0	1.2	(14)
(15)	Precipitation	PrecAvg	636	6	10	26	48	63	66	131	96	98	61	25	6	(15)
(16)		PrecMax	986	20	48	67	98	163	161	251	178	323	193	60	26	(16)
(17)		PrecMin	433	0	0	3	14	6	12	43	38	30	8	1	0	(17)
(18)		PrecStd	134	5	10	15	22	39	43	61	43	62	44	14	7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	13.5	18.3	26.2	31.2	33.1	35.8	36.4	35.2	33.1	27.4	22.0	14.5	(19)
(20)			MCWB	5.1	8.4	12.7	16.8	17.8	21.1	23.8	24.3	22.2	16.7	12.9	6.5	(20)
(21)		2%	DB	10.6	15.2	22.8	28.2	30.8	33.9	34.4	33.3	30.1	25.0	19.1	11.9	(21)
(22)			MCWB	3.4	6.7	11.3	15.0	17.6	20.9	24.1	23.8	20.9	15.9	11.1	5.0	(22)
(23)		5%	DB	8.1	12.7	20.0	25.9	29.0	32.2	33.0	31.8	27.7	22.7	16.8	9.7	(23)
(24)			MCWB	2.0	5.4	10.1	14.6	17.4	20.7	24.1	23.4	19.8	15.0	9.9	3.5	(24)
(25)		10%	DB	5.9	10.3	17.3	23.4	26.9	30.4	31.4	30.1	25.6	20.3	14.2	7.5	(25)
(26)			MCWB	0.6	4.2	8.9	13.4	16.9	20.3	23.7	22.9	18.7	13.9	8.5	2.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	5.6	9.2	14.7	19.7	21.3	24.7	26.9	26.3	24.7	18.5	13.9	7.4	(27)
(28)			MCDWB	12.7	15.9	22.2	26.8	28.0	30.2	32.9	31.8	30.1	23.6	19.6	13.1	(28)
(29)		2%	WB	3.7	7.5	12.3	17.2	20.0	23.6	25.9	25.4	22.4	17.2	12.0	5.5	(29)
(30)			MCDWB	9.9	13.5	20.4	24.4	26.6	29.7	31.4	30.7	27.6	22.1	17.3	10.6	(30)
(31)		5%	WB	2.4	6.1	10.9	15.9	19.0	22.6	25.2	24.7	21.0	16.1	10.7	4.2	(31)
(32)			MCDWB	7.2	11.6	18.6	22.9	25.4	28.5	30.4	29.4	24.9	20.5	15.6	8.4	(32)
(33)		10%	WB	1.1	4.8	9.5	14.5	18.1	21.6	24.6	23.9	20.0	15.2	9.4	3.0	(33)
(34)			MCDWB	5.2	9.3	16.2	21.2	24.3	27.2	29.3	27.9	23.5	18.9	13.1	7.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.7	10.9	12.1	12.7	12.5	11.8	9.7	9.3	9.5	10.5	11.0	10.7	(35)
(36)			MCDBR	15.7	16.4	17.4	17.9	17.5	15.9	12.9	12.4	14.1	15.4	15.8	15.2	(36)
(37)			MCWBR	9.7	9.1	8.1	7.1	6.6	5.4	4.2	4.1	5.5	7.0	8.4	9.1	(37)
(38)		5% WB	MCDBR	14.4	14.8	15.7	14.7	13.0	12.2	10.3	9.9	11.0	12.3	13.8	13.5	(38)
(39)			MCWBR	9.0	8.4	7.7	7.0	5.9	4.9	3.9	3.8	5.0	6.1	7.6	8.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.524	0.604	0.624	0.616	0.604	0.669	0.678	0.703	0.636	0.614	0.560	0.495	(40)	
(41)		taud	1.715	1.594	1.595	1.651	1.722	1.639	1.672	1.601	1.695	1.660	1.705	1.789	(41)	
(42)		Ebn at Noon	631	627	666	703	719	672	662	634	651	612	593	628	(42)	
(43)		Edh at Noon	187	235	253	249	235	255	245	259	226	216	188	164	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2.47	2.88	3.99	4.81	5.11	5.19	4.76	4.28	3.47	3.06	2.52	2.33	(44)	
(45)		RadStd	0.29	0.56	0.45	0.42	0.45	0.50	0.58	0.60	0.41	0.48	0.39	0.35	(45)	

Historical Trends

		DBAvg		Heating		Cooling		Degree-Days			
				99% DB	99% DP	1% DB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	-1.96	N/A	-0.43	-0.62	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page