

JINGHE SHAANXI, China

WMO: 571310

Lat: 34.4458N

Lon: 108.9723E

Elev: 411

StdP: 96.48

Time Zone: 8.00 (E08)

Period: 06-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.2	(c) -4.9	(d) -19.4	(e) 0.7	(f) -1.2	(g) -16.9	(h) 0.9	(i) 0.3	(j) 7.1	(k) 0.7	(l) 6.3	(m) 0.8	(n) 2.0	(o) 20	(p) 0.412

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.5	(c) 36.3	(d) 23.1	(e) 34.9	(f) 22.6	(g) 33.5	(h) 22.4	(i) 25.9	(j) 33.0	(k) 25.2	(l) 31.9	(m) 24.4	(n) 30.8	(o) 2.8	(p) 40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.0	19.8	30.2	23.2	18.9	29.3	22.5	18.1	28.5	83.2	32.8	79.9	31.9	76.7	30.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.0	(b) 6.1	(c) 5.3	(e) -8.3	(f) 39.0	(g) 2.0	(h) 0.9	(i) -9.8	(j) 39.6	(k) -11.0	(l) 40.1	(m) -12.1	(n) 40.6	(o) -13.5	(p) 41.3		
(a) 7.0	(b) 6.1	(c) 5.3	(e) -10.0	(f) 26.7	(g) 1.8	(h) 0.8	(i) -11.3	(j) 27.3	(k) -12.4	(l) 27.8	(m) -13.4	(n) 28.2	(o) -14.7	(p) 28.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	0.6	4.5	11.2	17.1	21.6	26.3	27.9	26.5	21.2	15.5	8.5	2.6
	DBStd	9.92	3.20	3.71	4.32	3.87	3.46	3.12	3.06	3.28	3.17	3.33	3.59	2.89
	HDD10.0	784	291	157	37	2	0	0	0	0	0	2	69	228
	HDD18.3	2126	549	387	222	66	11	1	0	0	10	99	296	486
	CDD10.0	2741	0	3	76	216	359	488	556	512	335	173	23	0
	CDD18.3	1040	0	0	2	29	111	238	298	254	95	12	0	0
	CDH23.3	10442	0	0	23	234	943	2561	3463	2621	538	59	0	0
CDH26.7	4619	0	0	2	49	335	1211	1724	1149	138	10	0	0	
Wind	WSAvg	2.5	2.2	2.5	2.8	2.7	2.6	2.6	2.7	2.7	2.4	2.2	2.2	2.2
Precipitation	PrecAvg	529	6	9	23	36	56	61	86	84	89	51	23	6
	PrecMax	866	19	28	58	102	143	112	209	196	300	128	65	18
	PrecMin	295	0	0	0	6	3	6	5	9	15	10	0	0
	PrecStd	123	5	7	15	22	35	30	43	46	64	28	19	6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	11.9	18.0	25.8	30.6	34.7	37.2	39.1	36.8	32.6	27.9	20.6	14.2
		MCWB	3.7	8.7	14.4	16.1	18.4	21.0	24.5	25.2	21.3	17.6	12.2	5.7
	2%	DB	9.4	14.7	23.1	28.0	32.1	35.8	36.7	35.1	29.9	24.7	17.4	11.0
		MCWB	2.6	6.8	12.5	15.6	18.1	20.8	24.2	24.7	20.9	16.1	10.9	4.1
	5%	DB	7.7	12.6	20.7	26.1	30.2	34.3	35.2	33.6	28.1	22.8	15.4	9.1
		MCWB	1.7	6.0	11.3	15.2	18.2	20.4	23.9	24.3	20.0	15.5	9.9	3.2
	10%	DB	5.9	10.6	18.4	24.1	28.4	32.7	33.6	32.0	26.4	20.9	13.8	7.6
		MCWB	0.9	5.0	10.0	14.6	17.8	20.2	23.4	23.7	19.4	14.7	9.3	2.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	4.6	9.2	15.6	18.9	21.7	24.2	27.1	26.6	23.8	19.0	13.3	6.5
		MCDB	10.3	16.0	23.0	26.7	29.3	31.0	33.5	34.1	29.4	24.5	17.4	11.6
	2%	WB	3.2	7.7	13.5	17.6	20.5	23.3	26.1	26.0	22.0	17.8	12.2	4.9
		MCDB	7.8	12.9	21.0	24.8	27.7	30.9	33.1	33.1	26.4	21.9	15.1	9.3
	5%	WB	2.3	6.6	12.0	16.5	19.7	22.3	25.3	25.3	21.0	16.9	11.1	4.0
		MCDB	6.8	11.3	19.1	23.4	26.5	29.9	32.5	31.6	25.4	21.2	14.3	7.9
	10%	WB	1.3	5.5	10.8	15.5	18.9	21.6	24.6	24.5	20.3	15.8	10.1	3.1
		MCDB	5.5	9.8	17.1	22.0	25.4	29.0	31.6	30.4	24.4	19.8	13.1	6.5
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.0	9.0	9.8	9.8	9.8	8.5	7.8	7.1	7.3	7.1	7.2
		MCDBR	10.6	11.8	12.5	13.2	13.1	13.1	10.8	9.4	10.1	10.4	10.1	10.0
		MCWBR	5.9	6.3	5.5	5.3	4.6	3.8	3.1	3.0	3.6	4.1	4.9	5.4
	5% WB	MCDBR	9.4	10.5	11.1	11.3	10.3	9.4	8.7	8.4	7.5	8.3	7.8	8.6
		MCWBR	5.5	5.8	5.3	5.2	4.5	3.4	3.1	3.2	3.2	3.7	4.0	4.9
Clear-Sky Solar Irradiance	taub	0.546	0.626	0.642	0.634	0.616	0.645	0.668	0.702	0.655	0.635	0.579	0.513	
	taud	1.696	1.569	1.570	1.620	1.716	1.700	1.698	1.615	1.671	1.654	1.695	1.775	
	Ebn at Noon	607	607	650	689	710	688	669	633	635	594	574	607	
	Edh at Noon	190	240	259	257	236	240	239	255	231	217	189	166	
All-Sky Solar Radiation	RadAvg	2.54	2.99	4.07	4.85	5.19	5.39	5.15	4.50	3.50	3.03	2.57	2.38	
	RadStd	0.27	0.48	0.40	0.47	0.41	0.50	0.65	0.62	0.40	0.46	0.36	0.32	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page