

XIHUA, China

WMO: 571930

Lat: 33.7836N

Lon: 114.5192E

Elev: 53

StdP: 100.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -5.2	(c) -3.9	(d) -18.0	(e) 0.8	(f) 1.6	(g) -15.0	(h) 1.0	(i) 1.1	(j) 6.0	(k) 4.3	(l) 5.3	(m) 4.0	(n) 1.2	(o) 0	(p) 0.362

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.2	(c) 35.3	(d) 25.6	(e) 34.1	(f) 25.5	(g) 32.9	(h) 25.0	(i) 28.6	(j) 32.9	(k) 27.8	(l) 31.9	(m) 27.1	(n) 30.9	(o) 2.0	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.5	23.5	31.5	26.7	22.5	30.7	26.0	21.5	29.8	93.4	32.9	89.8	32.2	86.3	31.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.3	4.5	4.0	-8.2	37.5	1.7	1.2	-9.4	38.4	-10.4	39.0	-11.3	39.7	-12.5	40.6		
			-9.4	29.5	1.5	0.7	-10.5	30.0	-11.4	30.4	-12.2	30.8	-13.3	31.2		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.8	1.8	4.8	10.5	16.2	21.6	26.3	28.0	26.8	22.4	17.1	9.8	3.8		
	DBStd	9.63	3.02	3.69	4.09	3.80	3.12	2.71	2.52	2.74	3.09	3.48	4.16	3.11		
	HDD10.0	693	254	148	43	3	0	0	0	0	0	1	51	192		
	HDD18.3	1999	512	379	244	84	8	0	0	0	4	64	255	449		
	CDD10.0	2817	0	3	59	189	359	488	557	521	372	222	47	1		
	CDD18.3	1081	0	0	1	19	108	238	298	263	127	27	1	0		
	CDH23.3	10678	0	0	12	158	904	2503	3388	2664	883	162	3	0		
	CDH26.7	4371	0	0	1	29	305	1153	1519	1067	268	28	0	0		
(14) Wind	WSAvg	1.7	1.8	2.0	2.2	2.0	1.8	1.5	1.5	1.5	1.4	1.3	1.6	1.8		
(15) Precipitation	PrecAvg	745	15	18	34	53	62	76	184	119	89	56	28	12		
	PrecMax	1263	66	50	82	198	210	202	414	285	302	168	113	41		
	PrecMin	361	0	0	1	6	1	6	75	14	9	0	0	0		
	PrecStd	182	15	15	20	46	49	53	105	74	67	46	26	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	18.1	24.7	29.7	34.3	36.7	36.5	35.7	33.5	29.4	23.6	15.7		
		MCWB	6.9	10.8	17.0	21.7	20.3	22.8	27.4	28.1	24.4	18.6	14.5	8.1		
	2%	DB	11.0	15.3	22.0	27.1	31.8	35.2	35.2	34.1	31.2	27.0	20.7	12.7		
		MCWB	5.1	8.6	14.5	19.3	20.8	22.9	27.4	27.7	23.2	17.2	13.0	6.4		
	5%	DB	9.0	13.1	19.9	25.1	30.0	33.9	34.1	32.7	29.4	25.1	18.3	10.7		
		MCWB	3.8	7.4	13.0	18.1	20.4	22.6	27.2	26.7	22.1	16.8	12.0	5.5		
	10%	DB	6.9	11.2	17.5	23.1	28.1	32.4	32.9	31.5	28.0	23.0	16.2	8.8		
		MCWB	2.7	6.5	11.6	16.7	20.1	22.5	26.7	26.0	21.2	16.2	10.9	4.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	7.9	12.2	18.2	22.9	24.3	27.2	29.7	29.2	27.4	21.1	16.2	9.6		
		MCDB	11.8	16.4	23.6	28.3	29.6	32.7	33.8	33.5	30.9	24.9	20.4	13.5		
	2%	WB	5.8	9.7	15.8	20.5	22.9	26.1	28.8	28.4	25.5	19.4	14.4	7.9		
		MCDB	10.3	13.6	20.7	25.1	28.4	31.4	33.3	32.5	28.9	23.9	19.1	10.8		
	5%	WB	4.5	8.4	13.8	19.0	21.8	25.2	28.2	27.7	23.9	18.3	13.0	6.5		
		MCDB	8.0	12.1	18.7	24.0	27.2	30.3	32.5	31.4	27.2	22.6	17.0	9.6		
	10%	WB	3.3	6.9	12.2	17.6	20.9	24.2	27.5	27.0	22.6	17.3	11.6	5.3		
		MCDB	6.2	10.4	16.7	22.1	26.3	29.2	31.6	30.4	26.0	21.2	15.2	8.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.5	8.1	9.0	9.7	9.9	9.8	7.2	7.0	8.3	9.1	8.5	7.5		
		MCDBR	11.4	11.9	12.4	12.7	13.2	12.6	9.1	8.4	10.6	12.5	12.1	11.5		
	5% WB	MCWBR	6.9	7.0	6.8	7.1	5.2	3.7	3.3	3.3	3.9	4.9	6.2	6.7		
		MCWBR	10.1	10.1	11.5	11.4	10.8	9.5	8.2	7.7	8.5	10.0	10.3	9.6		
(40) Clear-Sky Solar Irradiance	taub		0.605	0.665	0.670	0.669	0.684	0.789	0.750	0.765	0.719	0.720	0.662	0.599		
	taud		1.600	1.522	1.537	1.566	1.587	1.442	1.549	1.508	1.552	1.503	1.557	1.628		
	Ebn at Noon		561	582	633	666	663	595	615	594	592	534	510	533		
	Edh at Noon		212	254	269	272	269	310	278	285	261	255	220	196		
(44) All-Sky Solar Radiation	RadAvg		2.23	2.66	3.88	4.64	5.01	4.98	4.60	4.31	3.62	3.00	2.40	2.10		
	RadStd		0.27	0.50	0.37	0.40	0.39	0.42	0.54	0.60	0.53	0.38	0.36	0.33		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.43	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+72	N/A

Nomenclature: See separate page