

ANKANG, China

WMO: 572450

Lat: 32.6934N

Lon: 109.0417E

Elev: 291

StdP: 97.88

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.1	-1.1	-10.9	1.5	5.0	-8.3	1.9	4.3	5.4	4.4	4.8	5.0	0.9	90	0.344

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.6	36.2	25.3	34.8	25.0	33.4	24.5	27.0	33.2	26.4	32.3	25.8	31.3	2.0	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.5	21.4	30.0	24.8	20.6	29.4	24.3	19.9	28.9	87.3	33.3	84.5	32.6	81.9	31.4	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.2	4.2	3.4	-4.6	38.9	1.5	1.7	-5.7	40.1	-6.6	41.2	-7.4	42.1	-8.5	43.4		
			DB	WB	DB	WB	DB	WB	DB	WB	DB	WB	DB	WB		
			-5.4	28.0	1.5	0.9	-6.5	28.7	-7.3	29.2	-8.2	29.7	-9.3	30.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.7	4.4	7.2	12.2	17.6	21.6	25.5	28.1	27.5	22.6	17.1	10.9	5.7
	DBStd	8.72	2.27	2.90	3.88	3.72	3.06	2.72	2.53	3.14	3.23	3.09	3.11	2.19
	HDD10.0	446	175	85	22	2	0	0	0	0	0	1	27	134
	HDD18.3	1680	433	311	193	56	7	0	0	0	3	62	223	393
	CDD10.0	2904	0	8	90	229	358	464	561	542	378	219	53	1
	CDD18.3	1098	0	0	3	34	108	214	303	283	131	22	0	0
	CDH23.3	10363	0	0	40	304	812	1921	3352	2997	847	89	0	0
	CDH26.7	4525	0	0	6	87	291	826	1596	1411	293	15	0	0
Wind	WSAvg	1.4	1.3	1.5	1.6	1.6	1.5	1.5	1.5	1.5	1.4	1.2	1.2	1.2
Precipitation	PrecAvg	834	4	10	34	72	89	102	142	111	148	82	33	7
	PrecMax	1114	21	31	92	126	157	215	390	239	357	186	78	27
	PrecMin	540	0	0	5	16	25	21	44	30	33	26	5	0
	PrecStd	141	5	9	22	30	35	54	86	56	79	47	17	7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.0	19.1	27.2	31.8	34.3	36.5	38.2	38.2	35.6	28.6	20.7	14.2
		MCWB	7.2	11.1	16.1	19.2	20.9	24.0	26.4	25.9	23.8	19.5	14.5	8.6
	2%	DB	11.8	16.4	24.0	29.2	31.8	34.6	36.3	36.1	32.3	25.8	18.6	12.0
		MCWB	6.2	9.4	14.2	18.3	20.3	23.5	26.1	25.3	23.3	18.6	13.5	7.8
	5%	DB	10.0	14.2	21.4	26.9	29.9	33.0	34.8	34.5	29.9	23.6	16.9	10.7
		MCWB	5.2	8.2	12.9	17.3	19.9	22.9	25.9	25.2	22.3	18.1	12.8	7.0
	10%	DB	8.5	12.3	19.0	24.5	28.0	31.3	33.3	33.0	27.8	21.7	15.4	9.5
		MCWB	4.6	7.3	11.7	16.4	19.4	22.8	25.4	24.9	21.4	17.3	12.2	6.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.1	11.7	17.4	21.6	23.1	26.7	27.9	27.7	26.3	21.1	15.8	10.1
		MCDB	12.2	17.4	25.5	28.7	29.6	32.9	34.5	34.2	33.0	25.5	18.8	12.3
	2%	WB	6.8	10.2	15.1	19.6	22.1	25.2	27.2	26.7	24.4	19.7	14.6	8.7
		MCDB	10.6	15.0	22.3	26.2	27.8	30.9	33.4	33.0	29.7	23.5	17.1	11.2
	5%	WB	5.9	9.1	13.8	18.3	21.3	24.4	26.6	26.2	23.3	18.8	13.6	7.6
		MCDB	9.1	12.9	19.8	24.8	27.0	29.9	32.6	32.2	27.9	22.2	16.0	10.1
	10%	WB	5.0	8.1	12.6	17.2	20.4	23.7	26.1	25.6	22.2	18.0	12.7	6.7
		MCDB	7.9	11.4	17.8	22.8	25.9	28.8	31.7	31.2	26.3	21.0	14.9	8.9
Mean Daily Temperature Range	5% DB	MDBR	7.4	8.3	9.9	10.4	9.5	9.1	8.6	8.4	7.2	6.5	6.4	6.8
		MCDBR	11.1	12.6	14.9	15.6	14.4	12.9	11.2	11.0	11.1	10.2	8.9	9.2
		MCWBR	6.2	6.5	6.2	5.8	4.7	3.7	3.0	2.8	3.4	3.8	4.4	5.4
	5% WB	MCDBR	9.6	10.6	13.4	13.5	11.0	10.2	9.9	9.5	8.8	8.5	7.4	7.8
		MCWBR	5.8	5.6	5.9	5.6	4.2	3.6	3.1	2.9	3.3	3.4	3.9	4.8
Clear-Sky Solar Irradiance	taub	0.594	0.664	0.675	0.651	0.610	0.623	0.631	0.663	0.639	0.619	0.614	0.562	
	taud	1.614	1.519	1.540	1.625	1.764	1.782	1.794	1.710	1.727	1.694	1.645	1.688	
	Ebn at Noon	580	590	634	681	717	706	697	665	655	619	560	578	
	Edh at Noon	212	257	270	257	226	221	218	234	221	212	204	188	
All-Sky Solar Radiation	RadAvg	2.22	2.48	3.55	4.36	4.53	4.80	4.86	4.32	3.23	2.69	2.22	2.05	
	RadStd	0.36	0.51	0.34	0.50	0.56	0.47	0.69	0.55	0.45	0.50	0.39	0.35	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	-62	N/A	N/A
(47)	Regional (6 neighbors)	+0.24	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page