

FANGXIAN, China

WMO: 572590

Lat: 32.0510N

Lon: 110.7474E

Elev: 1427

StdP: 13.95

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	23.6	25.8	10.4	9.8	39.3	14.7	12.2	37.7	14.3	41.5	13.0	40.2	1.7	110	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	94.6	76.2	92.1	75.4	89.6	74.4	80.1	89.7	78.9	87.7	77.7	85.5	4.1	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.7	152.0	85.0	76.5	145.7	83.5	75.5	141.0	82.3	45.2	90.3	43.8	87.6	42.5	85.6	84.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	12.9	11.1	9.5	19.2	99.5	2.6	2.2	17.3	101.1	15.8	102.4	14.3	103.6	12.4	105.2	
(5)				18.3	81.9	2.5	1.2	16.5	82.7	15.0	83.4	13.6	84.1	11.7	85.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	60.0	37.6	42.3	51.5	61.6	69.1	75.9	80.4	78.5	70.7	61.1	50.1	40.6	(6)
(7)		DBStd	15.70	4.94	6.10	7.49	6.95	5.20	4.51	4.05	5.13	5.70	5.70	6.09	4.38	(7)
(8)		HDD50	1054	385	224	72	7	0	0	0	0	2	71	293		(8)
(9)		HDD65	3433	850	636	422	140	21	1	0	1	13	145	446	758	(9)
(10)		CDD50	4720	0	8	118	356	592	776	944	883	621	347	75	0	(10)
(11)		CDD65	1625	0	0	3	40	148	327	479	419	184	25	0	0	(11)
(12)		CDH74	13800	0	0	74	506	1222	2674	4385	3600	1165	172	2	0	(12)
(13)		CDH80	5315	0	0	12	149	422	1062	1805	1456	380	29	0	0	(13)
(14)	Wind	WSAvg	3.1	3.0	3.5	3.7	3.6	3.3	2.9	3.0	3.1	3.1	2.8	2.7	2.8	(14)
(15)	Precipitation	PrecAvg	33.6	0.4	0.7	1.6	3.0	4.0	4.2	5.8	5.2	4.3	2.8	1.3	0.4	(15)
(16)		PrecMax	46.3	0.7	2.0	4.0	5.8	8.0	8.5	11.1	10.8	9.5	7.2	4.0	1.0	(16)
(17)		PrecMin	21.6	0.0	0.0	0.4	0.8	0.7	1.1	2.2	0.9	0.6	0.2	0.2	0.0	(17)
(18)		PrecStd	5.8	0.2	0.5	0.8	1.3	1.3	2.0	2.1	2.3	2.1	1.5	0.7	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.4	68.5	81.0	89.3	92.5	96.3	98.1	97.3	94.0	83.9	72.9	60.1	(19)
(20)		0.4%	MCWB	45.7	51.6	57.7	64.7	67.4	72.9	79.0	77.5	72.5	65.9	57.3	47.1	(20)
(21)		2%	DB	55.3	62.8	75.1	84.3	88.6	92.5	94.8	93.6	88.0	78.8	68.6	56.5	(21)
(22)		2%	MCWB	43.7	48.7	55.8	63.2	67.4	72.6	78.9	76.9	71.9	64.2	55.7	45.5	(22)
(23)		5%	DB	51.2	58.2	69.8	79.9	84.8	89.5	92.0	90.7	84.3	74.9	64.4	53.0	(23)
(24)		5%	MCWB	41.1	46.0	53.8	61.5	66.4	72.0	77.8	76.6	70.6	62.7	53.9	43.6	(24)
(25)		10%	DB	47.4	53.7	65.2	75.4	81.0	86.4	89.2	87.9	80.6	71.0	60.6	49.7	(25)
(26)		10%	MCWB	39.3	43.9	52.0	60.2	66.0	71.8	77.2	75.9	68.9	61.2	52.9	42.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	47.2	53.7	62.1	69.4	73.7	79.1	81.9	81.7	78.2	69.5	60.1	50.0	(27)
(28)		0.4%	MCDWB	57.7	65.2	75.5	80.2	83.2	88.3	92.3	91.0	88.3	78.7	68.2	56.3	(28)
(29)		2%	WB	44.3	49.5	57.6	66.3	71.6	77.1	80.7	79.7	75.2	66.4	58.0	47.1	(29)
(30)		2%	MCDWB	53.3	60.1	70.6	76.7	80.4	85.7	90.9	89.1	83.1	74.9	65.0	53.6	(30)
(31)		5%	WB	42.1	47.2	55.3	64.0	69.8	75.4	79.5	78.4	73.0	64.4	55.7	45.0	(31)
(32)		5%	MCDWB	49.7	55.7	67.0	75.5	78.5	83.5	88.6	87.2	80.0	71.3	62.0	51.3	(32)
(33)		10%	WB	39.9	45.1	53.1	61.7	68.0	73.8	78.3	77.2	71.1	62.7	53.6	43.0	(33)
(34)		10%	MCDWB	46.5	51.9	63.4	72.1	76.5	82.0	86.2	85.0	77.9	68.9	59.2	48.5	(34)
(35)	Mean Daily Temperature Range		MDBR	17.0	17.9	19.9	21.0	19.2	17.7	15.8	15.4	15.2	15.7	16.5	16.6	(35)
(36)		5% DB	MCDBR	26.7	29.1	30.9	31.5	29.2	25.0	21.0	20.6	22.6	23.9	24.4	25.1	(36)
(37)			MCWBR	15.6	15.5	13.3	11.8	10.4	7.9	6.6	6.3	7.9	9.6	12.3	14.8	(37)
(38)			MCDBR	24.2	25.1	26.8	26.3	20.7	18.8	18.2	17.0	17.9	18.7	20.2	21.9	(38)
(39)		5% WB	MCWBR	14.8	13.9	12.1	11.3	9.0	7.3	6.4	6.0	7.6	8.5	10.9	13.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.597	0.660	0.674	0.657	0.620	0.660	0.648	0.685	0.660	0.637	0.619	0.567	(40)	
(41)		taud	1.600	1.516	1.531	1.605	1.724	1.690	1.749	1.652	1.669	1.642	1.627	1.672	(41)	
(42)		Ebn at Noon	185	189	202	215	225	216	218	207	203	193	178	184	(42)	
(43)		Edh at Noon	69	82	87	83	75	77	72	79	75	71	67	61	(43)	
(44)	All-Sky Solar Radiation	RadAvg	695	784	1123	1345	1405	1478	1492	1346	1060	901	743	662	(44)	
(45)		RadStd	115	169	105	150	169	157	198	170	135	144	117	116	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.88	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page