

FANGXIAN, China

WMO: 572590

Lat: 32.0510N

Lon: 110.7474E

Elev: 435

StdP: 96.21

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-4.7	-3.4	-12.0	1.4	4.1	-9.6	1.7	3.2	6.4	5.3	5.8	4.6	0.8	110	0.354

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.8	34.8	24.5	33.4	24.1	32.0	23.6	26.7	32.1	26.0	31.0	25.4	29.7	1.8	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	21.7	29.5	24.7	20.8	28.6	24.2	20.1	27.9	87.2	32.4	84.0	30.9	81.0	29.8	28.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	4.9	4.2	-7.1	37.5	1.4	1.2	-8.2	38.4	-9.0	39.1	-9.8	39.8	-10.9	40.7		
(5)			-7.6	27.7	1.4	0.7	-8.6	28.2	-9.5	28.6	-10.2	29.0	-11.3	29.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	3.1	5.7	10.8	16.5	20.6	24.4	26.9	25.8	21.5	16.2	10.1	4.8		
	DBStd	8.72	2.74	3.39	4.16	3.86	2.89	2.51	2.25	2.85	3.17	3.16	3.39	2.43		
	HDD10.0	586	214	124	40	4	0	0	0	0	1	39	163			
	HDD18.3	1907	472	353	234	78	12	1	0	1	7	81	248	421		
	CDD10.0	2622	0	4	66	198	329	431	524	491	345	193	42	0		
	CDD18.3	903	0	0	2	22	82	182	266	233	102	14	0	0		
	CDH23.3	7667	0	0	41	281	679	1486	2436	2000	647	96	1	0		
	CDH26.7	2953	0	0	7	83	234	590	1003	809	211	16	0	0		
(14) Wind	WSAvg	1.4	1.4	1.6	1.7	1.6	1.5	1.3	1.4	1.4	1.4	1.2	1.2	1.3		
(15) Precipitation	PrecAvg	854	9	17	40	76	102	107	147	133	108	72	33	10		
	PrecMax	1177	19	51	101	147	204	216	281	274	242	184	102	25		
	PrecMin	549	0	0	10	21	19	29	55	23	16	6	5	0		
	PrecStd	148	6	13	21	32	34	52	53	59	54	37	18	7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.8	20.3	27.2	31.8	33.6	35.7	36.7	36.3	34.4	28.8	22.7	15.6		
		MCWB	7.6	10.9	14.3	18.2	19.7	22.7	26.1	25.3	22.5	18.8	14.0	8.4		
	2%	DB	13.0	17.1	23.9	29.0	31.4	33.6	34.9	34.2	31.1	26.0	20.3	13.6		
		MCWB	6.5	9.3	13.2	17.3	19.6	22.6	26.1	25.0	22.2	17.9	13.2	7.5		
	5%	DB	10.7	14.6	21.0	26.6	29.4	32.0	33.4	32.6	29.0	23.8	18.0	11.7		
		MCWB	5.0	7.8	12.1	16.4	19.1	22.2	25.4	24.8	21.4	17.0	12.1	6.4		
	10%	DB	8.6	12.0	18.5	24.1	27.2	30.2	31.8	31.1	27.0	21.7	15.9	9.9		
		MCWB	4.0	6.6	11.1	15.7	18.9	22.1	25.1	24.4	20.5	16.2	11.6	5.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.5	12.1	16.7	20.8	23.1	26.2	27.7	27.6	25.7	20.8	15.6	10.0		
		MCDB	14.3	18.5	24.2	26.8	28.4	31.3	33.5	32.8	31.3	26.0	20.1	13.5		
	2%	WB	6.9	9.7	14.2	19.0	22.0	25.0	27.1	26.5	24.0	19.1	14.4	8.4		
		MCDB	11.8	15.6	21.5	24.8	26.9	29.9	32.7	31.7	28.4	23.8	18.3	12.0		
	5%	WB	5.6	8.5	12.9	17.8	21.0	24.1	26.4	25.8	22.8	18.0	13.2	7.2		
		MCDB	9.9	13.2	19.4	24.2	25.8	28.6	31.4	30.7	26.7	21.8	16.7	10.7		
	10%	WB	4.4	7.3	11.7	16.5	20.0	23.2	25.7	25.1	21.7	17.1	12.0	6.1		
		MCDB	8.0	11.1	17.4	22.3	24.7	27.8	30.1	29.4	25.5	20.5	15.1	9.2		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.4	10.0	11.1	11.6	10.7	9.8	8.8	8.6	8.4	8.7	9.2	9.2		
		MCDBR	14.8	16.2	17.2	17.5	16.2	13.9	11.7	11.4	12.5	13.3	13.5	13.9		
	5% WB	MCWBR	8.7	8.6	7.4	6.5	5.8	4.4	3.7	3.5	4.4	5.4	6.8	8.2		
		MCWBR	13.4	13.9	14.9	14.6	11.5	10.4	10.1	9.4	9.9	10.4	11.2	12.2		
(40) Clear-Sky Solar Irradiance	taub		0.597	0.660	0.674	0.657	0.620	0.660	0.648	0.685	0.660	0.637	0.619	0.567		
	taud		1.600	1.516	1.531	1.605	1.724	1.690	1.749	1.652	1.669	1.642	1.627	1.672		
	Ebn at Noon		583	597	637	678	710	680	686	651	641	608	562	580		
	Edh at Noon		217	259	273	263	235	243	228	248	235	225	210	192		
(44) All-Sky Solar Radiation	RadAvg		2.19	2.47	3.54	4.24	4.43	4.66	4.71	4.24	3.34	2.84	2.34	2.09		
	RadStd		0.36	0.53	0.33	0.47	0.53	0.49	0.62	0.54	0.43	0.46	0.37	0.37		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	+0.49	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page