

DA XIAN, China

WMO: 573280

Lat: 31.2074N

Lon: 107.5067E

Elev: 344

StdP: 97.26

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.3	2.4	-4.1	2.8	5.4	-2.0	3.3	5.5	4.6	6.2	4.0	5.5	1.4	40	0.324

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.8	36.6	25.4	35.3	25.3	34.0	25.0	27.1	33.0	26.5	32.2	26.1	31.4	1.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.7	21.9	29.3	25.2	21.2	29.1	24.7	20.6	28.8	88.2	33.1	85.8	32.3	83.5	31.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 4.7	3.8	3.3	-0.6	38.7	1.2	1.3	-1.4	39.6	-2.1	40.3	-2.8	41.1	-3.6	42.0		
(5)			-1.3	28.3	1.4	1.8	-2.3	29.6	-3.1	30.7	-3.9	31.7	-4.9	33.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	6.8	9.2	13.5	18.6	22.2	25.3	28.5	28.5	23.9	18.4	13.4	8.1	(6)
(7)		DBStd	8.02	2.01	2.56	3.56	3.60	2.75	2.63	2.45	3.14	3.40	3.04	2.85	2.11	(7)
(8)		HDD10.0	223	102	43	7	1	0	0	0	0	0	0	5	66	(8)
(9)		HDD18.3	1314	358	257	154	39	3	0	0	0	1	35	149	317	(9)
(10)		CDD10.0	3170	1	19	117	259	378	458	574	574	416	262	106	7	(10)
(11)		CDD18.3	1221	0	0	6	48	122	208	316	316	167	38	1	0	(11)
(12)		CDH23.3	11643	0	0	41	330	790	1711	3672	3674	1251	173	2	0	(12)
(13)	CDH26.7	5162	0	0	7	95	252	648	1753	1877	488	42	0	0	(13)	
(14)	Wind	WSAvg	1.4	1.1	1.2	1.4	1.5	1.5	1.4	1.6	1.6	1.4	1.2	1.2	1.1	(14)
(15)	Precipitation	PrecAvg	1208	16	18	46	102	155	152	208	155	178	106	50	21	(15)
(16)		PrecMax	1566	44	51	119	173	338	394	542	369	337	365	107	58	(16)
(17)		PrecMin	844	1	3	15	40	32	22	52	36	37	26	20	3	(17)
(18)		PrecStd	209	10	12	23	33	69	84	114	89	90	65	25	12	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	19.6	27.6	32.1	33.7	35.6	37.8	38.5	36.0	31.0	22.7	15.4	(19)
MCWB			9.3	13.0	17.8	20.7	21.4	25.0	26.2	25.4	25.1	21.1	16.3	10.9	(20)	
2%		DB	12.4	16.5	24.0	29.4	31.3	33.7	36.2	37.1	33.6	27.3	20.6	13.6	(21)	
		MCWB	8.4	11.4	15.9	19.7	21.2	24.3	25.9	25.2	24.3	19.8	15.4	10.4	(22)	
5%		DB	10.9	14.7	21.6	27.1	29.4	32.0	35.0	35.7	31.5	25.0	18.8	12.3	(23)	
		MCWB	7.9	10.4	14.7	18.5	21.0	23.9	25.9	25.2	23.2	19.1	15.0	9.6	(24)	
10%		DB	9.9	13.2	19.2	24.9	27.7	30.5	33.7	34.4	29.5	23.0	17.3	11.2	(25)	
		MCWB	7.5	9.5	13.6	17.9	20.5	23.6	25.6	25.1	22.6	18.4	14.4	9.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.3	13.5	19.2	22.3	24.1	26.7	27.9	27.6	26.1	22.6	17.6	12.7	(27)
MCDWB			12.6	18.0	26.0	29.4	28.9	31.9	33.8	33.7	33.5	28.8	20.7	13.9	(28)	
2%		WB	9.2	12.1	16.5	20.8	22.9	25.9	27.2	26.9	25.2	21.1	16.5	11.1	(29)	
		MCDWB	11.3	15.4	22.2	26.2	27.7	30.6	33.0	33.3	31.1	25.0	19.0	12.7	(30)	
5%		WB	8.5	11.1	15.3	19.8	22.1	25.2	26.7	26.3	24.4	20.0	15.7	10.1	(31)	
		MCDWB	10.4	13.8	20.4	25.0	26.8	29.5	32.2	32.4	29.4	22.9	17.8	11.8	(32)	
10%		WB	7.7	10.2	14.3	18.6	21.3	24.5	26.3	25.8	23.5	19.1	14.9	9.2	(33)	
		MCDWB	9.6	12.6	18.5	23.5	25.7	28.6	31.4	31.6	27.9	22.0	16.8	10.8	(34)	
(35)	Mean Daily Temperature Range	MDBR	4.8	6.0	7.5	8.1	7.7	7.1	7.8	8.4	6.8	5.7	5.2	4.5	(35)	
5% DB		MCDBR	7.5	9.4	11.9	12.7	11.8	10.4	10.0	10.6	10.3	9.9	8.1	6.5	(36)	
		MCWBR	4.2	4.9	4.9	4.5	3.7	3.1	2.4	2.3	3.0	3.5	3.8	3.7	(37)	
		MCDBR	6.2	7.8	10.4	10.5	8.6	8.1	8.7	9.3	8.7	7.9	6.7	5.1	(38)	
(39)		5% WB	MCWBR	3.7	4.3	4.5	4.5	3.5	2.9	2.6	2.8	3.1	3.3	3.5	3.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.723	0.759	0.765	0.732	0.672	0.638	0.623	0.645	0.663	0.719	0.752	0.724	(40)	
taud		1.417	1.379	1.403	1.499	1.653	1.754	1.810	1.742	1.673	1.517	1.441	1.445	(41)		
Ebn at Noon		492	532	578	629	675	696	704	681	642	552	470	462	(42)		
Edh at Noon		266	301	313	294	253	228	215	227	235	258	257	248	(43)		
(44)	All-Sky Solar Radiation	RadAvg	1.59	1.88	2.98	3.86	3.97	4.17	5.02	4.70	3.27	2.35	1.76	1.42	(44)	
(45)		RadStd	0.25	0.31	0.30	0.48	0.57	0.53	0.71	0.63	0.45	0.39	0.30	0.24	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.37	+0.55	N/A	+0.56	N/A	N/A	-33	-78	+119	+58
(47)	Regional (5 neighbors)	+0.31	N/A	N/A	+0.74	N/A	N/A	-29	N/A	+88	+36

Nomenclature: See separate page