

FENGJIE, China

WMO: 573480

Lat: 31.0280N

Lon: 109.4783E

Elev: 303

StdP: 97.74

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.5	2.6	-6.9	2.2	5.6	-4.7	2.6	6.2	6.4	6.6	5.6	7.0	1.7	0	0.337

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.4	37.2	25.0	35.7	24.6	34.2	24.3	26.7	32.5	26.2	32.0	25.6	31.3	1.7	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
25.6	21.6	28.8	24.7	20.5	28.6	24.2	19.8	28.3	86.4	32.8	83.6	32.0	81.2	31.4	32.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
5.8	4.8	4.1	0.2	38.6	1.8	1.8	-1.1	39.9	-2.2	40.9	-3.2	41.9	-4.5	43.2		
			-1.5	27.7	1.8	1.3	-2.8	28.7	-3.9	29.5	-4.9	30.2	-6.2	31.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	7.3	9.4	13.7	18.6	22.2	25.5	28.5	28.6	24.4	19.0	14.0	8.9
	DBStd	7.98	2.58	2.98	3.98	3.82	3.06	3.03	2.70	3.27	3.47	3.29	3.09	2.49
	HDD10.0	199	89	43	11	1	0	0	0	0	0	5	51	
	HDD18.3	1248	342	251	151	43	4	1	0	2	31	132	292	
	CDD10.0	3263	7	26	126	258	378	466	574	432	278	125	17	
	CDD18.3	1268	0	0	8	49	124	216	316	318	183	51	2	0
	CDH23.3	12333	0	1	56	348	848	1880	3672	3774	1514	239	1	0
CDH26.7	5491	0	0	11	101	278	753	1774	1937	582	55	0	0	
Wind	WSAvg	1.8	1.7	1.8	2.0	1.9	1.8	1.6	1.7	1.8	1.8	1.7	1.7	1.6
Precipitation	PrecAvg	1038	13	22	46	90	146	161	167	128	116	88	45	15
	PrecMax	1341	31	73	84	166	196	303	292	347	252	196	134	51
	PrecMin	773	1	1	20	27	75	42	62	11	11	21	2	0
	PrecStd	144	7	17	17	37	37	53	65	75	60	48	28	11
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.0	20.5	28.3	32.4	33.9	37.1	38.6	39.2	36.2	31.2	23.1	16.6
		MCWB	9.3	13.3	17.2	19.9	21.3	24.0	25.6	25.0	24.0	21.6	16.4	11.3
	2%	DB	14.0	17.6	24.5	29.4	31.7	34.6	36.8	37.7	33.8	28.0	21.3	14.8
		MCWB	8.8	11.8	15.5	18.7	21.0	23.7	25.6	24.8	23.2	19.5	15.6	10.4
	5%	DB	12.3	15.6	22.1	27.1	29.7	32.5	35.2	36.1	31.8	26.0	19.8	13.6
		MCWB	8.4	10.4	14.2	17.9	20.7	23.4	25.3	24.6	22.6	19.0	15.0	9.8
	10%	DB	11.1	13.9	20.0	25.0	27.8	30.7	33.6	34.5	30.1	24.0	18.4	12.5
		MCWB	7.5	9.5	13.1	17.3	20.0	23.1	25.1	24.4	22.0	18.2	14.4	9.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.1	14.9	18.6	21.5	24.5	26.6	28.1	27.4	25.6	23.1	17.9	12.8
		MCDB	13.4	18.7	26.3	29.4	29.6	32.1	32.5	33.3	31.7	28.4	20.7	14.9
	2%	WB	10.0	12.5	16.3	20.1	23.0	25.5	27.0	26.6	24.7	21.1	16.7	11.2
		MCDB	13.0	16.1	22.5	26.3	28.2	30.8	32.6	32.8	30.9	25.3	19.6	13.9
	5%	WB	8.8	11.3	15.1	19.1	21.9	24.8	26.4	26.0	24.0	19.8	15.8	10.3
		MCDB	12.0	14.7	20.7	24.6	26.7	29.6	31.9	32.4	29.2	23.8	18.7	12.8
	10%	WB	7.7	10.1	14.0	18.1	21.0	24.1	25.9	25.4	23.2	18.9	15.0	9.5
		MCDB	10.6	13.2	18.6	23.4	25.7	28.8	31.2	31.6	28.1	22.7	17.8	12.0
Mean Daily Temperature Range	5% DB	MDBR	4.6	5.6	7.3	8.1	7.6	7.4	8.0	8.4	7.1	6.0	5.2	4.5
		MCDBR	7.1	9.1	11.7	12.7	11.8	11.2	10.5	11.1	10.0	9.6	7.6	6.5
		MCWBR	3.4	4.2	4.5	4.2	3.7	3.1	2.6	2.4	2.7	3.2	3.3	3.3
	5% WB	MCDBR	5.9	7.7	10.3	10.3	9.1	8.6	8.9	9.7	8.1	7.6	6.0	5.6
		MCWBR	3.1	3.9	4.1	4.0	3.5	2.9	3.0	2.7	2.8	3.1	2.9	3.1
Clear-Sky Solar Irradiance	taub	0.672	0.711	0.740	0.720	0.649	0.641	0.613	0.648	0.645	0.661	0.673	0.638	
	taud	1.490	1.452	1.442	1.519	1.700	1.757	1.843	1.740	1.716	1.614	1.549	1.556	
	Ebn at Noon	531	566	596	637	691	694	711	679	657	596	528	528	
	Edh at Noon	247	280	301	288	242	227	208	228	225	234	230	221	
All-Sky Solar Radiation	RadAvg	1.80	2.04	3.12	3.82	3.98	4.26	4.72	4.53	3.40	2.65	2.10	1.77	
	RadStd	0.35	0.38	0.26	0.49	0.64	0.56	0.65	0.48	0.42	0.43	0.34	0.34	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+1.24	+1.56	N/A	+1.78	+0.54	+0.48	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.60	N/A	N/A	N/A	N/A	+79	N/A

Nomenclature: See separate page