

ZHONGXIANG, China

WMO: 573780

Lat: 31.1983N

Lon: 112.6325E

Elev: 357

StdP: 14.51

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 27.8	(c) 29.8	(d) 10.7	(e) 9.6	(f) 39.6	(g) 15.4	(h) 12.2	(i) 39.1	(j) 16.4	(k) 36.8	(l) 15.0	(m) 36.8	(n) 6.0	(o) 340	(p) 0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.0	95.4	81.1	93.5	80.3	91.6	79.3	83.7	91.6	82.7	90.3	81.6	88.9	8.0	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.8	167.5	88.8	80.7	161.4	88.0	79.6	155.7	86.9	48.4	91.8	47.1	90.5	45.9	89.1	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.3	13.5	11.9		DB	24.0	98.1	3.0	1.5	21.9	99.2	20.2	100.1	18.5	100.9	16.3	102.0
				WB	22.0	85.2	2.9	1.2	19.9	86.1	18.2	86.9	16.6	87.6	14.4	88.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.2	39.4	44.2	53.7	63.9	72.9	79.2	83.5	82.4	74.9	65.3	54.0	43.6
	DBStd	16.37	5.59	6.85	7.57	7.33	5.81	5.06	4.57	5.47	6.10	6.33	6.96	5.39
	HDD50	809	330	182	47	3	0	0	0	0	0	0	38	209
	HDD65	2921	793	582	358	102	8	0	0	0	4	74	335	665
	CDD50	5621	2	20	161	422	710	876	1039	1003	748	475	156	9
	CDD65	2259	0	0	7	71	253	426	574	539	302	84	3	0
	CDH74	22418	0	1	34	413	1880	4157	6892	6184	2412	433	12	0
	CDH80	9217	0	0	3	82	588	1569	3213	2827	854	81	0	0
Wind	WSAvg	5.9	5.7	5.8	6.2	6.4	6.0	5.7	6.2	6.0	6.0	5.4	5.4	5.6
Precipitation	PrecAvg	37.9	0.8	1.3	2.2	3.3	4.7	5.0	7.0	4.5	3.9	2.8	1.8	0.7
	PrecMax	59.7	2.1	4.0	4.9	8.9	12.0	12.4	16.9	13.3	12.2	7.6	4.6	2.0
	PrecMin	22.0	0.0	0.0	0.4	0.6	0.4	0.6	0.4	0.6	0.2	0.0	0.0	0.0
	PrecStd	8.1	0.6	1.0	1.2	1.9	2.2	2.9	4.4	3.3	2.6	1.8	1.2	0.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.1	67.2	78.2	86.6	91.8	95.2	97.5	98.4	94.9	86.8	75.7	62.5
		MCWB	47.9	56.4	65.6	71.8	72.3	76.8	83.0	81.0	78.1	69.0	61.1	50.0
	2%	DB	54.5	61.8	72.6	82.2	88.8	92.5	95.3	95.6	90.7	81.7	71.2	58.3
		MCWB	45.6	51.7	60.3	69.5	71.4	76.8	82.4	81.3	75.1	65.8	58.6	48.4
	5%	DB	51.4	58.0	69.0	78.8	86.1	90.1	93.5	93.4	87.8	78.9	67.6	55.0
		MCWB	43.3	49.0	58.4	66.2	70.4	76.5	81.9	80.9	74.4	64.4	57.1	46.5
	10%	DB	48.1	54.5	65.3	75.4	83.3	87.8	91.6	91.0	84.9	75.6	64.2	52.1
		MCWB	41.7	46.7	56.2	64.8	69.6	76.1	81.1	79.7	72.7	63.7	55.8	45.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.1	58.4	67.9	74.6	77.7	82.6	85.7	84.7	80.9	72.5	63.4	53.0
		MCDB	56.5	64.5	74.6	82.7	86.0	90.4	93.8	92.9	90.0	80.4	71.0	57.8
	2%	WB	46.9	53.4	63.0	71.8	75.4	80.9	84.2	83.6	79.3	69.1	60.8	50.3
		MCDB	52.7	59.8	70.2	79.6	83.0	88.3	92.2	91.4	86.9	76.8	67.5	55.8
	5%	WB	44.5	50.4	60.0	68.9	73.6	79.5	83.1	82.5	77.2	67.4	59.0	48.0
		MCDB	49.7	55.3	66.9	76.5	80.6	86.3	91.0	89.8	84.3	74.8	65.5	53.7
	10%	WB	42.3	48.4	57.3	66.3	71.9	78.2	82.0	81.5	75.1	65.8	56.9	46.0
		MCDB	47.0	53.3	63.8	73.7	79.6	84.5	89.6	88.5	82.1	72.6	63.1	51.0
Mean Daily Temperature Range	5% DB	MDBR	10.8	12.1	13.3	13.8	13.8	12.0	11.0	12.1	12.7	12.7	12.0	11.4
		MCDBR	16.7	18.1	18.2	17.9	18.0	15.2	13.5	14.8	16.5	18.1	17.3	17.0
		MCWBR	9.8	10.0	9.4	8.1	6.2	5.4	4.8	4.6	5.2	6.1	7.8	9.5
	5% WB	MCDBR	14.9	14.8	16.6	16.4	14.2	12.6	13.1	13.3	14.3	15.0	14.6	15.1
		MCWBR	9.6	9.4	9.6	9.1	6.9	5.7	5.5	5.3	6.1	6.3	7.6	9.2
Clear-Sky Solar Irradiance	taub		0.655	0.713	0.724	0.717	0.700	0.724	0.676	0.710	0.726	0.715	0.689	0.645
	taud		1.520	1.453	1.461	1.516	1.587	1.573	1.696	1.610	1.551	1.514	1.526	1.561
	Ebn at Noon		172	179	192	203	208	203	212	202	190	176	163	166
	Edh at Noon		76	89	94	92	86	87	76	82	84	82	75	69
All-Sky Solar Radiation	RadAvg		642	749	1095	1302	1393	1430	1538	1431	1160	945	757	637
	RadStd		101	173	85	141	148	158	181	156	145	132	100	111

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	N/A	N/A	N/A	+0.63	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page