

ZHONGXIANG, China

WMO: 573780

Lat: 31.1983N

Lon: 112.6325E

Elev: 109

StdP: 100.02

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-2.3	-1.2	-11.8	1.4	4.2	-9.2	1.7	3.9	7.3	2.7	6.7	2.7	2.7	340	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.1	35.2	27.3	34.2	26.9	33.1	26.3	28.7	33.1	28.1	32.4	27.6	31.6	3.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.6	23.9	31.6	27.0	23.1	31.1	26.5	22.2	30.5	94.7	33.2	91.7	32.5	88.8	31.7	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
6.8	6.0	5.3	-4.4	36.7	1.7	0.9	-5.6	37.3	-6.6	37.8	-7.5	38.3	-8.7	38.9
			-5.6	29.6	1.6	0.7	-6.7	30.1	-7.7	30.5	-8.6	30.9	-9.8	31.4
				DB										
				WB										

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	17.3	4.1	6.8	12.0	17.7	22.7	26.2	28.6	28.0	23.8	18.5	12.2	6.4	(6)
(7)		DBStd	9.09	3.11	3.80	4.21	4.07	3.23	2.81	2.54	3.04	3.39	3.52	3.87	3.00	(7)
(8)		HDD10.0	449	183	101	26	2	0	0	0	0	0	21	116		(8)
(9)		HDD18.3	1623	441	323	199	57	4	0	0	2	41	186	369		(9)
(10)		CDD10.0	3123	1	11	89	234	394	487	577	557	416	264	87	5	(10)
(11)		CDD18.3	1255	0	0	4	39	141	237	319	299	168	47	2	0	(11)
(12)		CDH23.3	12454	0	1	19	229	1044	2309	3829	3436	1340	241	7	0	(12)
(13)		CDH26.7	5121	0	0	2	46	327	872	1785	1571	474	45	0	0	(13)
(14)	Wind	WSAvg	2.6	2.5	2.6	2.8	2.8	2.7	2.6	2.8	2.7	2.7	2.4	2.4	2.5	(14)
(15)	Precipitation	PrecAvg	962	21	32	57	85	120	126	177	114	99	70	46	18	(15)
(16)		PrecMax	1517	53	102	125	225	304	314	429	339	310	193	116	50	(16)
(17)		PrecMin	560	0	0	10	16	10	16	11	14	4	0	1	0	(17)
(18)		PrecStd	206	14	25	31	49	57	73	111	83	67	45	30	14	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	15.1	19.5	25.7	30.3	33.2	35.1	36.4	36.9	35.0	30.5	24.3	16.9	(19)
MCWB			8.8	13.5	18.7	22.1	22.4	24.9	28.3	27.2	25.6	20.6	16.2	10.0	(20)	
2%		DB	12.5	16.6	22.5	27.9	31.5	33.6	35.2	35.3	32.6	27.6	21.8	14.6	(21)	
		MCWB	7.6	10.9	15.7	20.9	21.9	24.9	28.0	27.4	23.9	18.8	14.8	9.1	(22)	
5%		DB	10.8	14.5	20.5	26.0	30.1	32.3	34.2	34.1	31.0	26.0	19.8	12.8	(23)	
		MCWB	6.3	9.4	14.7	19.0	21.3	24.7	27.7	27.1	23.6	18.0	13.9	8.1	(24)	
10%		DB	9.0	12.5	18.5	24.1	28.5	31.0	33.1	32.8	29.4	24.2	17.9	11.2	(25)	
		MCWB	5.4	8.2	13.5	18.2	20.9	24.5	27.3	26.5	22.6	17.6	13.2	7.4	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	10.1	14.7	19.9	23.7	25.4	28.1	29.9	29.3	27.1	22.5	17.4	11.7	(27)
MCDWB			13.6	18.0	23.7	28.2	30.0	32.5	34.3	33.8	32.2	26.9	21.7	14.3	(28)	
2%		WB	8.3	11.9	17.2	22.1	24.1	27.1	29.0	28.7	26.3	20.6	16.0	10.2	(29)	
		MCDWB	11.5	15.4	21.2	26.4	28.3	31.3	33.4	33.0	30.5	24.9	19.7	13.2	(30)	
5%		WB	7.0	10.2	15.6	20.5	23.1	26.4	28.4	28.1	25.1	19.7	15.0	8.9	(31)	
		MCDWB	9.9	12.9	19.4	24.7	27.0	30.1	32.8	32.1	29.0	23.8	18.6	12.1	(32)	
10%		WB	5.7	9.1	14.0	19.0	22.2	25.7	27.8	27.5	23.9	18.8	13.8	7.8	(33)	
		MCDWB	8.3	11.8	17.7	23.1	26.5	29.2	32.0	31.4	27.8	22.6	17.3	10.5	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.0	6.7	7.4	7.6	7.6	6.7	6.1	6.7	7.1	7.1	6.7	6.3	(35)
MCDBR			9.3	10.0	10.1	9.9	10.0	8.4	7.5	8.2	9.2	10.0	9.6	9.5	(36)	
MCWBR			5.4	5.6	5.2	4.5	3.4	3.0	2.7	2.5	2.9	3.4	4.4	5.3	(37)	
5% WB		MCDBR	8.3	8.2	9.2	9.1	7.9	7.0	7.3	7.4	7.9	8.3	8.1	8.4	(38)	
		MCWBR	5.3	5.2	5.3	5.1	3.8	3.2	3.1	2.9	3.4	3.5	4.2	5.1	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.655	0.713	0.724	0.717	0.700	0.724	0.676	0.710	0.726	0.715	0.689	0.645	(40)	
taud		1.520	1.453	1.461	1.516	1.587	1.573	1.696	1.610	1.551	1.514	1.526	1.561	(41)		
Ebn at Noon		543	564	606	639	656	639	667	636	598	555	514	522	(42)		
Edh at Noon		239	279	295	289	270	273	241	260	266	258	236	219	(43)		
(44)	All-Sky Solar Radiation	RadAvg	2.02	2.36	3.45	4.10	4.39	4.51	4.85	4.51	3.66	2.98	2.39	2.01	(44)	
(45)		RadStd	0.32	0.55	0.27	0.44	0.47	0.50	0.57	0.49	0.46	0.42	0.31	0.35	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.35	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page