

LIANGPING, China

WMO: 574260

Lat: 30.6805N

Lon: 107.7921E

Elev: 1493

StdP: 13.92

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 32.5	(c) 34.7	(d) 27.0	(e) 22.1	(f) 39.2	(g) 29.5	(h) 24.9	(i) 39.1	(j) 11.3	(k) 42.8	(l) 9.7	(m) 43.3	(n) 1.8	(o) 40	(p) 0.327

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 14.6	(c) 96.7	(d) 76.3	(e) 94.5	(f) 76.2	(g) 92.2	(h) 76.0	(i) 80.0	(j) 90.1	(k) 79.0	(l) 88.6	(m) 78.0	(n) 87.2	(o) 4.3	(p) 140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.4	150.8	84.9	76.5	146.2	83.7	75.6	141.9	82.6	45.1	90.1	44.0	88.6	42.9	87.4	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.4	(b) 9.0	(c) 7.6	(e) 28.3	(f) 100.0	(g) 2.2	(h) 2.3	(i) 26.7	(j) 101.7	(k) 25.4	(l) 103.1	(m) 24.2	(n) 104.4	(o) 22.5	(p) 106.1		
(a) 10.4	(b) 9.0	(c) 7.6	(e) 27.8	(f) 81.7	(g) 2.3	(h) 1.2	(i) 26.1	(j) 82.6	(k) 24.7	(l) 83.4	(m) 23.4	(n) 84.0	(o) 21.7	(p) 84.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.5	43.1	47.3	55.2	64.3	70.8	76.0	82.1	81.9	74.3	64.5	55.6	45.6
	DBStd	14.34	3.75	4.83	6.44	6.54	5.05	4.83	4.18	5.27	6.11	5.39	5.25	3.96
	HDD50	493	214	101	20	1	0	0	0	0	0	0	13	144
	HDD65	2545	678	495	311	89	9	1	0	0	3	75	283	601
	CDD50	5415	1	26	181	431	646	780	996	988	728	449	181	8
	CDD65	1992	0	0	7	69	190	331	531	523	281	59	1	0
	CDH74	18396	0	1	57	488	1214	2541	5891	5775	2132	294	3	0
	CDH80	7834	0	0	9	132	368	908	2689	2823	832	73	0	0
Wind	WSAvg	3.3	2.7	3.1	3.5	3.6	3.5	3.3	3.7	3.6	3.5	3.1	2.8	2.6
Precipitation	PrecAvg	51.2	0.6	0.8	2.1	4.4	6.6	7.4	8.0	6.1	7.8	4.4	2.2	0.9
	PrecMax	73.9	1.5	2.0	6.2	8.3	13.5	14.8	27.3	15.2	18.1	7.8	4.3	2.1
	PrecMin	34.2	0.1	0.0	0.5	2.2	3.5	1.3	1.3	0.7	1.5	1.9	0.8	0.1
	PrecStd	8.9	0.4	0.5	1.3	1.6	2.2	2.9	5.0	3.8	4.2	1.5	0.9	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.9	68.4	80.4	88.7	91.7	94.9	98.7	100.1	96.4	87.7	73.0	59.5
		MCWB	49.0	56.1	64.4	68.9	70.2	75.7	78.5	76.4	74.7	69.5	61.0	52.0
	2%	DB	53.9	61.4	74.3	84.0	87.6	91.5	96.1	97.4	92.4	81.1	68.9	56.3
		MCWB	47.2	53.2	60.6	66.8	70.2	75.3	77.4	76.1	74.7	67.0	59.9	50.7
	5%	DB	51.1	57.9	69.8	79.6	84.2	88.4	93.9	95.2	88.4	76.7	65.8	53.8
		MCWB	46.1	50.9	58.5	65.1	69.8	74.8	77.3	76.0	72.9	66.2	58.8	49.5
	10%	DB	48.9	54.9	65.8	75.7	80.6	85.5	91.6	92.6	84.9	72.9	63.1	51.6
		MCWB	45.1	49.3	56.7	64.0	68.8	74.4	77.4	75.9	72.0	64.8	58.0	47.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	50.8	57.7	66.7	71.6	75.5	79.8	81.7	80.7	78.3	72.0	63.3	54.5
		MCDB	54.4	64.7	77.7	83.2	83.9	87.5	92.5	92.3	89.9	82.6	69.2	56.9
	2%	WB	48.7	54.3	61.8	68.9	73.3	78.1	80.5	79.4	76.4	69.4	61.5	52.1
		MCDB	52.4	59.7	71.3	79.4	81.3	86.6	90.9	90.5	87.4	76.6	66.2	54.9
	5%	WB	47.0	52.2	59.4	66.9	71.5	76.8	79.6	78.3	75.1	67.6	60.0	49.9
		MCDB	50.2	56.5	67.4	75.6	79.8	84.3	89.1	88.8	84.2	73.3	64.1	52.8
	10%	WB	45.6	50.2	57.5	65.2	70.0	75.5	78.6	77.4	73.7	66.1	58.7	48.4
		MCDB	48.3	54.0	64.3	73.3	77.9	82.3	87.4	87.3	81.4	71.2	62.3	50.9
Mean Daily Temperature Range	5% DB	MDBR	8.9	10.6	13.1	14.1	13.6	13.0	14.6	15.7	12.8	10.4	9.7	8.6
		MCDBR	15.2	17.7	21.6	23.2	21.9	19.7	19.0	20.5	19.3	19.1	15.3	13.4
		MCWBR	9.0	9.7	9.3	8.5	7.2	6.4	5.1	4.7	5.2	7.0	7.3	7.9
	5% WB	MCDBR	12.7	14.2	18.7	18.5	16.5	15.2	15.9	17.3	16.3	14.7	12.6	10.5
MCWBR		8.1	8.4	8.9	7.7	7.0	6.2	5.5	5.4	5.5	6.2	6.7	6.6	
Clear-Sky Solar Irradiance	taub	0.723	0.750	0.763	0.734	0.664	0.630	0.605	0.631	0.650	0.717	0.753	0.731	
	taud	1.410	1.385	1.403	1.495	1.664	1.768	1.848	1.766	1.693	1.512	1.433	1.428	
	Ebn at Noon	157	172	185	200	216	223	228	220	207	177	150	147	
	Edh at Noon	86	95	100	94	80	71	66	70	73	82	83	81	
All-Sky Solar Radiation	RadAvg	493	594	928	1186	1209	1277	1589	1482	1061	738	562	444	
	RadStd	81	91	83	153	194	177	203	192	147	121	93	73	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	+1.82	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (7 neighbors)	+0.52	N/A	N/A	+1.31	N/A	N/A	N/A	N/A	+160	+74

Nomenclature: See separate page