

ENSHI, China

WMO: 574470

Lat: 30.2861N

Lon: 109.4711E

Elev: 1503

StdP: 13.92

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	31.8	33.5	23.9	19.1	39.6	27.1	22.2	39.7	8.3	42.7	7.2	41.7	2.1	270	0.322

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.7	95.7	76.5	93.4	75.8	91.1	75.2	79.1	88.8	78.3	87.5	77.5	85.9	4.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
77.2	149.5	81.7	76.3	145.0	81.4	75.4	141.0	81.1	44.1	89.4	43.3	87.8	42.4	86.3	82.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.4	7.0	5.5	DB	29.1	99.3	2.1	1.4	27.6	100.3	26.3	101.1	25.1	101.9	23.6	103.0	(4)
(5)			WB	28.1	80.9	2.2	1.2	26.5	81.7	25.2	82.4	24.0	83.0	22.5	83.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	63.0	42.3	46.1	54.1	63.7	70.5	76.5	81.8	81.8	74.2	64.4	54.9	45.2	(6)
(7)		DBStd	14.63	4.43	5.09	6.56	6.31	4.94	4.85	4.10	4.61	5.60	5.33	5.26	3.93	(7)
(8)		HDD50	575	242	128	33	1	0	0	0	0	0	0	16	155	(8)
(9)		HDD65	2682	705	530	343	97	10	0	0	0	3	77	303	614	(9)
(10)		CDD50	5336	3	19	158	411	637	794	986	985	727	446	164	6	(10)
(11)		CDD65	1968	0	0	4	57	182	345	521	520	280	58	1	0	(11)
(12)		CDH74	16968	0	0	42	410	1132	2615	5243	5321	1946	257	2	0	(12)
(13)		CDH80	6848	0	0	5	105	356	965	2264	2415	689	49	0	0	(13)
(14)	Wind	WSAvg	2.4	2.1	2.2	2.6	2.7	2.6	2.5	2.9	3.0	2.6	2.2	2.0	2.0	(14)
(15)	Precipitation	PrecAvg	57.9	1.0	1.3	2.6	5.0	7.6	8.9	9.6	6.1	7.3	4.7	2.6	1.2	(15)
(16)		PrecMax	76.9	2.3	3.1	6.3	8.9	13.3	18.7	20.4	17.0	16.1	10.2	6.0	2.9	(16)
(17)		PrecMin	40.4	0.2	0.2	1.0	1.0	3.3	3.7	1.4	1.3	0.9	0.6	0.1	0.1	(17)
(18)		PrecStd	9.5	0.5	0.7	1.3	1.9	2.4	4.1	5.2	3.3	3.9	2.4	1.3	0.7	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.5	65.6	79.0	87.9	91.3	95.5	98.0	98.3	94.6	85.4	72.6	59.0	(19)
(20)			MCWB	49.0	53.9	61.4	66.6	68.3	74.0	77.8	76.5	75.2	69.0	60.2	50.7	(20)
(21)		2%	DB	54.1	60.3	73.3	83.0	87.6	91.8	95.3	96.1	90.6	80.2	68.7	55.6	(21)
(22)			MCWB	46.2	51.0	58.5	64.7	69.0	73.6	77.3	76.4	73.5	65.8	58.9	49.7	(22)
(23)		5%	DB	50.9	56.3	68.9	78.9	84.1	88.8	92.9	93.8	87.3	76.5	65.2	53.3	(23)
(24)			MCWB	45.6	49.4	56.3	63.9	68.0	73.4	76.8	76.0	72.1	65.0	57.8	48.4	(24)
(25)		10%	DB	48.5	53.5	64.6	74.5	80.5	85.8	90.5	91.2	83.9	72.9	62.4	51.1	(25)
(26)			MCWB	44.7	49.3	54.9	62.7	67.7	73.0	76.6	75.5	70.9	64.2	57.2	47.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	56.2	64.8	70.9	75.1	79.0	80.8	79.9	78.0	72.0	63.0	54.7	(27)
(28)			MCDWB	55.1	61.1	73.3	79.8	81.7	86.9	90.3	91.4	87.8	78.4	67.2	56.1	(28)
(29)		2%	WB	48.8	53.5	60.6	68.6	72.8	77.4	79.5	78.8	76.5	69.4	61.2	51.3	(29)
(30)			MCDWB	51.4	57.1	68.9	76.2	79.6	84.7	88.9	89.3	85.1	75.5	64.7	53.5	(30)
(31)		5%	WB	46.7	51.6	58.5	66.4	71.1	76.5	78.7	77.9	75.3	67.3	59.7	49.0	(31)
(32)			MCDWB	49.6	54.1	65.1	73.6	78.2	83.0	88.0	87.8	82.8	72.7	63.2	51.7	(32)
(33)		10%	WB	45.3	49.8	56.5	64.2	69.5	75.3	78.0	77.1	73.8	65.6	58.2	47.6	(33)
(34)			MCDWB	48.0	52.8	62.4	71.8	76.2	81.1	86.4	86.3	80.2	70.8	61.7	50.2	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.8	10.3	13.8	15.2	14.8	14.1	14.7	15.9	13.8	11.5	10.3	8.8	(35)
(36)			MCDBR	16.0	18.8	24.2	25.6	24.2	21.4	19.5	20.3	20.6	19.8	17.0	14.0	(36)
(37)			MCWBR	8.5	9.4	9.8	8.8	7.5	6.0	4.5	4.4	5.6	6.8	7.8	7.6	(37)
(38)		5% WB	MCDBR	11.7	12.3	19.2	19.0	16.3	14.3	16.3	17.0	15.3	14.5	13.0	10.1	(38)
(39)			MCWBR	6.8	7.0	8.6	8.0	6.7	5.1	4.6	4.6	5.2	6.2	6.7	6.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.670	0.701	0.732	0.715	0.632	0.621	0.587	0.627	0.634	0.662	0.672	0.643	(40)	
(41)		taud	1.490	1.466	1.453	1.528	1.732	1.796	1.903	1.780	1.731	1.607	1.547	1.543	(41)	
(42)		Ebn at Noon	171	183	192	204	223	225	232	221	212	190	170	168	(42)	
(43)		Edh at Noon	79	88	95	91	74	69	62	69	71	75	74	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	516	595	926	1133	1191	1270	1464	1423	1068	799	636	519	(44)	
(45)		RadStd	110	116	83	155	210	180	196	146	141	135	116	108	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.61	N/A	N/A	+1.17	N/A	N/A	N/A	-119	+216	+115
(47) Regional (5 neighbors)		N/A	N/A	N/A	+1.17	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page