

JIANGLING, China

WMO: 574760

Lat: 30.3503N

Lon: 112.1480E

Elev: 108

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.7	30.7	15.3	12.0	39.3	19.4	14.6	38.0	16.0	37.0	14.2	38.1	4.5	20	0.364

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	11.4	95.3	82.0	93.6	81.1	91.8	80.0	83.7	92.0	82.8	90.8	81.8	89.5	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.7	165.4	88.8	80.7	160.1	88.1	79.7	154.9	87.4	48.1	92.2	47.0	90.9	45.9	89.9	86.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
14.5	12.8	11.2	DB	25.6	98.0	2.4	1.9	23.8	99.4	22.4	100.5	21.0	101.5	19.3	102.8
			WB	24.0	85.2	2.2	1.0	22.4	85.9	21.1	86.5	19.9	87.0	18.3	87.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	40.4	44.9	53.8	63.9	72.8	78.9	83.8	82.7	75.5	65.8	54.8	44.6
	DBStd	16.02	5.59	6.77	7.30	6.83	5.52	4.77	4.52	5.26	5.83	6.01	6.72	5.24
	HDD50	722	301	166	44	2	0	0	0	0	0	30	179	
	HDD65	2791	763	563	353	96	7	0	0	0	3	64	309	633
	CDD50	5681	3	23	161	420	705	868	1046	1013	766	490	174	12
	CDD65	2275	0	0	6	65	247	418	581	548	318	88	4	0
	CDH74	22648	0	1	38	393	1765	3965	7127	6372	2544	425	18	0
	CDH80	9373	0	0	4	76	551	1448	3388	2922	905	78	1	0
Wind	WSAvg	4.8	4.4	4.8	5.2	5.2	4.9	4.8	5.5	5.2	4.9	4.2	4.2	4.3
Precipitation	PrecAvg	42.6	0.9	1.7	3.0	4.3	5.6	6.0	5.6	5.0	3.8	3.4	2.3	1.0
	PrecMax	61.1	2.1	5.3	6.4	11.0	11.7	14.7	13.8	15.4	18.1	10.2	6.0	2.6
	PrecMin	25.3	0.1	0.0	0.8	0.7	0.9	0.7	0.2	0.1	0.2	0.0	0.0	0.0
	PrecStd	9.8	0.6	1.1	1.6	2.1	2.5	3.1	3.6	3.7	3.3	2.3	1.5	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	60.9	68.6	79.0	86.0	92.2	94.5	97.8	97.5	94.4	86.6	76.8	63.9
		MCWB	49.8	57.8	67.4	72.4	73.5	79.3	82.9	82.4	79.4	70.4	62.1	52.3
	2%	DB	55.5	62.7	72.6	82.1	88.8	92.3	95.7	95.2	91.0	81.8	71.7	59.2
		MCWB	47.2	52.8	61.5	70.0	72.6	78.2	82.7	82.2	77.3	67.5	60.1	49.4
	5%	DB	52.1	58.5	68.8	78.5	85.8	90.0	93.9	93.4	88.1	78.7	68.0	56.1
		MCWB	45.0	49.9	59.2	67.7	71.8	77.5	82.2	81.5	75.5	65.1	58.1	48.0
	10%	DB	49.0	54.9	65.2	75.1	82.8	87.5	92.0	91.3	85.3	75.6	64.7	53.1
		MCWB	43.3	48.1	57.3	65.8	70.5	76.9	81.4	80.5	73.7	64.7	57.0	46.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.1	59.8	68.2	75.0	78.4	82.6	85.3	84.8	81.9	73.8	64.8	54.2
		MCDB	57.8	67.1	75.4	82.6	87.4	90.8	93.7	93.2	90.6	80.3	72.4	59.5
	2%	WB	48.3	54.1	63.7	72.1	76.3	81.1	84.1	83.6	79.9	70.2	62.0	51.7
		MCDB	53.8	60.0	69.7	78.9	83.6	89.1	92.6	91.9	87.9	77.5	67.7	57.2
	5%	WB	45.9	51.5	60.9	69.4	74.5	79.8	83.1	82.7	78.2	68.3	60.2	49.2
		MCDB	50.9	56.7	67.2	75.9	81.1	86.9	91.4	90.6	85.7	75.4	66.1	55.1
	10%	WB	43.9	49.2	58.1	66.9	72.7	78.4	82.2	81.7	76.2	66.6	58.0	47.2
		MCDB	48.2	54.1	63.9	74.0	79.5	84.4	90.2	89.2	82.8	73.0	63.7	52.0
Mean Daily Temperature Range	5% DB	MDBR	10.6	11.6	12.8	13.4	13.6	11.7	11.4	11.7	12.6	12.7	12.0	11.5
		MCDBR	17.3	19.3	19.3	19.1	19.0	15.3	13.9	14.1	16.2	18.3	17.8	18.4
		MCWBR	10.0	10.8	10.1	8.8	6.5	5.0	4.7	4.8	5.4	6.0	7.9	10.0
	5% WB	MCDBR	15.7	16.2	17.1	17.0	14.6	12.7	13.3	13.3	14.3	15.1	15.0	16.7
		MCWBR	9.9	10.0	10.0	9.1	6.8	5.6	5.2	5.2	6.2	6.3	7.8	9.8
Clear-Sky Solar Irradiance	taub	0.685	0.738	0.751	0.743	0.714	0.723	0.659	0.706	0.742	0.743	0.715	0.674	
	taud	1.484	1.422	1.429	1.486	1.580	1.587	1.738	1.621	1.529	1.479	1.497	1.522	
	Ebn at Noon	167	175	187	198	206	203	216	203	187	172	160	161	
	Edh at Noon	80	92	97	95	87	86	73	82	87	86	78	73	
All-Sky Solar Radiation	RadAvg	605	707	1027	1231	1330	1377	1579	1455	1168	922	739	614	
	RadStd	103	172	67	140	151	168	168	146	127	129	103	114	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page