

NEIJANG, China

WMO: 575030

Lat: 29.6198N

Lon: 105.1186E

Elev: 1145

StdP: 14.10

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	36.1	38.3	29.2	24.2	43.7	32.4	28.0	44.0	9.8	45.6	8.7	46.6	2.6	20	0.312

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.4	96.0	78.6	93.6	78.1	91.5	77.4	81.2	90.4	80.3	89.0	79.4	87.7	4.7	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.1	157.7	85.5	78.2	152.8	84.7	77.3	148.4	84.0	46.2	90.6	45.2	89.3	44.3	87.9	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10.8	9.2	7.7	32.5	99.8	2.4	2.2	30.8	101.4	29.4	102.7	28.1	103.9	26.4	105.5
			32.3	83.1	2.5	0.6	30.5	83.5	29.1	83.9	27.7	84.2	25.9	84.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	45.7	49.7	57.5	66.9	73.3	76.9	82.1	82.4	74.1	65.5	57.8	48.4	(6)
(7)		DBStd	13.54	3.80	4.92	6.14	6.58	5.49	4.27	4.53	5.18	6.00	4.83	5.06	3.68	(7)
(8)		HDD50	285	138	60	8	1	0	0	0	0	0	5	73	(8)	
(9)		HDD65	2114	597	429	244	54	5	0	0	2	51	217	515	(9)	
(10)		CDD50	5797	6	51	239	507	723	808	994	1003	724	480	239	23	(10)
(11)		CDD65	2149	0	0	10	110	262	358	529	538	276	65	1	0	(11)
(12)		CDH74	19292	0	0	46	687	1917	2738	5813	6008	1895	186	2	0	(12)
(13)		CDH80	7797	0	0	3	185	647	875	2561	2800	695	31	0	0	(13)
(14)	Wind	WSAvg	3.3	2.8	3.1	3.7	4.0	4.1	3.5	3.4	3.5	3.3	3.0	2.8	2.7	(14)
(15)	Precipitation	PrecAvg	41.7	0.6	0.7	0.9	2.1	4.1	6.7	8.5	7.7	5.9	2.7	1.3	0.6	(15)
(16)		PrecMax	63.8	1.6	1.7	2.8	4.4	9.6	14.4	18.7	20.9	15.5	5.9	2.6	1.3	(16)
(17)		PrecMin	27.3	0.2	0.2	0.1	0.4	0.9	1.3	3.2	1.1	2.0	0.7	0.3	0.1	(17)
(18)		PrecStd	8.7	0.3	0.4	0.6	1.1	1.7	3.4	3.5	4.5	3.5	1.2	0.6	0.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.7	67.4	78.2	90.9	93.6	93.1	97.8	99.5	97.0	84.5	73.5	60.7	(19)
(20)		0.4%	MCWB	49.6	54.1	62.7	71.4	70.6	76.6	79.7	78.7	78.2	72.3	61.7	53.9	(20)
(21)		2%	DB	55.7	63.7	74.7	85.5	89.5	90.4	95.1	96.7	91.8	78.9	69.6	57.7	(21)
(22)		2%	MCWB	48.1	52.8	60.6	67.4	69.9	75.8	79.6	78.5	77.1	69.4	60.4	51.5	(22)
(23)		5%	DB	53.4	60.7	71.1	81.2	86.6	87.8	93.1	94.2	87.3	75.4	66.8	55.4	(23)
(24)		5%	MCWB	47.2	51.3	59.1	66.7	70.1	75.0	79.2	78.4	75.2	67.3	59.5	50.5	(24)
(25)		10%	DB	51.5	57.5	67.6	77.7	83.4	85.1	90.9	91.6	83.4	72.4	64.4	53.6	(25)
(26)		10%	MCWB	46.6	50.2	57.7	65.7	69.3	74.6	78.7	78.2	73.8	66.2	59.0	49.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.2	55.6	64.7	73.1	76.4	80.7	82.5	82.4	81.0	73.2	63.0	55.5	(27)
(28)		0.4%	MCDWB	56.1	64.5	74.4	86.8	85.6	87.2	91.7	93.3	92.4	80.8	68.3	58.3	(28)
(29)		2%	WB	49.6	53.8	62.4	70.6	74.4	78.8	81.4	81.0	78.8	70.8	62.0	53.5	(29)
(30)		2%	MCDWB	53.2	62.1	70.5	80.3	82.9	85.4	90.3	90.7	87.5	76.6	66.9	55.9	(30)
(31)		5%	WB	48.5	52.1	60.3	68.6	72.6	77.4	80.6	80.1	76.9	69.0	60.9	51.6	(31)
(32)		5%	MCDWB	51.8	58.9	68.8	77.0	80.7	83.5	89.2	89.2	85.4	73.7	64.6	54.5	(32)
(33)		10%	WB	47.3	50.6	58.4	66.9	71.1	76.2	79.8	79.3	74.9	67.2	59.9	50.0	(33)
(34)		10%	MCDWB	50.4	56.4	66.2	75.1	78.9	82.0	87.9	87.8	81.2	71.1	63.3	52.5	(34)
(35)	Mean Daily Temperature Range		MDBR	8.1	10.0	11.7	13.4	13.7	11.3	12.4	13.4	10.2	8.2	8.1	7.2	(35)
(36)		5% DB	MCDBR	12.3	16.5	18.7	19.7	19.6	16.8	16.5	17.6	17.2	13.8	12.8	11.9	(36)
(37)		5% DB	MCWBR	6.0	7.2	7.1	5.9	5.4	4.7	4.4	4.0	5.0	5.2	5.1	6.0	(37)
(38)		5% WB	MCDBR	9.7	15.1	16.3	16.2	14.3	12.2	14.2	15.0	14.3	12.0	9.8	8.7	(38)
(39)		5% WB	MCWBR	5.4	7.2	7.0	6.0	6.1	4.7	4.8	4.8	5.1	5.3	4.6	4.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.746	0.778	0.805	0.784	0.725	0.702	0.692	0.726	0.750	0.822	0.823	0.791	(40)	
(41)		taud	1.391	1.359	1.352	1.422	1.559	1.622	1.649	1.574	1.511	1.376	1.357	1.369	(41)	
(42)		Ebn at Noon	155	168	177	190	204	207	209	200	187	157	139	137	(42)	
(43)		Edh at Noon	89	99	105	101	89	83	80	86	89	96	91	87	(43)	
(44)	All-Sky Solar Radiation	RadAvg	497	681	964	1220	1309	1217	1521	1403	995	687	558	444	(44)	
(45)		RadStd	80	113	123	153	178	191	193	207	155	116	58	68	(45)	

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)	
(47)	Regional (7 neighbors)	(m) N/A	N/A	-0.99	+0.99	N/A	N/A	N/A	N/A	+169	N/A	(47)

Nomenclature: See separate page