

NEIJANG, China

WMO: 575030

Lat: 29.6198N

Lon: 105.1186E

Elev: 349

StdP: 97.20

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.3	3.5	-1.6	3.5	6.5	0.2	4.0	6.6	4.4	7.5	3.9	8.1	1.2	20	0.312

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.4	35.5	25.9	34.2	25.6	33.0	25.2	27.3	32.4	26.8	31.7	26.4	30.9	2.1	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.2	22.5	29.7	25.7	21.8	29.3	25.2	21.2	28.9	89.6	32.5	87.3	31.8	85.0	31.0	29.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.8	4.1	3.4	0.3	37.6	1.3	1.2	-0.7	38.5	-1.4	39.3	-2.2	40.0	-3.1	40.9		
			0.2	28.4	1.4	0.3	-0.8	28.6	-1.6	28.8	-2.4	29.0	-3.4	29.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	7.6	9.8	14.1	19.4	22.9	25.0	27.8	28.0	23.4	18.6	14.3	9.1	(6)
		DBStd	7.52	2.11	2.73	3.41	3.66	3.05	2.37	2.52	2.88	3.34	2.68	2.81	2.04	
		HDD10.0	158	77	33	4	1	0	0	0	0	0	0	3	41	
		HDD18.3	1174	332	238	136	30	3	0	0	1	28	121	286		
		CDD10.0	3221	3	28	133	282	402	449	552	557	402	267	133	13	
		CDD18.3	1194	0	0	6	61	146	199	294	299	153	36	1	0	
		CDH23.3	10718	0	0	26	382	1065	1521	3229	3338	1053	103	1	0	
(13)		CDH26.7	4332	0	0	2	103	359	486	1423	1556	386	17	0	0	(13)
(14)	Wind	WSAvg	1.5	1.3	1.4	1.7	1.8	1.8	1.6	1.5	1.6	1.5	1.4	1.3	1.2	(14)
(15)	Precipitation	PrecAvg	1058	16	17	22	53	103	170	216	196	151	68	32	15	(15)
(16)		PrecMax	1621	41	43	70	113	243	365	476	530	394	149	65	34	(16)
(17)		PrecMin	693	5	4	2	10	24	34	81	29	51	17	8	2	(17)
(18)		PrecStd	222	8	10	14	28	44	86	90	115	90	31	14	8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	14.8	19.7	25.7	32.7	34.2	34.0	36.6	37.5	36.1	29.1	23.0	15.9		(19)
(20)		0.4% MCWB	9.8	12.3	17.1	21.9	21.5	24.8	26.5	26.0	25.7	22.4	16.5	12.2		(20)
(21)		2% DB	13.2	17.6	23.7	29.7	31.9	32.4	35.0	36.0	33.2	26.0	20.9	14.3		(21)
(22)		2% MCWB	9.0	11.6	15.9	19.7	21.1	24.3	26.4	25.8	25.1	20.8	15.8	10.8		(22)
(23)		5% DB	11.9	15.9	21.7	27.3	30.4	31.0	33.9	34.6	30.7	24.1	19.3	13.0		(23)
(24)		5% MCWB	8.4	10.7	15.1	19.3	21.2	23.9	26.2	25.8	24.0	19.6	15.3	10.3		(24)
(25)		10% DB	10.8	14.2	19.8	25.4	28.6	29.5	32.7	33.1	28.5	22.4	18.0	12.0		(25)
(26)		10% MCWB	8.1	10.1	14.3	18.7	20.7	23.7	25.9	25.7	23.2	19.0	15.0	9.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	10.6	13.1	18.2	22.8	24.7	27.1	28.0	28.0	27.2	22.9	17.2	13.1		(27)
(28)		0.4% MCDB	13.4	18.0	23.6	30.4	29.8	30.6	33.2	34.1	33.5	27.1	20.2	14.6		(28)
(29)		2% WB	9.8	12.1	16.9	21.5	23.6	26.0	27.5	27.2	26.0	21.6	16.7	11.9		(29)
(30)		2% MCDB	11.8	16.7	21.4	26.9	28.3	29.7	32.4	32.6	30.8	24.8	19.4	13.3		(30)
(31)		5% WB	9.2	11.2	15.7	20.4	22.6	25.2	27.0	26.7	25.0	20.6	16.1	10.9		(31)
(32)		5% MCDB	11.0	14.9	20.5	25.0	27.0	28.6	31.8	31.8	29.7	23.2	18.1	12.5		(32)
(33)		10% WB	8.5	10.3	14.7	19.4	21.7	24.5	26.5	26.3	23.8	19.6	15.5	10.0		(33)
(34)		10% MCDB	10.2	13.5	19.0	24.0	26.1	27.8	31.1	31.0	27.4	21.7	17.4	11.4		(34)
(35)	Mean Daily Temperature Range	MDBR	4.5	5.5	6.5	7.4	7.6	6.3	6.9	7.4	5.7	4.6	4.5	4.0		(35)
(36)		5% DB MCDBR	6.8	9.2	10.4	10.9	10.9	9.3	9.2	9.8	9.5	7.7	7.1	6.6		(36)
(37)		5% WB MCWBR	3.3	4.0	4.0	3.3	3.0	2.6	2.4	2.2	2.8	2.9	2.8	3.3		(37)
(38)		5% WB MCDBR	5.4	8.4	9.0	9.0	8.0	6.8	7.9	8.3	8.0	6.7	5.5	4.8		(38)
(39)		5% WB MCWBR	3.0	4.0	3.9	3.3	3.4	2.6	2.7	2.7	2.9	2.9	2.6	2.7		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.746	0.778	0.805	0.784	0.725	0.702	0.692	0.726	0.750	0.822	0.823	0.791		(40)
(41)		taud	1.391	1.359	1.352	1.422	1.559	1.622	1.649	1.574	1.511	1.376	1.357	1.369		(41)
(42)		Ebn at Noon	490	529	559	599	642	654	658	629	588	495	439	433		(42)
(43)		Edh at Noon	279	312	332	319	279	261	253	270	279	302	286	274		(43)
(44)	All-Sky Solar Radiation	RadAvg	1.57	2.15	3.04	3.85	4.13	3.83	4.79	4.42	3.14	2.17	1.76	1.40		(44)
(45)		RadStd	0.25	0.36	0.39	0.48	0.56	0.60	0.61	0.65	0.49	0.37	0.18	0.21		(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (7 neighbors)	N/A	N/A	-0.55	+0.55	N/A	N/A	N/A	N/A	+94	N/A	

Nomenclature: See separate page