

CHONGQING, China

WMO: 575160

Lat: 29.5758N

Lon: 106.4609E

Elev: 853

StdP: 14.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.0	38.9	28.2	22.9	43.3	31.6	26.7	43.0	13.0	46.9	11.7	46.0	4.0	0	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.6	99.4	77.0	96.9	77.2	94.6	77.0	81.0	90.8	80.0	89.8	79.1	88.7	5.6	70

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	154.1	86.0	77.5	147.5	84.9	76.8	143.9	84.3	45.7	91.0	44.6	90.2	43.6	89.1	88.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.0	11.1	9.6	32.9	103.1	2.7	2.9	31.0	105.2	29.4	106.9	27.9	108.5	26.0	110.6
			31.6	83.1	2.7	1.5	29.6	84.1	28.1	85.0	26.6	85.9	24.6	86.9
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.8	46.0	50.4	58.0	66.8	72.9	77.5	84.4	84.4	76.1	66.2	57.9	48.5	
	DBStd	14.18	3.88	5.23	6.43	6.84	5.46	5.17	5.08	6.12	6.82	5.45	5.29	3.75	
	HDD50	270	133	53	7	0	0	0	0	0	0	0	4	73	
	HDD65	2074	590	409	233	58	4	0	0	0	1	48	219	512	
	CDD50	6050	8	64	255	505	709	826	1065	1065	783	503	240	27	
	CDD65	2377	0	0	16	113	247	376	600	600	334	86	5	0	
	CDH74	23487	0	0	95	723	1654	3039	7351	7411	2848	360	6	0	
	CDH80	10995	0	0	20	211	564	1157	3748	3974	1233	88	0	0	
Wind	WSAvg	4.3	3.8	4.1	4.6	4.6	4.6	4.2	4.6	4.6	4.5	3.9	3.8	3.8	
Precipitation	PrecAvg	43.3	0.8	0.8	1.5	3.7	6.1	6.6	6.3	4.9	5.7	3.8	2.0	1.0	
	PrecMax	53.5	1.9	1.6	3.3	7.6	13.6	12.7	16.7	16.4	14.0	7.6	4.3	1.8	
	PrecMin	31.1	0.1	0.0	0.5	1.2	2.1	0.7	0.4	0.5	1.3	1.1	0.5	0.0	
	PrecStd	5.2	0.5	0.4	0.7	1.6	2.7	2.6	3.5	3.3	3.1	1.4	0.9	0.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	59.2	69.5	82.6	90.8	94.3	96.9	101.9	103.6	100.5	87.7	74.4	60.4	
		MCWB	49.3	57.0	66.0	70.3	72.2	78.2	77.5	76.2	75.8	70.6	63.2	54.2	
	2%	DB	55.6	64.2	75.8	85.8	89.8	93.2	98.6	100.3	95.0	82.1	70.3	57.6	
		MCWB	48.7	54.5	62.2	68.5	71.0	76.6	77.8	76.4	75.9	68.6	61.6	52.7	
	5%	DB	53.4	60.7	71.8	82.0	86.1	89.8	96.5	97.5	91.0	77.7	67.5	55.5	
		MCWB	47.9	53.2	60.2	67.2	70.5	75.5	78.1	76.9	74.6	67.6	60.8	50.9	
	10%	DB	51.5	57.8	68.0	77.9	82.5	86.4	93.8	95.0	87.0	73.8	64.8	53.6	
		MCWB	47.1	51.6	58.5	65.8	69.6	75.2	77.9	76.8	73.6	66.5	59.9	49.6	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.3	58.2	67.6	73.5	77.0	80.9	83.2	81.8	79.6	74.0	65.3	56.5
			MCDB	55.4	66.5	79.2	86.0	87.1	90.3	92.4	92.9	91.5	83.6	70.5	58.7
2%		WB	50.0	55.6	63.7	70.9	74.6	79.2	81.6	80.5	78.1	70.6	63.1	53.7	
		MCDB	54.0	61.7	72.8	80.5	83.6	88.3	90.7	91.4	88.9	77.5	67.9	56.7	
5%		WB	48.8	54.0	61.5	68.9	72.7	77.9	80.5	79.6	76.6	69.0	61.8	51.8	
		MCDB	52.1	59.5	69.6	78.2	80.9	86.0	89.8	90.1	86.6	74.9	66.1	54.4	
10%		WB	47.6	52.4	59.4	67.1	71.3	76.6	79.6	78.7	75.2	67.5	60.4	50.4	
		MCDB	50.7	57.2	66.2	75.6	78.7	83.7	88.7	88.9	84.4	72.4	64.2	52.7	
Mean Daily Temperature Range	5% DB	MDBR	8.0	9.9	12.6	13.9	13.7	12.4	14.6	15.1	12.3	9.3	8.6	7.6	
		MCDBR	12.1	15.3	19.9	21.2	20.9	19.0	18.4	19.1	18.6	16.5	13.2	10.2	
		MCWBR	7.0	7.8	8.8	8.2	7.5	7.0	5.7	5.1	5.9	7.0	6.6	6.3	
	5% WB	MCDBR	9.9	13.4	17.5	17.6	16.0	14.8	15.8	16.5	15.7	13.5	11.0	8.1	
		MCWBR	6.3	7.3	8.4	7.9	7.2	6.5	6.0	5.6	6.0	6.5	6.2	5.6	
Clear-Sky Solar Irradiance	taub	0.783	0.814	0.834	0.806	0.731	0.697	0.656	0.693	0.719	0.831	0.855	0.836		
	taud	1.351	1.327	1.327	1.404	1.564	1.651	1.740	1.653	1.581	1.370	1.331	1.329		
	Ebn at Noon	148	161	172	186	202	208	216	207	193	155	134	129		
	Edh at Noon	92	102	108	103	88	80	73	79	82	96	93	91		
All-Sky Solar Radiation	RadAvg	456	632	914	1151	1194	1172	1604	1464	1048	671	532	414		
	RadStd	68	95	102	167	196	202	180	219	169	122	72	59		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-2.00	N/A	-0.74	-0.94	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	-0.99	N/A	-0.40	-0.49	N/A	N/A	N/A	N/A

Nomenclature: See separate page