

SANGZHI, China

WMO: 575540

Lat: 29.4013N

Lon: 110.1622E

Elev: 1056

StdP: 14.14

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.4	31.8	18.1	14.2	40.3	22.0	17.2	38.1	13.8	43.8	11.9	41.6	2.7	40	0.328

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	95.5	78.1	93.4	77.4	91.2	76.5	80.5	90.3	79.5	88.8	78.6	87.3	5.3	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.2	152.1	84.6	77.2	147.1	83.6	76.3	142.8	82.7	45.2	90.3	44.1	89.4	43.1	87.6	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.3	10.3	8.7	DB	27.3	99.3	2.5	1.8	25.5	100.6	24.0	101.7	22.6	102.7	20.8	104.0
			WB	26.2	82.1	2.5	1.3	24.4	83.0	22.9	83.8	21.5	84.5	19.7	85.4

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	41.6	45.3	53.6	63.3	70.9	76.7	81.9	81.4	74.4	64.4	54.8	45.4	(6)
(7)		DBStd	14.97	5.56	6.37	7.19	6.72	5.15	4.66	4.04	4.65	5.57	5.64	5.96	4.73	(7)
(8)		HDD50	645	264	155	45	3	0	0	0	0	0	23	155		(8)
(9)		HDD65	2750	725	551	357	108	11	0	0	3	80	307	608		(9)
(10)		CDD50	5358	4	25	157	402	647	801	990	974	731	447	168	12	(10)
(11)		CDD65	1989	0	0	5	57	193	351	525	510	284	62	2	0	(11)
(12)		CDH74	17637	0	2	57	461	1285	2737	5503	5207	2055	316	14	0	(12)
(13)		CDH80	7095	0	0	8	124	430	995	2407	2329	739	63	0	0	(13)
(14)	Wind	WSAvg	2.7	2.5	2.9	3.1	3.1	2.9	2.6	2.9	3.0	2.7	2.3	2.2	2.2	(14)
(15)	Precipitation	PrecAvg	54.8	1.0	1.5	3.0	5.7	7.9	9.6	7.7	6.0	4.4	4.2	2.6	1.2	(15)
(16)		PrecMax	87.8	2.5	3.4	7.1	10.4	15.0	27.4	20.0	17.1	10.3	12.0	6.4	3.5	(16)
(17)		PrecMin	32.5	0.1	0.1	0.9	1.0	4.1	2.3	1.3	0.4	0.7	0.2	0.0	0.1	(17)
(18)		PrecStd	11.8	0.6	0.8	1.7	2.2	2.9	5.2	5.1	3.8	2.2	2.4	1.7	0.8	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	62.2	69.3	80.0	88.3	91.8	94.4	98.1	98.6	95.1	86.0	75.8	64.0	(19)
(20)		MCWB	49.5	55.1	62.3	67.5	69.6	76.2	79.4	77.8	76.5	68.3	61.5	51.9		(20)
(21)		2%	DB	57.2	63.3	74.3	83.6	88.1	91.5	95.4	95.9	90.9	81.2	71.2	60.1	(21)
(22)		MCWB	47.1	52.1	59.6	66.2	69.7	75.3	79.1	78.0	75.1	66.3	59.6	49.9		(22)
(23)		5%	DB	53.0	58.6	69.6	79.5	84.9	88.9	93.2	93.6	87.7	77.5	67.1	56.4	(23)
(24)		MCWB	45.6	49.7	57.5	64.9	69.8	75.2	78.4	77.7	73.2	65.4	58.1	48.3		(24)
(25)		10%	DB	49.8	54.6	65.2	75.2	81.4	85.9	90.9	91.0	84.4	73.7	63.6	53.1	(25)
(26)		MCWB	44.4	48.5	55.7	63.5	68.8	74.5	78.1	77.1	71.6	64.2	56.8	46.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	52.5	58.0	66.2	73.1	76.9	80.4	81.8	81.8	79.1	73.1	64.5	54.8	(27)
(28)		MCDWB	57.3	65.2	73.0	81.8	84.3	87.0	92.0	92.2	90.0	79.9	69.8	59.6		(28)
(29)		2%	WB	49.0	53.9	62.0	69.8	74.2	78.8	80.6	80.4	77.5	69.3	61.8	51.8	(29)
(30)		MCDWB	53.8	59.7	69.8	77.5	80.6	86.2	90.7	90.8	87.1	75.7	67.6	57.3		(30)
(31)		5%	WB	47.0	51.5	59.2	67.0	72.5	77.5	79.7	79.2	76.1	67.4	59.8	49.5	(31)
(32)		MCDWB	51.8	56.2	66.3	74.1	79.1	84.5	89.3	88.7	84.1	73.3	65.1	54.7		(32)
(33)		10%	WB	44.8	49.5	56.8	64.9	70.8	76.3	78.9	78.2	74.4	65.7	57.9	47.5	(33)
(34)		MCDWB	49.2	54.1	63.5	72.4	77.4	82.7	88.0	87.1	81.0	71.7	62.5	52.2		(34)
(35)	Mean Daily Temperature Range		MDBR	10.5	11.6	14.0	15.4	14.8	13.4	14.4	15.3	14.4	12.7	12.3	11.5	(35)
(36)		5% DB	MCDBR	20.5	22.4	25.1	25.4	23.7	19.8	19.0	19.9	20.2	21.2	20.2	20.5	(36)
(37)		MCWBR	11.3	11.4	10.8	9.1	7.7	6.3	4.8	4.8	6.1	7.5	9.2	11.1	(37)	
(38)		5% WB	MCDBR	16.9	17.4	20.0	18.6	15.8	14.7	16.4	17.3	16.6	15.4	15.9	17.9	(38)
(39)		MCWBR	9.9	9.7	9.8	8.8	7.0	6.0	5.2	5.2	6.0	7.0	8.0	10.4	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.693	0.735	0.766	0.747	0.668	0.662	0.606	0.667	0.696	0.721	0.702	0.677	(40)	
(41)		taud	1.460	1.423	1.410	1.485	1.665	1.709	1.856	1.696	1.611	1.503	1.502	1.496	(41)	
(42)		Ebn at Noon	168	178	186	198	216	216	228	212	199	178	165	163	(42)	
(43)		Edh at Noon	82	93	100	95	80	76	65	76	80	84	78	76	(43)	
(44)	All-Sky Solar Radiation	RadAvg	505	585	867	1063	1139	1207	1460	1378	1059	793	651	521	(44)	
(45)		RadStd	104	141	87	147	200	185	168	136	143	132	124	108	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(46)
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+0.94	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page