

YUEYANG, China

WMO: 575840

Lat: 29.3807N

Lon: 113.0879E

Elev: 171

StdP: 14.61

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.0	32.0	15.1	11.9	39.7	20.0	15.1	40.5	15.5	40.0	14.2	39.8	7.3	20	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	8.0	94.2	81.1	92.7	80.6	91.4	80.1	83.5	90.2	82.5	89.6	81.5	88.8	7.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.9	166.9	87.9	80.6	159.8	87.6	79.4	153.7	86.7	48.0	90.2	46.7	89.9	45.5	89.0	92.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	13.9	12.2	28.3	97.2	2.2	1.4	26.7	98.2	25.4	99.0	24.2	99.8	22.6	100.8
			25.5	85.3	2.5	1.9	23.7	86.7	22.2	87.8	20.8	88.9	18.9	90.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	64.6	41.8	46.2	54.7	64.9	73.1	79.2	85.0	83.7	76.4	67.0	56.4	46.2	(6)
(7)		DBStd	15.97	6.37	7.79	8.15	7.60	5.81	4.92	4.78	5.16	5.99	6.04	6.96	5.73	(7)
(8)		HDD50	626	264	153	42	2	0	0	0	0	0	22	143		(8)
(9)		HDD65	2585	718	529	335	93	6	0	0	3	50	268	583		(9)
(10)		CDD50	5970	11	46	187	447	717	875	1085	1044	792	527	213	26	(10)
(11)		CDD65	2451	0	2	15	88	258	425	620	579	344	111	9	0	(11)
(12)		CDH74	24823	0	8	62	493	1717	4030	8105	7145	2842	399	22	0	(12)
(13)		CDH80	10412	0	0	12	98	446	1380	4116	3379	924	56	1	0	(13)
(14)	Wind	WSAvg	6.0	5.8	6.0	6.2	6.4	6.1	5.7	7.1	6.5	6.0	5.4	5.5	5.7	(14)
(15)	Precipitation	PrecAvg	49.8	1.8	2.6	4.8	6.6	6.9	8.3	4.0	4.3	2.8	3.2	2.7	1.7	(15)
(16)		PrecMax	69.9	4.1	5.1	8.8	13.1	15.4	22.5	13.9	14.8	11.7	7.0	7.4	5.8	(16)
(17)		PrecMin	31.0	0.0	0.3	1.1	1.9	1.4	1.5	0.4	0.1	0.2	0.0	0.0	0.0	(17)
(18)		PrecStd	9.8	1.1	1.4	1.9	2.8	2.9	4.6	3.1	4.0	2.5	1.9	1.9	1.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.4	74.3	80.9	87.0	90.6	93.0	96.2	96.1	92.9	85.0	77.2	64.7	(19)
(20)		MCWB	53.2	60.9	68.0	72.4	75.6	80.0	81.3	81.6	79.5	71.4	63.7	53.7	(20)	
(21)		2%	DB	58.1	66.4	74.2	82.8	87.3	91.2	94.4	94.2	90.0	81.1	72.2	60.7	(21)
(22)		MCWB	48.9	55.4	63.3	70.2	73.9	79.4	81.1	81.4	78.5	69.9	61.6	51.2	(22)	
(23)		5%	DB	54.1	61.1	70.2	79.6	84.8	89.2	93.1	92.6	87.8	78.2	68.9	57.4	(23)
(24)		MCWB	46.9	52.1	60.2	67.8	72.6	78.4	80.6	81.0	77.4	68.1	60.1	49.5	(24)	
(25)		10%	DB	50.8	56.9	66.6	76.4	82.3	87.0	91.8	91.0	85.4	75.7	66.0	54.7	(25)
(26)		MCWB	45.3	50.4	58.3	65.9	71.6	77.6	80.1	80.5	76.1	66.8	58.6	48.0	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.3	61.9	70.9	75.0	78.9	82.1	84.6	85.3	81.9	75.6	66.5	56.9	(27)
(28)		MCD B	62.3	73.0	80.1	84.1	86.9	89.4	91.6	91.6	88.3	80.5	72.8	60.8	(28)	
(29)		2%	WB	50.9	57.5	65.4	72.2	76.8	80.8	83.4	83.9	80.6	72.3	64.0	53.1	(29)
(30)		MCD B	55.4	63.6	71.5	80.4	83.4	88.4	90.6	90.2	87.5	78.1	69.6	58.6	(30)	
(31)		5%	WB	48.0	53.9	62.4	69.8	75.2	79.6	82.4	82.9	79.2	70.2	61.9	50.8	(31)
(32)		MCD B	52.8	59.1	68.3	76.6	80.8	87.1	89.8	89.6	86.0	75.8	66.9	55.7	(32)	
(33)		10%	WB	45.5	51.0	59.4	67.5	73.6	78.5	81.4	81.8	77.6	68.6	59.8	48.7	(33)
(34)		MCD B	50.1	55.9	64.7	74.1	79.9	85.5	89.1	88.8	84.0	74.0	64.6	53.4	(34)	
(35)	Mean Daily Temperature Range		MDBR	7.9	8.8	9.5	10.0	9.6	8.4	8.0	8.7	9.6	9.4	8.9	8.5	(35)
(36)		5% DB	MCD BR	14.6	15.8	14.7	13.8	12.6	10.6	9.0	9.6	11.9	12.8	13.1	14.0	(36)
(37)			MCWBR	8.7	8.9	8.4	7.9	6.4	4.6	4.6	4.7	5.3	5.7	6.9	7.9	(37)
(38)			MCD BR	12.7	14.1	13.0	12.6	10.4	9.5	8.6	9.1	10.6	11.0	10.9	11.5	(38)
(39)		5% WB	MCWBR	8.2	8.7	8.4	8.2	6.2	4.9	5.1	4.9	5.6	6.2	6.5	7.3	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.690	0.737	0.771	0.760	0.713	0.707	0.627	0.692	0.726	0.738	0.698	0.672	(40)	
(41)		taud	1.490	1.445	1.419	1.478	1.596	1.630	1.822	1.656	1.567	1.494	1.532	1.543	(41)	
(42)		Ebn at Noon	169	177	185	195	206	207	223	207	192	175	166	165	(42)	
(43)		Edh at Noon	80	91	99	96	85	82	68	79	84	85	76	73	(43)	
(44)	All-Sky Solar Radiation	RadAvg	575	669	945	1153	1278	1329	1634	1458	1204	936	744	617	(44)	
(45)		RadStd	104	183	68	132	158	146	165	137	127	136	113	124	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page