

YUEYANG, China

WMO: 575840

Lat: 29.3807N

Lon: 113.0879E

Elev: 52

StdP: 100.70

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-1.1	0.0	-9.4	1.7	4.3	-6.7	2.2	4.7	6.9	4.5	6.3	4.3	3.3	20	0.380

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	34.5	27.3	33.7	27.0	33.0	26.7	28.6	32.3	28.1	32.0	27.5	31.5	3.5	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.7	23.8	31.0	27.0	22.8	30.9	26.3	22.0	30.4	93.7	32.3	90.8	32.2	88.0	31.7	33.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
7.1	6.2	5.5	DB	-2.1	36.2	1.2	0.8	-2.9	36.8	-3.7	37.2	-4.3	37.7	-5.2	38.2	(4)
			WB	-3.6	29.6	1.4	1.1	-4.6	30.4	-5.4	31.0	-6.2	31.6	-7.3	32.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.1	5.5	7.9	12.6	18.3	22.8	26.2	29.4	28.7	24.7	19.4	13.5	7.9	(6)
		DBStd	8.87	3.54	4.33	4.53	4.22	3.23	2.73	2.65	2.86	3.33	3.36	3.87	3.19	(7)
		HDD10.0	348	147	85	23	1	0	0	0	0	0	12	79		(8)
		HDD18.3	1436	399	294	186	52	3	0	0	2	28	149	324		(9)
		CDD10.0	3317	6	26	104	248	398	486	603	580	440	293	118	14	(10)
		CDD18.3	1362	0	1	8	49	143	236	344	322	191	62	5	0	(11)
		CDH23.3	13791	0	4	34	274	954	2239	4503	3969	1579	222	12	0	(12)
		CDH26.7	5784	0	0	7	54	248	767	2287	1877	513	31	1	0	(13)
(14)	Wind	WSAvg	2.7	2.6	2.7	2.8	2.9	2.7	2.5	3.2	2.9	2.7	2.4	2.5	2.5	(14)
(15)	Precipitation	PrecAvg	1264	46	65	123	168	176	212	102	109	72	81	68	42	(15)
(16)		PrecMax	1776	104	130	223	334	391	572	354	376	298	179	188	148	(16)
(17)		PrecMin	787	0	7	27	49	36	11	3	5	0	1	0		(17)
(18)		PrecStd	249	28	35	49	71	74	118	79	102	63	48	49	35	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	18.0	23.5	27.1	30.5	32.6	33.9	35.7	35.6	33.8	29.4	25.1	18.2		(19)
(20)		MCWB	11.8	16.0	20.0	22.5	24.2	26.7	27.4	27.5	26.4	21.9	17.6	12.0		(20)
(21)		DB	14.5	19.1	23.4	28.2	30.7	32.9	34.7	34.6	32.2	27.3	22.3	15.9		(21)
(22)		MCWB	9.4	13.0	17.4	21.2	23.3	26.4	27.3	27.5	25.8	21.1	16.5	10.7		(22)
(23)		DB	12.3	16.1	21.2	26.5	29.4	31.8	33.9	33.7	31.0	25.7	20.5	14.1		(23)
(24)		MCWB	8.3	11.1	15.6	19.9	22.6	25.8	27.0	27.2	25.2	20.0	15.6	9.7		(24)
(25)		DB	10.5	13.8	19.2	24.6	27.9	30.6	33.2	32.8	29.7	24.3	18.9	12.6		(25)
(26)		MCWB	7.4	10.2	14.6	18.8	22.0	25.3	26.7	27.0	24.5	19.3	14.8	8.9		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	13.5	16.6	21.6	23.9	26.0	27.8	29.2	29.6	27.7	24.2	19.2	13.8		(27)
(28)		MCDB	16.8	22.8	26.7	28.9	30.5	31.9	33.1	33.1	31.3	26.9	22.6	16.0		(28)
(29)		WB	10.5	14.2	18.6	22.3	24.9	27.1	28.5	28.9	27.0	22.4	17.8	11.7		(29)
(30)		MCDB	13.0	17.6	22.0	26.9	28.6	31.4	32.5	32.3	30.8	25.6	20.9	14.8		(30)
(31)		WB	8.9	12.1	16.9	21.0	24.0	26.5	28.0	28.3	26.2	21.2	16.6	10.5		(31)
(32)		MCDB	11.6	15.0	20.2	24.8	27.1	30.6	32.1	32.0	30.0	24.3	19.4	13.2		(32)
(33)		WB	7.5	10.6	15.2	19.7	23.1	25.8	27.4	27.7	25.3	20.3	15.5	9.3		(33)
(34)		MCDB	10.0	13.3	18.2	23.4	26.6	29.7	31.7	31.5	28.9	23.3	18.1	11.9		(34)
(35)	Mean Daily Temperature Range	MDBR	4.4	4.9	5.3	5.6	5.3	4.7	4.4	4.8	5.4	5.2	5.0	4.7		(35)
(36)		5% DB	8.1	8.8	8.2	7.7	7.0	5.9	5.0	5.3	6.6	7.1	7.3	7.8		(36)
(37)		MCWBR	4.8	4.9	4.6	4.4	3.6	2.6	2.5	2.6	3.0	3.2	3.8	4.4		(37)
(38)		5% WB	7.0	7.8	7.2	7.0	5.8	5.3	4.8	5.0	5.9	6.1	6.0	6.4		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.690	0.737	0.771	0.760	0.713	0.707	0.627	0.692	0.726	0.738	0.698	0.672		(40)
(41)		taud	1.490	1.445	1.419	1.478	1.596	1.630	1.822	1.656	1.567	1.494	1.532	1.543		(41)
(42)		Ebn at Noon	533	559	583	615	649	651	703	652	606	551	524	519		(42)
(43)		Edh at Noon	252	286	311	302	269	259	213	249	264	268	240	230		(43)
(44)	All-Sky Solar Radiation	RadAvg	1.81	2.11	2.98	3.63	4.03	4.19	5.15	4.60	3.80	2.95	2.35	1.95		(44)
(45)		RadStd	0.33	0.58	0.21	0.42	0.50	0.46	0.52	0.43	0.40	0.43	0.36	0.39		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (6 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page