

XIUSHUI, China

WMO: 575980

Lat: 29.0301N

Lon: 114.5751E

Elev: 147

StdP: 99.57

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -2.5	(c) -1.2	(d) -9.7	(e) 1.7	(f) 6.0	(g) -6.8	(h) 2.2	(i) 5.3	(j) 4.8	(k) 6.6	(l) 4.2	(m) 6.4	(n) 0.6	(o) 140	(p) 0.332

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 8.9	(c) 36.4	(d) 26.1	(e) 35.3	(f) 25.9	(g) 34.1	(h) 25.6	(i) 27.7	(j) 32.8	(k) 27.2	(l) 32.1	(m) 26.6	(n) 31.4	(o) 2.1	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.6	29.7	26.1	21.8	29.1	25.5	21.1	28.6	90.0	33.1	87.1	32.2	84.7	31.5	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 4.7	(b) 4.0	(c) 3.3	(e) -4.8	(f) 38.3	(g) 1.6	(h) 1.2	(i) -5.9	(j) 39.1	(k) -6.9	(l) 39.8	(m) -7.8	(n) 40.4	(o) -9.0	(p) 41.3		
(a) 4.7	(b) 4.0	(c) 3.3	(e) -5.1	(f) 28.7	(g) 1.7	(h) 0.8	(i) -6.3	(j) 29.3	(k) -7.2	(l) 29.7	(m) -8.2	(n) 30.2	(o) -9.4	(p) 30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	5.4	7.8	12.2	18.0	22.5	25.6	28.8	28.4	24.8	19.4	13.4	7.6
	DBStd	8.66	3.20	4.15	4.22	3.75	2.75	2.57	2.21	2.28	3.22	3.10	3.63	3.01
	HDD10.0	352	146	86	24	1	0	0	0	0	0	0	10	85
	HDD18.3	1452	399	294	196	50	3	0	0	0	1	24	153	332
	CDD10.0	3231	5	24	92	242	388	468	582	570	444	292	111	11
	CDD18.3	1290	0	1	5	41	133	218	324	312	196	57	4	0
	CDH23.3	12482	0	6	61	336	992	1876	3781	3349	1674	373	36	0
CDH26.7	5428	0	0	12	91	367	759	1854	1552	691	98	4	0	
Wind	WSAvg	1.2	1.1	1.2	1.2	1.2	1.2	1.1	1.3	1.3	1.3	1.1	1.1	1.1
Precipitation	PrecAvg	1538	56	92	148	211	236	267	152	101	84	77	71	43
	PrecMax	2203	150	178	308	461	538	508	518	230	205	183	175	135
	PrecMin	1088	0	12	53	79	68	65	21	20	14	0	0	0
	PrecStd	272	31	47	59	99	103	101	107	52	53	47	49	35
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.3	23.6	28.2	31.6	34.3	35.6	38.0	38.0	36.4	31.9	26.8	19.4
		MCWB	12.2	15.5	18.7	20.3	22.6	25.7	26.3	25.8	25.4	21.5	17.8	11.9
	2%	DB	15.1	19.9	24.7	29.2	32.4	34.1	36.6	36.3	34.5	29.3	24.0	16.9
		MCWB	9.8	13.2	16.4	19.3	21.8	25.2	26.3	26.3	24.8	20.4	16.2	10.4
	5%	DB	12.8	16.9	21.9	27.2	30.7	32.7	35.5	35.1	32.7	27.2	21.7	15.0
		MCWB	8.4	11.6	14.7	19.0	21.7	24.8	26.1	26.3	24.2	18.9	15.3	10.5
	10%	DB	10.6	14.2	19.1	25.0	28.6	31.0	34.3	33.6	30.7	25.3	19.4	13.0
		MCWB	7.5	10.4	13.9	18.3	21.4	24.5	26.0	26.0	23.5	18.4	14.6	9.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	16.9	20.7	24.0	25.9	27.7	28.6	28.8	27.3	24.3	20.3	14.9
		MCDB	16.0	21.7	25.4	28.1	29.0	32.1	33.7	33.5	32.4	28.3	23.8	16.8
	2%	WB	11.1	14.6	18.2	22.2	24.8	26.8	27.8	27.8	26.2	22.4	18.4	12.7
		MCDB	13.1	18.4	22.0	25.5	27.9	31.0	33.0	33.0	31.4	25.9	21.4	15.2
	5%	WB	9.3	12.7	16.5	21.0	23.8	26.2	27.2	27.1	25.5	21.2	17.1	10.9
		MCDB	11.9	15.3	19.6	24.4	27.0	30.2	32.3	32.2	30.2	24.3	19.4	13.7
	10%	WB	7.9	11.1	15.0	19.8	22.8	25.5	26.7	26.6	24.8	20.1	15.7	9.5
		MCDB	10.1	13.7	18.0	22.9	26.4	29.1	31.5	31.3	28.7	23.7	18.3	12.1
Mean Daily Temperature Range	5% DB	MDBR	7.0	7.6	8.8	9.6	9.3	8.1	8.9	8.9	9.4	9.6	9.4	8.6
		MCDBR	12.7	13.7	15.1	14.8	14.3	11.5	11.7	11.6	12.4	13.8	14.3	13.6
		MCWBR	7.1	7.1	6.8	5.9	5.0	3.7	2.9	3.1	3.7	4.9	6.6	7.3
	5% WB	MCDBR	10.0	10.6	11.4	10.3	9.0	8.8	10.1	10.1	9.7	9.4	9.3	10.3
		MCWBR	6.1	6.2	6.1	5.6	4.2	3.6	3.4	3.4	3.4	4.3	5.1	6.1
Clear-Sky Solar Irradiance	taub	0.683	0.732	0.783	0.771	0.708	0.701	0.639	0.694	0.714	0.720	0.661	0.641	
	taud	1.492	1.447	1.399	1.459	1.601	1.641	1.786	1.649	1.584	1.510	1.577	1.575	
	Ebn at Noon	541	565	576	609	653	655	695	652	615	565	555	547	
	Edh at Noon	253	286	318	308	268	256	221	251	260	264	230	223	
All-Sky Solar Radiation	RadAvg	1.88	2.16	2.89	3.58	3.97	4.01	5.08	4.50	3.87	3.16	2.48	2.10	
	RadStd	0.38	0.60	0.27	0.41	0.52	0.48	0.49	0.43	0.41	0.45	0.40	0.45	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (6 neighbors)	+0.31	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	+93	N/A

Nomenclature: See separate page