

NAXI, China

WMO: 576040

Lat: 28.7874N

Lon: 105.3928E

Elev: 1194

StdP: 14.07

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.1	39.0	32.5	28.2	41.7	34.7	30.8	42.9	9.6	47.6	8.5	47.7	3.3	110	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	13.5	96.6	78.6	94.1	78.3	91.7	77.7	81.7	90.6	80.5	89.4	79.4	87.9	4.8	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.5	160.2	86.3	78.3	153.6	85.4	77.2	148.2	84.4	46.9	90.8	45.5	89.6	44.3	88.2	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.8	8.4	7.4		34.4	100.3	2.2	2.6	32.8	102.1	31.5	103.7	30.3	105.1	28.6	107.0
				33.7	83.5	2.2	1.5	32.1	84.6	30.8	85.5	29.5	86.4	27.9	87.5
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	45.9	50.2	58.3	67.1	72.5	76.3	81.8	82.0	74.4	65.4	57.6	48.6	(6)
(7)		DBStd	13.39	4.16	5.60	6.46	6.83	5.23	4.68	4.68	5.55	6.08	4.96	5.36	3.89	(7)
(8)		HDD50	285	138	61	7	0	0	0	0	0	0	6	73	(8)	
(9)		HDD65	2085	593	414	226	56	5	0	0	2	54	226	509	(9)	
(10)		CDD50	5794	10	67	263	513	699	790	987	992	731	479	234	29	(10)
(11)		CDD65	2115	0	0	16	118	238	340	522	527	282	68	4	0	(11)
(12)		CDH74	18644	0	0	62	749	1586	2515	5662	5827	2036	206	1	0	(12)
(13)		CDH80	7676	0	0	5	196	492	857	2542	2794	756	34	0	0	(13)
(14)	Wind	WSAvg	3.4	3.0	3.2	3.7	3.7	3.8	3.5	3.7	3.7	3.5	3.1	3.0	2.9	(14)
(15)	Precipitation	PrecAvg	43.1	1.1	1.0	1.9	3.3	4.8	7.5	6.5	6.1	4.8	3.3	1.8	1.1	(15)
(16)		PrecMax	56.2	2.5	2.0	4.1	5.6	9.7	14.1	17.0	10.7	10.8	6.0	3.2	2.1	(16)
(17)		PrecMin	30.3	0.3	0.4	0.8	1.7	2.2	3.4	2.4	0.7	1.7	1.5	0.2	0.3	(17)
(18)		PrecStd	6.6	0.5	0.5	0.9	1.2	1.9	2.7	3.1	2.5	2.6	1.2	0.8	0.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	DB	60.0	68.6	79.5	89.9	92.7	93.9	98.4	100.7	97.9	84.5	72.9	60.7	(19)	
(20)		MCWB	50.8	57.4	64.2	70.1	72.4	78.0	79.7	77.1	76.6	71.4	63.8	54.4	(20)	
(21)		DB	56.3	64.5	75.2	84.9	88.5	90.6	95.8	97.5	92.1	79.6	70.1	57.9	(21)	
(22)		MCWB	49.4	55.4	62.2	68.4	71.7	76.7	79.6	78.3	76.5	69.4	62.4	52.5	(22)	
(23)		DB	53.7	61.3	72.0	81.6	85.3	88.0	93.5	94.8	87.8	75.8	67.4	55.8	(23)	
(24)		MCWB	48.5	53.5	60.7	67.7	70.6	75.4	79.3	78.1	75.2	68.2	61.4	51.2	(24)	
(25)		DB	51.6	58.6	68.5	78.1	82.2	85.1	91.0	92.2	84.1	72.7	64.9	53.8	(25)	
(26)		MCWB	47.6	52.3	59.3	66.5	69.9	75.0	78.8	77.8	73.7	67.0	60.6	50.1	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	WB	52.2	58.4	67.4	73.9	77.1	82.1	83.6	82.7	79.8	74.3	66.1	55.9	(27)	
(28)		MCDWB	56.8	66.4	76.7	84.5	85.6	88.2	91.9	92.4	89.9	81.5	70.0	59.0	(28)	
(29)		WB	50.5	56.1	63.9	70.9	74.8	79.3	82.1	81.4	78.3	71.1	63.8	54.1	(29)	
(30)		MCDWB	54.1	62.3	71.5	80.5	82.5	86.4	90.7	90.9	87.2	75.3	67.5	56.6	(30)	
(31)		WB	49.4	54.5	62.0	69.2	73.3	77.8	80.9	80.2	76.9	69.5	62.6	52.1	(31)	
(32)		MCDWB	52.3	59.9	69.2	77.8	80.9	84.5	89.6	89.3	84.3	73.7	66.1	54.4	(32)	
(33)		WB	48.3	53.0	60.2	67.6	71.8	76.2	79.9	79.1	75.2	67.9	61.2	50.8	(33)	
(34)		MCDWB	50.9	57.7	67.2	75.8	78.4	82.4	88.3	88.0	82.3	71.7	64.2	52.9	(34)	
(35)	Mean Daily Temperature Range	MDBR	6.2	8.2	10.7	12.5	12.5	11.0	13.1	13.5	10.3	7.6	7.0	5.8	(35)	
(36)		5% DB	10.9	13.7	16.9	18.4	18.8	17.3	17.5	18.0	16.4	14.1	11.7	9.4	(36)	
(37)		MCWBR	5.3	5.8	6.1	6.0	6.1	5.8	5.5	4.8	5.0	5.3	5.0	4.6	(37)	
(38)		5% WB	8.8	12.0	14.8	15.4	14.4	13.4	15.1	15.5	13.3	11.2	9.6	7.1	(38)	
(39)		MCWBR	4.7	5.4	6.2	6.2	6.0	5.8	6.0	5.4	4.9	5.1	5.0	3.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.749	0.771	0.806	0.783	0.709	0.681	0.655	0.691	0.716	0.804	0.818	0.796	(40)	
(41)		taud	1.399	1.380	1.359	1.434	1.595	1.672	1.734	1.647	1.579	1.402	1.360	1.360	(41)	
(42)		Ebn at Noon	157	171	178	191	207	212	217	207	195	162	142	139	(42)	
(43)		Edh at Noon	89	97	105	100	85	79	74	80	83	94	91	89	(43)	
(44)	All-Sky Solar Radiation	RadAvg	493	701	964	1207	1263	1182	1584	1446	1033	673	577	441	(44)	
(45)		RadStd	88	116	133	160	202	218	180	215	169	127	73	78	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+1.04	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page