

NAXI, China

WMO: 576040

Lat: 28.7874N

Lon: 105.3928E

Elev: 364

StdP: 97.03

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.8	3.9	0.3	4.0	5.4	1.5	4.4	6.0	4.3	8.7	3.8	8.7	1.5	110	0.306

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.5	35.9	25.9	34.5	25.7	33.2	25.4	27.6	32.5	27.0	31.9	26.4	31.1	2.2	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.9	30.2	25.7	21.9	29.7	25.1	21.2	29.1	91.3	32.7	88.0	32.0	85.1	31.2	30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
4.4	3.7	3.3	DB	1.4	37.9	1.2	1.4	0.5	39.0	-0.3	39.8	-1.0	40.6	-1.9	41.7	(4)
			WB	1.0	28.6	1.2	0.9	0.1	29.2	-0.7	29.7	-1.4	30.2	-2.3	30.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	7.7	10.1	14.6	19.5	22.5	24.6	27.7	27.8	23.5	18.6	14.2	9.2	(6)
		DBStd	7.44	2.31	3.11	3.59	3.80	2.90	2.60	2.60	3.08	3.38	2.76	2.98	2.16	(7)
		HDD10.0	158	77	34	4	0	0	0	0	0	0	3	41		(8)
		HDD18.3	1158	329	230	126	31	3	0	0	1	30	126	283		(9)
		CDD10.0	3219	6	37	146	285	388	439	548	551	406	266	130	16	(10)
		CDD18.3	1175	0	0	9	66	132	189	290	293	157	38	2	0	(11)
		CDH23.3	10358	0	0	34	416	881	1397	3146	3237	1131	114	1	0	(12)
		CDH26.7	4264	0	0	3	109	273	476	1412	1552	420	19	0	0	(13)
(14)	Wind	WSAvg	1.5	1.3	1.4	1.7	1.7	1.7	1.6	1.7	1.7	1.5	1.4	1.4	1.3	(14)
(15)	Precipitation	PrecAvg	1094	29	26	49	84	122	191	165	156	121	83	46	28	(15)
(16)		PrecMax	1427	64	50	103	143	246	357	432	273	274	153	81	53	(16)
(17)		PrecMin	769	8	9	21	42	57	87	62	18	43	39	6	8	(17)
(18)		PrecStd	167	13	12	22	30	47	68	78	64	65	31	20	10	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	15.6	20.3	26.4	32.2	33.7	34.4	36.9	38.2	36.6	29.2	22.7	15.9		(19)
(20)		0.4% MCWB	10.4	14.1	17.9	21.2	22.4	25.5	26.5	25.0	24.8	21.9	17.7	12.4		(20)
(21)		2% DB	13.5	18.0	24.0	29.4	31.4	32.6	35.4	36.4	33.4	26.5	21.1	14.4		(21)
(22)		2% MCWB	9.7	13.0	16.8	20.2	22.1	24.9	26.5	25.7	24.7	20.8	16.9	11.4		(22)
(23)		5% DB	12.1	16.3	22.2	27.5	29.6	31.1	34.2	34.9	31.0	24.3	19.7	13.2		(23)
(24)		5% MCWB	9.2	12.0	16.0	19.8	21.4	24.1	26.3	25.6	24.0	20.1	16.3	10.7		(24)
(25)		10% DB	10.9	14.8	20.3	25.6	27.9	29.5	32.8	33.4	29.0	22.6	18.3	12.1		(25)
(26)		10% MCWB	8.7	11.3	15.2	19.2	21.1	23.9	26.0	25.4	23.1	19.5	15.9	10.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	11.2	14.6	19.7	23.3	25.1	27.9	28.6	28.2	26.5	23.5	19.0	13.3		(27)
(28)		0.4% MCDB	13.8	19.1	24.8	29.2	29.8	31.2	33.3	33.5	32.2	27.5	21.1	15.0		(28)
(29)		2% WB	10.3	13.4	17.7	21.6	23.8	26.3	27.8	27.5	25.7	21.7	17.7	12.3		(29)
(30)		2% MCDB	12.3	16.8	21.9	26.9	28.1	30.2	32.6	32.7	30.7	24.1	19.7	13.7		(30)
(31)		5% WB	9.7	12.5	16.7	20.6	23.0	25.4	27.2	26.8	24.9	20.8	17.0	11.2		(31)
(32)		5% MCDB	11.3	15.5	20.7	25.5	27.1	29.1	32.0	31.8	29.1	23.2	18.9	12.5		(32)
(33)		10% WB	9.1	11.7	15.7	19.8	22.1	24.6	26.6	26.2	24.0	20.0	16.2	10.4		(33)
(34)		10% MCDB	10.5	14.3	19.5	24.3	25.8	28.0	31.3	31.1	27.9	22.1	17.9	11.6		(34)
(35)	Mean Daily Temperature Range	MDBR	3.5	4.5	5.9	6.9	6.9	6.1	7.3	7.5	5.7	4.2	3.9	3.2		(35)
(36)		5% DB MCDBR	6.1	7.6	9.4	10.2	10.5	9.6	9.7	10.0	9.1	7.9	6.5	5.2		(36)
(37)		5% DB MCWBR	3.0	3.2	3.4	3.3	3.4	3.2	3.0	2.7	2.8	3.0	2.8	2.5		(37)
(38)		5% WB MCDBR	4.9	6.7	8.2	8.6	8.0	7.4	8.4	8.6	7.4	6.2	5.3	4.0		(38)
(39)		5% WB MCWBR	2.6	3.0	3.4	3.4	3.3	3.2	3.3	3.0	2.7	2.8	2.8	2.2		(39)
(40)	Clear-Sky Solar Irradiance	taub	0.749	0.771	0.806	0.783	0.709	0.681	0.655	0.691	0.716	0.804	0.818	0.796		(40)
(41)		taud	1.399	1.380	1.359	1.434	1.595	1.672	1.734	1.647	1.579	1.402	1.360	1.360		(41)
(42)		Ebn at Noon	496	539	562	602	653	668	684	654	614	511	448	438		(42)
(43)		Edh at Noon	279	307	331	316	269	248	232	252	262	296	288	280		(43)
(44)	All-Sky Solar Radiation	RadAvg	1.55	2.21	3.04	3.81	3.98	3.73	4.99	4.56	3.26	2.12	1.82	1.39		(44)
(45)		RadStd	0.28	0.37	0.42	0.51	0.64	0.69	0.57	0.68	0.53	0.40	0.23	0.25		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	+0.58	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page