

BIJIE, China

WMO: 577070

Lat: 27.2975N

Lon: 105.2885E

Elev: 4957

StdP: 12.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.1	28.9	22.1	20.0	32.5	24.7	22.5	32.7	9.0	46.3	7.6	44.8	1.8	110	0.345

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.8	86.0	69.0	83.9	68.4	81.9	67.9	71.8	81.5	70.8	80.0	70.0	78.4	5.0	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
69.2	129.4	75.4	68.3	125.4	74.7	67.5	121.7	74.0	39.3	82.0	38.3	80.2	37.4	78.7	75.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.4	7.7	6.8	24.8	90.0	2.4	1.9	23.1	91.3	21.6	92.4	20.3	93.5	18.5	94.8
			23.4	73.9	2.5	1.1	21.6	74.7	20.1	75.4	18.7	76.0	16.9	76.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.1	38.2	42.7	50.4	59.3	64.5	68.5	72.7	71.8	66.6	58.3	50.7	41.2
	DBStd	13.23	6.32	8.46	8.25	7.56	5.70	4.71	3.66	3.96	5.64	5.89	6.55	5.46
	HDD50	1071	369	236	99	13	0	0	0	0	4	70	280	
	HDD65	3653	831	624	456	200	80	18	2	4	49	222	428	739
	CDD50	3679	4	32	112	292	449	555	703	675	497	262	92	6
	CDD65	783	0	0	4	29	63	123	240	213	96	15	0	0
	CDH74	4311	1	16	64	228	385	586	1290	1159	515	64	3	0
	CDH80	883	0	1	12	39	77	106	279	272	92	5	0	0
Wind	WSAvg	2.4	2.0	2.3	2.7	2.8	2.8	2.3	2.6	2.5	2.5	2.0	2.1	2.0
Precipitation	PrecAvg	34.7	0.6	0.6	0.9	2.3	4.7	5.8	5.8	5.9	4.4	2.3	1.2	0.6
	PrecMax	45.5	1.3	1.2	2.1	6.9	11.5	11.4	12.2	13.9	7.7	4.3	2.8	1.4
	PrecMin	24.3	0.2	0.2	0.4	0.6	1.5	2.4	1.1	1.7	1.6	0.9	0.3	0.2
	PrecStd	4.9	0.3	0.2	0.5	1.3	2.3	2.0	2.5	2.7	1.7	0.9	0.7	0.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	63.9	76.2	81.1	84.5	86.1	86.5	88.0	88.3	86.3	80.3	72.2	63.7
		MCWB	51.0	53.0	56.7	62.0	65.4	69.9	70.3	69.6	69.7	65.2	58.3	51.2
	2%	DB	56.2	67.8	74.1	80.0	82.1	82.9	85.2	85.6	82.6	75.5	67.6	57.0
		MCWB	46.9	52.3	57.4	62.0	65.3	69.1	70.1	69.2	67.9	62.9	56.8	48.4
	5%	DB	51.0	60.8	68.4	76.1	78.4	80.2	83.2	83.1	79.8	71.5	64.0	52.2
		MCWB	44.5	50.3	55.7	61.1	64.3	67.8	69.7	69.0	66.8	62.0	55.2	46.0
	10%	DB	46.3	54.0	63.0	71.7	74.9	77.3	81.0	80.6	76.8	67.4	60.0	48.3
		MCWB	42.1	47.3	53.6	60.0	63.4	67.3	69.3	68.5	65.5	60.4	53.9	44.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	51.0	55.6	60.3	66.2	70.1	72.5	73.5	72.7	70.8	66.7	60.1	51.9
		MCDB	62.0	69.6	74.1	78.0	80.3	81.9	82.5	83.4	82.6	76.5	67.1	61.0
	2%	WB	47.5	52.8	58.0	64.2	67.9	71.0	72.0	71.1	69.3	64.7	57.9	49.2
		MCDB	55.5	65.4	70.4	75.2	76.9	79.5	81.3	81.1	79.6	72.6	65.7	55.4
	5%	WB	44.9	50.4	56.3	62.6	66.3	69.9	71.1	70.2	68.2	63.0	56.2	46.9
		MCDB	49.9	60.2	66.4	72.4	74.5	77.2	80.0	79.4	76.9	69.2	62.6	51.5
	10%	WB	42.4	47.7	54.2	60.9	64.7	68.7	70.1	69.3	67.0	61.1	54.5	44.5
		MCDB	46.0	53.9	62.4	69.5	72.5	75.0	78.2	77.7	74.4	66.7	59.4	47.9
Mean Daily Temperature Range	5% DB	MDBR	9.0	11.4	13.7	14.8	14.3	12.4	13.8	14.4	13.4	10.7	11.2	9.2
		MCDBR	20.4	26.5	25.7	23.6	21.8	18.8	18.1	19.5	19.1	19.3	19.4	19.8
		MCWBR	11.9	12.5	10.7	9.1	8.6	7.4	6.0	6.3	6.7	8.3	9.3	11.5
	5% WB	MCDBR	19.3	24.6	22.7	19.9	17.5	14.8	15.7	16.5	16.4	16.6	16.9	18.1
		MCWBR	11.5	12.0	10.1	8.7	8.1	6.8	6.2	6.2	6.2	7.9	8.4	10.7
Clear-Sky Solar Irradiance	taub	0.518	0.542	0.655	0.631	0.555	0.531	0.504	0.534	0.531	0.580	0.563	0.551	
	taud	1.761	1.731	1.540	1.631	1.858	1.969	2.058	1.950	1.925	1.730	1.696	1.683	
	Ebn at Noon	221	230	213	224	242	247	253	245	241	216	206	203	
	Edh at Noon	62	69	88	82	66	58	53	59	59	68	66	64	
All-Sky Solar Radiation	RadAvg	554	805	1020	1260	1307	1191	1555	1423	1139	748	707	512	
	RadStd	129	167	141	179	186	226	138	162	169	145	92	113	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	+0.72	N/A	N/A	+1.28	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	N/A	N/A	N/A	+1.15	N/A	N/A	N/A	N/A	+196	+70

Nomenclature: See separate page