

HUICHUAN, China

WMO: 577120

Lat: 27.7266N

Lon: 106.9467E

Elev: 984

StdP: 90.05

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.5	0.6	-5.0	2.8	2.9	-3.5	3.2	3.2	4.2	8.4	3.6	6.8	0.9	20	0.313

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.0	32.6	22.7	31.6	22.5	30.5	22.3	24.2	29.7	23.8	29.0	23.4	28.3	2.3	140

Dehumidification DP/MCDB and HR

0.4%			1%			2%			0.4%		1%		2%		Extreme Max WB
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.8	19.8	26.7	22.4	19.3	26.2	22.0	18.9	25.7	79.5	29.8	77.5	29.1	75.8	28.6	27.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4.5	3.8	3.3	-2.1	35.0	1.2	1.1	-2.9	35.8	-3.6	36.4	-4.3	37.0	-5.2	37.8
			-3.0	25.2	1.4	0.8	-4.0	25.8	-4.9	26.3	-5.6	26.7	-6.7	27.3
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	16.3	5.3	7.3	11.5	17.0	20.4	23.2	25.9	25.5	22.2	17.1	12.3	7.2
	DBStd	7.76	3.05	4.02	4.30	4.16	2.88	2.60	1.98	2.40	3.20	2.84	3.42	2.85
	HDD10.0	388	149	94	32	2	0	0	0	0	0	0	16	94
	HDD18.3	1606	404	309	217	73	12	1	0	0	6	58	183	344
	CDD10.0	2682	4	19	78	213	322	395	493	481	366	219	84	8
	CDD18.3	859	0	1	5	34	76	146	234	222	121	19	2	0
	CDH23.3	6321	0	6	40	214	439	900	1976	1842	828	71	5	0
	CDH26.7	2006	0	1	9	46	104	237	676	667	251	13	0	0
Wind	WSAvg	1.2	1.1	1.2	1.3	1.4	1.3	1.2	1.3	1.2	1.2	1.0	1.0	1.0
Precipitation	PrecAvg	1062	27	25	38	85	147	207	172	113	79	102	42	23
	PrecMax	1303	47	51	76	129	253	422	425	229	135	183	94	54
	PrecMin	735	12	3	15	36	87	68	48	28	29	38	8	9
	PrecStd	148	9	14	16	28	42	90	96	63	31	38	20	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	16.9	23.3	27.7	30.2	31.1	32.0	33.7	34.3	33.3	28.7	23.7	17.7
		MCWB	10.8	14.2	17.4	19.3	20.2	22.7	22.8	22.3	21.6	20.5	16.6	12.6
	2%	DB	13.6	18.1	23.5	28.0	29.4	30.6	32.4	32.7	31.0	25.5	21.3	15.0
		MCWB	9.4	13.1	16.4	19.1	20.0	22.5	23.1	23.0	20.9	18.5	15.0	10.7
	5%	DB	11.1	15.0	20.4	25.9	27.6	29.3	31.2	31.6	29.5	23.2	19.3	12.9
		MCWB	8.2	11.0	14.7	18.5	19.6	22.3	23.1	22.8	21.1	17.7	14.5	9.5
	10%	DB	9.5	12.7	18.0	23.7	25.9	27.9	30.2	30.3	27.9	21.6	17.5	11.4
		MCWB	7.4	9.8	13.8	17.7	19.3	22.0	22.9	22.6	20.5	17.3	14.0	8.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	11.8	14.6	17.7	21.8	23.1	24.4	25.0	24.8	23.7	21.2	17.5	13.4
		MCDB	16.8	21.2	25.3	27.4	27.9	29.4	30.8	30.9	30.2	26.8	21.0	16.9
	2%	WB	9.7	13.0	16.8	20.4	21.9	23.7	24.3	24.1	22.9	20.1	16.5	11.7
		MCDB	12.7	18.1	22.8	25.6	26.3	28.2	29.6	30.1	28.5	23.9	19.8	13.9
	5%	WB	8.5	11.4	15.5	19.2	21.0	23.1	23.9	23.6	22.2	19.0	15.4	10.0
		MCDB	10.8	14.3	19.9	24.3	25.6	27.4	28.8	29.2	27.1	21.6	18.1	12.1
	10%	WB	7.7	10.0	13.9	18.2	20.1	22.6	23.5	23.2	21.6	17.9	14.4	8.7
		MCDB	9.6	12.4	17.6	22.8	23.9	26.5	28.3	28.2	26.0	20.5	17.2	11.1
Mean Daily Temperature Range	5% DB	MDBR	4.0	4.7	6.3	7.3	7.1	6.2	7.0	7.5	7.6	5.2	5.4	4.7
		MCDBR	9.0	10.6	12.0	12.0	11.4	9.2	9.2	10.1	10.8	9.5	10.0	9.5
		MCWBR	5.4	5.6	5.3	4.5	4.0	2.9	2.4	2.5	3.0	3.9	4.6	5.4
	5% WB	MCDBR	8.4	9.7	11.4	10.2	8.2	7.0	7.6	8.3	8.1	6.9	7.1	7.3
		MCWBR	5.2	5.1	5.2	4.4	4.0	2.6	2.5	2.4	2.8	3.5	3.7	4.4
Clear-Sky Solar Irradiance	taub	0.637	0.650	0.723	0.691	0.596	0.571	0.523	0.565	0.574	0.666	0.670	0.671	
	taud	1.527	1.529	1.447	1.546	1.791	1.895	2.040	1.905	1.840	1.577	1.520	1.480	
	Ebn at Noon	586	631	620	664	732	747	782	747	723	611	556	531	
	Edh at Noon	247	266	304	283	222	199	171	195	202	249	247	250	
All-Sky Solar Radiation	RadAvg	1.41	1.99	2.73	3.42	3.67	3.57	4.88	4.51	3.52	2.22	1.92	1.39	
	RadStd	0.33	0.42	0.39	0.53	0.65	0.65	0.44	0.51	0.46	0.43	0.35	0.31	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (5 neighbors)	N/A	N/A	N/A	+0.60	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page