

ZHIJIANG, China

WMO: 577450

Lat: 27.4548N

Lon: 109.6812E

Elev: 896

StdP: 14.23

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.6	31.8	19.0	14.8	39.5	22.4	17.4	38.1	13.9	44.6	12.0	42.8	3.7	40	0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.1	95.1	78.2	93.1	77.6	91.1	77.3	81.0	89.1	80.0	88.0	79.1	86.8	5.4	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	156.6	84.0	78.2	151.3	83.3	77.2	146.5	82.8	45.7	89.3	44.6	88.4	43.6	86.9	86.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.2	10.6	9.3	DB	26.4	98.7	2.8	1.9	24.4	100.1	22.7	101.2	21.1	102.3	19.1	103.7	(4)
			WB	25.1	82.5	2.5	1.7	23.3	83.7	21.9	84.7	20.5	85.6	18.7	86.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	42.1	46.1	53.8	64.0	71.5	77.4	82.2	81.8	75.6	65.7	55.8	46.0
	DBStd	15.13	6.25	7.66	7.65	7.34	5.40	4.50	3.79	4.28	6.00	6.09	6.62	5.24
	HDD50	623	255	154	46	2	0	0	0	0	0	0	22	144
	HDD65	2649	709	530	357	105	8	0	0	0	4	64	282	590
	CDD50	5587	10	45	163	424	668	821	999	986	767	488	197	19
	CDD65	2137	0	1	9	76	211	371	534	521	321	86	7	0
	CDH74	19262	1	14	77	528	1403	2948	5792	5400	2573	482	44	0
	CDH80	7640	0	1	14	142	450	1011	2503	2372	1023	121	3	0
Wind	WSAvg	3.4	3.7	4.0	3.7	3.6	3.1	2.8	3.2	3.3	3.4	3.1	3.1	3.4
Precipitation	PrecAvg	48.6	1.6	1.9	3.3	5.7	7.9	8.2	5.8	4.6	2.6	3.6	2.6	1.4
	PrecMax	72.7	4.8	4.5	7.8	15.3	18.2	21.8	17.8	22.1	8.6	10.4	9.8	3.4
	PrecMin	31.0	0.2	0.0	0.7	1.6	1.9	3.3	0.1	0.3	0.0	0.2	0.0	0.0
	PrecStd	7.6	0.8	1.0	1.5	2.6	3.0	3.7	3.8	3.5	2.0	2.2	2.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.9	75.4	81.6	88.0	91.3	93.2	97.4	98.2	95.7	88.5	79.1	66.8
		MCWB	54.8	61.6	67.3	71.2	73.4	77.4	78.5	77.9	76.3	71.0	65.3	54.0
	2%	DB	59.4	68.2	75.1	84.3	88.1	90.8	94.8	95.4	92.3	83.2	74.1	62.1
		MCWB	49.8	58.1	63.4	69.8	72.8	77.2	78.7	78.3	75.5	68.5	61.7	50.9
	5%	DB	54.4	61.9	70.4	80.4	85.2	88.5	92.8	93.2	89.6	79.2	69.9	57.7
		MCWB	47.5	53.9	60.6	68.6	72.1	76.7	78.5	77.9	74.5	66.4	59.4	49.6
	10%	DB	51.1	56.9	65.5	76.0	81.9	86.1	90.8	90.8	86.3	75.6	66.1	54.2
		MCWB	46.1	50.6	57.9	66.7	71.6	76.2	78.2	77.6	73.5	65.6	58.6	47.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	62.8	69.2	74.6	78.2	80.9	82.7	82.2	79.8	74.8	67.9	56.7
		MCDB	63.6	73.5	79.8	82.7	85.3	87.9	90.5	90.3	87.4	83.1	76.0	61.7
	2%	WB	51.2	59.2	65.7	72.4	76.5	79.3	81.2	80.9	78.3	71.6	64.3	53.5
		MCDB	55.9	67.0	72.9	80.6	83.3	86.4	89.1	89.6	86.6	78.2	70.0	59.2
	5%	WB	49.0	55.2	62.3	70.4	74.6	78.3	80.1	79.9	77.0	69.6	61.9	51.0
		MCDB	53.4	60.4	67.8	77.5	81.0	85.1	88.0	88.3	85.3	75.4	67.0	55.8
	10%	WB	46.7	51.3	58.8	68.1	73.0	77.3	79.2	79.0	75.5	67.3	59.6	49.0
		MCDB	50.6	56.1	63.9	74.0	79.2	83.6	87.0	86.7	83.5	73.3	64.5	53.5
Mean Daily Temperature Range	5% DB	MDBR	9.8	11.0	12.6	14.0	14.0	12.3	14.1	15.0	15.2	13.0	12.7	11.6
		MCDBR	20.3	22.9	23.5	23.0	21.6	17.5	18.5	19.4	20.5	20.7	21.2	22.0
		MCWBR	11.6	12.8	11.5	10.0	8.2	6.3	5.2	5.0	6.1	7.4	9.6	11.9
	5% WB	MCDBR	17.2	20.5	19.2	18.7	15.8	13.7	16.0	16.4	17.1	15.9	16.4	17.8
		MCWBR	10.4	12.6	10.8	9.6	7.6	5.8	5.6	5.4	5.8	7.3	8.6	10.5
Clear-Sky Solar Irradiance	taub	0.691	0.711	0.774	0.742	0.646	0.624	0.556	0.631	0.671	0.740	0.686	0.682	
	taud	1.482	1.481	1.417	1.517	1.738	1.807	1.998	1.781	1.665	1.484	1.543	1.509	
	Ebn at Noon	174	187	187	200	221	225	240	221	207	178	174	168	
	Edh at Noon	82	89	100	92	74	69	57	70	76	87	77	77	
All-Sky Solar Radiation	RadAvg	476	594	818	1019	1122	1178	1557	1427	1161	837	687	530	
	RadStd	115	155	105	154	188	172	144	122	142	124	133	128	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	+1.48	N/A	N/A	N/A	N/A	+185	+90
Regional (7 neighbors)		+0.43	N/A	N/A	+0.92	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page