

ZHIJIANG, China

WMO: 577450

Lat: 27.4548N

Lon: 109.6812E

Elev: 273

StdP: 98.09

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -1.3	(c) -0.1	(d) -7.2	(e) 2.1	(f) 4.1	(g) -5.3	(h) 2.5	(i) 3.4	(j) 6.2	(k) 7.0	(l) 5.4	(m) 6.0	(n) 1.7	(o) 40	(p) 0.336

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.8	(c) 35.1	(d) 25.7	(e) 33.9	(f) 25.3	(g) 32.8	(h) 25.1	(i) 27.2	(j) 31.7	(k) 26.7	(l) 31.1	(m) 26.2	(n) 30.4	(o) 2.4	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	22.4	28.9	25.7	21.6	28.5	25.1	20.9	28.2	88.4	31.8	85.8	31.3	83.6	30.5	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 5.4	(b) 4.7	(c) 4.2	(e) -3.1	(f) 37.1	(g) 1.6	(h) 1.1	(i) -4.2	(j) 37.8	(k) -5.2	(l) 38.5	(m) -6.0	(n) 39.1	(o) -7.2	(p) 39.8		
(a) 5.4	(b) 4.7	(c) 4.2	(e) -3.8	(f) 28.0	(g) 1.4	(h) 0.9	(i) -4.8	(j) 28.7	(k) -5.6	(l) 29.3	(m) -6.4	(n) 29.8	(o) -7.4	(p) 30.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.6	5.6	7.8	12.1	17.8	22.0	25.2	27.9	27.7	24.2	18.7	13.2	7.8
	DBStd	8.41	3.47	4.26	4.25	4.08	3.00	2.50	2.11	2.38	3.33	3.38	3.68	2.91
	HDD10.0	346	142	86	26	1	0	0	0	0	0	0	12	80
	HDD18.3	1472	394	294	198	58	4	0	0	0	2	36	157	328
	CDD10.0	3104	6	25	91	236	371	456	555	548	426	271	109	11
	CDD18.3	1187	0	1	5	42	117	206	297	289	178	48	4	0
	CDH23.3	10701	1	8	43	293	779	1638	3218	3000	1429	268	24	0
	CDH26.7	4244	0	1	8	79	250	562	1391	1318	568	67	2	0
Wind	WSAvg	1.5	1.6	1.8	1.7	1.6	1.4	1.2	1.4	1.5	1.5	1.4	1.4	1.5
Precipitation	PrecAvg	1235	41	49	83	146	201	209	147	116	65	91	65	35
	PrecMax	1846	123	114	198	389	463	553	451	562	218	264	249	87
	PrecMin	788	5	1	19	40	48	83	3	7	0	6	0	0
	PrecStd	192	21	26	38	67	77	94	96	89	51	56	50	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	24.1	27.5	31.1	33.0	34.0	36.4	36.8	35.4	31.4	26.2	19.3
		MCWB	12.7	16.4	19.6	21.8	23.0	25.2	25.9	25.5	24.6	21.7	18.5	12.2
	2%	DB	15.2	20.1	24.0	29.0	31.2	32.6	34.9	35.2	33.5	28.5	23.4	16.7
		MCWB	9.9	14.5	17.4	21.0	22.7	25.1	26.0	25.7	24.1	20.3	16.5	10.5
	5%	DB	12.5	16.6	21.3	26.9	29.6	31.4	33.8	34.0	32.0	26.2	21.1	14.3
		MCWB	8.6	12.2	15.9	20.3	22.3	24.8	25.9	25.5	23.6	19.1	15.2	9.8
	10%	DB	10.6	13.9	18.6	24.5	27.7	30.0	32.6	32.7	30.2	24.2	18.9	12.3
		MCWB	7.8	10.3	14.4	19.3	22.0	24.6	25.6	25.3	23.0	18.7	14.8	8.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.2	17.1	20.7	23.7	25.7	27.2	28.2	27.9	26.6	23.8	19.9	13.7
		MCDB	17.6	23.1	26.6	28.2	29.6	31.1	32.5	32.4	30.8	28.4	24.5	16.5
	2%	WB	10.7	15.1	18.7	22.5	24.7	26.3	27.4	27.2	25.7	22.0	18.0	11.9
		MCDB	13.3	19.4	22.7	27.0	28.5	30.2	31.7	32.0	30.3	25.6	21.1	15.1
	5%	WB	9.4	12.9	16.8	21.3	23.7	25.7	26.7	26.6	25.0	20.9	16.6	10.5
		MCDB	11.9	15.8	19.9	25.3	27.2	29.5	31.1	31.3	29.6	24.1	19.4	13.2
	10%	WB	8.1	10.7	14.9	20.1	22.8	25.2	26.2	26.1	24.2	19.6	15.3	9.4
		MCDB	10.4	13.4	17.7	23.3	26.2	28.6	30.5	30.4	28.6	23.0	18.1	12.0
Mean Daily Temperature Range	5% DB	MDBR	5.4	6.1	7.0	7.8	7.8	6.8	7.8	8.4	8.4	7.2	7.0	6.5
		MCDBR	11.3	12.7	13.1	12.8	12.0	9.7	10.3	10.8	11.4	11.5	11.8	12.2
		MCWBR	6.5	7.1	6.4	5.6	4.6	3.5	2.9	2.8	3.4	4.1	5.4	6.6
	5% WB	MCDBR	9.6	11.4	10.7	10.4	8.8	7.6	8.9	9.1	9.5	8.8	9.1	9.9
MCWBR		5.8	7.0	6.0	5.4	4.2	3.2	3.1	3.0	3.2	4.0	4.8	5.8	
Clear-Sky Solar Irradiance	taub	0.691	0.711	0.774	0.742	0.646	0.624	0.556	0.631	0.671	0.740	0.686	0.682	
	taud	1.482	1.481	1.417	1.517	1.738	1.807	1.998	1.781	1.665	1.484	1.543	1.509	
	Ebn at Noon	548	589	588	631	697	708	757	698	651	560	548	529	
	Edh at Noon	260	280	314	291	234	217	179	221	241	275	242	244	
All-Sky Solar Radiation	RadAvg	1.50	1.87	2.58	3.21	3.54	3.71	4.91	4.50	3.66	2.64	2.17	1.67	
	RadStd	0.36	0.49	0.33	0.49	0.59	0.54	0.45	0.39	0.45	0.39	0.42	0.40	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.82	N/A	N/A	N/A	N/A	+103	+50
Regional (7 neighbors)	+0.24	N/A	N/A	+0.51	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page