

NANYUE, China

WMO: 577760

Lat: 27.2960N

Lon: 112.6936E

Elev: 1268

StdP: 86.99

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-8.4	-7.0	-16.6	1.0	2.1	-13.1	1.4	1.6	18.3	9.0	16.0	8.3	4.6	0	0.564

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.0	26.6	22.3	25.7	22.1	24.8	21.7	23.1	25.3	22.6	24.7	22.1	24.0	2.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.5	20.2	24.3	22.0	19.5	23.8	21.6	19.0	23.3	76.4	25.4	74.2	24.8	72.2	24.1	25.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.0	12.6	DB	-9.7	28.5	1.9	0.9	-11.0	29.2	-12.1	29.7	-13.1	30.3	-14.5	31.0	(4)
(5)			WB	-10.3	24.2	1.8	0.5	-11.5	24.5	-12.6	24.8	-13.5	25.1	-14.8	25.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	0.8	3.1	7.3	12.8	16.8	19.8	22.0	21.4	18.1	13.7	8.9	3.2
	DBStd	8.29	5.30	5.88	5.18	4.27	3.11	2.29	2.00	2.38	3.42	3.70	4.82	4.77
	HDD10.0	929	287	203	115	22	1	0	0	0	1	11	77	214
	HDD18.3	2514	543	426	343	168	67	13	2	6	46	149	284	468
	CDD10.0	1791	2	11	30	107	210	293	371	352	244	124	43	4
	CDD18.3	334	0	0	0	3	18	56	114	99	39	4	0	0
	CDH23.3	606	0	0	0	2	11	46	267	226	52	4	0	0
	CDH26.7	24	0	0	0	0	0	1	11	13	1	0	0	0
Wind	WSAvg	5.1	4.8	5.3	5.5	6.1	5.3	6.1	6.8	4.4	3.9	4.0	4.4	4.5
Precipitation	PrecAvg	2004	85	120	165	253	279	249	144	193	159	166	123	67
	PrecMax	2947	194	244	272	526	540	532	341	431	633	350	253	167
	PrecMin	1494	12	30	75	137	131	68	15	14	4	3	4	1
	PrecStd	369	42	52	49	81	102	107	87	111	129	86	69	42
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	14.1	17.2	19.4	23.0	24.5	25.8	27.9	28.1	26.2	23.6	20.3	14.8
		MCWB	11.1	13.9	15.2	17.1	19.6	22.1	22.9	22.4	22.1	18.9	15.0	10.9
	2%	DB	12.3	14.8	17.3	21.0	23.2	24.6	26.7	26.7	24.8	21.4	18.1	12.9
		MCWB	9.8	11.9	14.0	17.2	19.2	21.6	22.4	22.3	21.4	17.6	14.2	9.0
	5%	DB	10.6	13.2	15.8	19.7	22.0	23.6	25.8	25.6	23.6	19.7	16.6	11.5
		MCWB	8.3	11.1	13.4	16.6	18.5	21.0	22.2	22.1	20.7	16.5	13.3	8.3
	10%	DB	9.1	11.8	14.4	18.4	20.9	22.7	24.9	24.6	22.5	18.5	15.2	10.0
		MCWB	6.6	10.2	12.4	16.0	18.2	20.6	21.9	21.8	20.0	15.7	12.1	6.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.1	14.4	17.0	19.7	21.6	23.1	24.0	23.7	22.9	20.2	17.1	13.8
		MCDB	13.0	16.1	18.6	21.1	23.3	24.9	26.1	25.8	24.9	22.1	18.4	14.1
	2%	WB	10.7	12.9	15.5	18.6	20.7	22.2	23.2	23.1	22.1	18.7	15.9	11.1
		MCDB	11.7	14.3	16.3	20.0	22.0	23.7	25.4	25.3	24.0	20.2	17.3	11.8
	5%	WB	9.2	11.6	14.2	17.7	20.0	21.7	22.7	22.6	21.3	17.5	14.5	9.4
		MCDB	10.3	12.8	15.1	18.7	21.0	23.0	24.8	24.6	23.1	19.0	15.7	10.6
	10%	WB	7.2	10.5	13.0	16.9	19.2	21.1	22.2	22.1	20.6	16.5	12.9	7.5
		MCDB	8.5	11.5	13.9	17.8	20.2	22.2	24.2	23.9	22.1	17.9	14.6	9.4
Mean Daily Temperature Range	5% DB	MDBR	4.6	4.9	5.0	5.2	4.6	3.7	4.0	3.9	4.4	4.8	5.0	5.0
		MCDBR	6.3	6.9	6.3	6.6	5.6	4.8	5.3	5.5	5.3	6.1	5.9	6.3
		MCWBR	4.9	5.2	4.9	4.9	4.5	3.3	3.2	3.3	3.7	4.6	4.4	5.2
	5% WB	MCDBR	6.0	6.8	5.6	6.1	4.7	4.1	4.7	4.8	5.1	5.3	5.1	6.0
		MCWBR	5.1	5.5	4.8	4.8	3.8	3.0	3.2	3.3	3.5	4.1	4.2	5.4
Clear-Sky Solar Irradiance	taub	0.542	0.570	0.615	0.595	0.532	0.517	0.471	0.523	0.539	0.572	0.526	0.519	
	taud	1.705	1.686	1.628	1.726	1.934	2.018	2.169	1.989	1.892	1.725	1.789	1.767	
	Ebn at Noon	673	700	700	734	781	788	824	781	752	688	684	671	
	Edh at Noon	207	227	254	236	192	176	151	179	192	215	188	186	
All-Sky Solar Radiation	RadAvg	1.65	1.98	2.56	3.26	3.81	4.11	5.36	4.60	3.80	3.02	2.38	1.95	
	RadStd	0.38	0.56	0.34	0.45	0.55	0.53	0.56	0.38	0.41	0.47	0.42	0.46	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days					
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only		N/A	N/A	N/A	+0.68	+0.29	+0.35	N/A	N/A	N/A	N/A		
(47) Regional (6 neighbors)		+0.30	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	+144	N/A		

Nomenclature: See separate page