

YICHUN JIANGXI, China

WMO: 577930

Lat: 27.7912N

Lon: 114.3693E

Elev: 423

StdP: 14.47

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	30.8	32.6	18.7	14.3	43.6	23.1	17.7	42.6	15.0	41.6	13.0	43.6	3.1	270	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	13.9	96.6	79.5	94.9	79.2	92.9	78.8	81.7	90.9	80.9	90.2	80.1	89.0	5.7	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.6	155.9	85.5	78.7	151.4	84.8	78.0	147.7	84.2	46.0	91.1	45.1	90.4	44.3	89.6	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.7	10.9	9.4	DB	27.0	99.5	2.6	2.0	25.1	100.9	23.6	102.1	22.2	103.2	20.3	104.7	
			WB	26.2	83.2	2.4	0.8	24.5	83.7	23.1	84.2	21.8	84.6	20.1	85.2	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	65.1	43.3	47.4	54.8	65.3	73.4	79.1	84.2	83.3	77.1	68.0	57.2	47.0
	DBStd	15.37	6.04	7.85	7.80	7.35	5.11	4.71	3.88	4.23	5.82	5.70	6.75	5.41
	HDD50	536	223	133	38	2	0	0	0	0	0	0	15	125
	HDD65	2424	673	495	328	84	3	0	0	0	1	34	246	560
	CDD50	6054	15	60	188	462	726	873	1062	1034	813	559	232	30
	CDD65	2467	0	2	13	94	264	423	597	569	364	128	13	0
	CDH74	24399	0	16	95	659	1865	3911	7331	6500	3239	716	67	0
	CDH80	10133	0	2	16	187	602	1490	3519	2937	1215	157	8	0
Wind	WSAvg	4.2	4.2	4.4	4.4	4.6	4.5	4.1	4.1	4.2	4.0	3.9	3.9	4.0
Precipitation	PrecAvg	63.1	2.8	4.4	6.6	8.9	9.5	8.9	5.3	4.8	3.3	3.5	3.1	2.0
	PrecMax	78.5	7.5	8.1	9.9	14.3	18.6	17.7	9.3	10.6	8.4	12.0	8.5	5.0
	PrecMin	43.1	0.3	1.5	2.2	4.4	2.2	3.5	0.3	0.1	0.6	0.0	0.2	0.0
	PrecStd	9.9	1.6	1.9	2.0	2.8	3.9	4.2	2.4	2.5	2.0	2.4	2.4	1.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.8	76.4	81.9	90.9	93.3	95.3	99.2	99.3	95.8	88.5	80.4	67.6
		MCWB	55.0	63.7	67.9	72.3	75.7	79.6	79.8	79.6	78.3	72.4	66.2	55.4
	2%	DB	60.5	69.1	76.3	85.1	89.6	92.9	96.9	96.6	92.7	84.3	75.6	63.0
		MCWB	51.8	58.7	64.0	70.9	73.5	78.6	79.8	79.6	77.9	70.3	62.9	53.0
	5%	DB	56.3	63.2	71.4	81.1	86.4	90.6	95.3	94.4	89.9	81.0	71.7	59.6
		MCWB	49.3	54.8	60.7	68.9	72.3	78.1	79.5	79.4	77.1	67.6	61.1	51.7
	10%	DB	52.5	58.8	66.8	77.4	83.1	88.0	93.3	92.0	87.0	78.0	68.0	56.2
		MCWB	46.8	52.7	59.2	67.8	71.9	77.4	79.3	79.3	75.3	66.4	59.9	49.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.5	64.6	70.3	76.6	79.1	82.0	82.8	82.7	80.9	76.0	69.9	60.2
		MCDB	62.9	74.8	78.9	85.4	86.8	89.5	92.0	91.8	89.8	83.9	75.7	63.3
	2%	WB	53.9	60.5	66.4	73.6	77.1	80.8	81.8	81.5	79.7	73.3	66.8	56.4
		MCDB	58.1	66.8	73.5	81.5	83.6	88.9	91.3	91.1	88.2	80.2	71.0	60.7
	5%	WB	50.2	57.0	63.6	71.9	75.8	79.8	81.0	80.7	78.6	71.2	64.3	52.6
		MCDB	55.0	61.3	68.6	78.4	81.5	87.3	90.4	90.4	86.5	77.0	68.7	56.9
	10%	WB	47.5	53.8	60.9	69.8	74.5	78.8	80.3	79.9	77.5	69.4	61.5	50.2
		MCDB	51.5	57.5	65.3	74.9	79.7	85.5	89.4	88.8	84.5	75.3	66.1	54.5
Mean Daily Temperature Range	5% DB	MDBR	9.9	10.7	11.9	13.5	13.6	12.2	13.9	13.5	13.6	14.0	13.5	12.4
		MCDBR	19.8	20.7	22.3	21.6	21.0	17.1	18.5	17.9	17.8	19.6	20.9	20.9
	5% WB	MCWBR	11.2	10.8	10.5	9.0	7.6	5.6	4.9	4.8	5.7	6.7	8.9	11.2
		MCWBR	15.7	17.9	17.5	16.9	14.0	14.2	15.9	15.8	15.5	14.4	13.7	14.5
Clear-Sky Solar Irradiance	taub		0.671	0.714	0.772	0.750	0.667	0.651	0.594	0.646	0.669	0.699	0.639	0.626
	taud		1.535	1.495	1.435	1.515	1.704	1.756	1.904	1.759	1.679	1.562	1.632	1.623
	Ebn at Noon		178	186	187	198	216	219	231	218	207	187	185	181
	Edh at Noon		78	87	98	93	77	72	62	72	75	80	70	69
All-Sky Solar Radiation	RadAvg		563	668	844	1059	1220	1266	1681	1465	1238	1023	784	668
	RadStd		131	187	109	144	177	170	159	130	133	152	150	155

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	+0.70	N/A	N/A	+0.90	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.70	N/A	N/A	+1.10	N/A	N/A	N/A	N/A	+301	+178

Nomenclature: See separate page