

YICHUN JIANGXI, China

WMO: 577930

Lat: 27.7912N

Lon: 114.3693E

Elev: 129

StdP: 99.78

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -0.7	(c) 0.4	(d) -7.4	(e) 2.0	(f) 6.5	(g) -4.9	(h) 2.5	(i) 5.9	(j) 6.7	(k) 5.3	(l) 5.8	(m) 6.4	(n) 1.4	(o) 270	(p) 0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.7	35.9	26.4	34.9	26.2	33.8	26.0	27.6	32.7	27.2	32.3	26.7	31.7	2.5	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.4	22.3	29.7	26.0	21.6	29.3	25.6	21.1	29.0	89.1	32.9	87.0	32.4	85.2	32.0	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5.7	4.9	4.2	-2.8	37.5	1.4	1.1	-3.8	38.3	-4.6	38.9	-5.4	39.6	-6.5	40.4
			-3.2	28.4	1.3	0.4	-4.2	28.7	-4.9	29.0	-5.7	29.2	-6.6	29.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.4	6.3	8.5	12.7	18.5	23.0	26.2	29.0	28.5	25.1	20.0	14.0	8.3
	DBStd	8.54	3.36	4.36	4.33	4.08	2.84	2.62	2.16	2.35	3.23	3.17	3.75	3.01
	HDD10.0	298	124	74	21	1	0	0	0	0	0	0	8	69
	HDD18.3	1347	374	275	182	47	2	0	0	0	1	19	137	311
	CDD10.0	3363	8	33	104	257	403	485	590	574	452	311	129	17
	CDD18.3	1371	0	1	7	52	147	235	332	316	202	71	7	0
	CDH23.3	13555	0	9	53	366	1036	2173	4073	3611	1799	398	37	0
	CDH26.7	5629	0	1	9	104	334	828	1955	1632	675	87	4	0
Wind	WSAvg	1.9	1.9	2.0	2.0	2.1	2.0	1.8	1.8	1.9	1.8	1.8	1.8	1.8
Precipitation	PrecAvg	1602	70	111	168	227	242	225	135	121	84	90	78	50
	PrecMax	1994	190	206	252	363	472	449	236	269	213	304	216	126
	PrecMin	1095	8	37	56	113	56	88	8	2	14	0	4	0
	PrecStd	252	41	49	52	71	99	106	62	63	51	61	60	36
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.8	24.7	27.7	32.7	34.0	35.1	37.3	37.4	35.5	31.4	26.9	19.8
		MCWB	12.8	17.6	20.0	22.4	24.3	26.4	26.6	26.4	25.7	22.5	19.0	13.0
	2%	DB	15.8	20.6	24.6	29.5	32.0	33.8	36.0	35.9	33.7	29.1	24.2	17.2
		MCWB	11.0	14.8	17.8	21.6	23.1	25.9	26.5	26.4	25.5	21.3	17.2	11.7
	5%	DB	13.5	17.4	21.9	27.3	30.2	32.5	35.2	34.6	32.2	27.2	22.1	15.3
		MCWB	9.6	12.7	16.0	20.5	22.4	25.6	26.4	26.4	25.0	19.8	16.2	10.9
	10%	DB	11.4	14.9	19.3	25.2	28.4	31.1	34.1	33.4	30.5	25.6	20.0	13.4
		MCWB	8.2	11.5	15.1	19.9	22.2	25.2	26.3	26.3	24.0	19.1	15.5	9.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	18.1	21.3	24.8	26.2	27.8	28.2	28.2	27.2	24.4	21.0	15.7
		MCDB	17.1	23.8	26.0	29.6	30.5	32.0	33.4	33.2	32.1	28.8	24.3	17.4
	2%	WB	12.2	15.8	19.1	23.1	25.1	27.1	27.7	27.5	26.5	23.0	19.3	13.5
		MCDB	14.5	19.4	23.0	27.5	28.7	31.6	33.0	32.9	31.2	26.8	21.7	16.0
	5%	WB	10.1	13.9	17.6	22.2	24.4	26.6	27.2	27.1	25.9	21.8	18.0	11.5
		MCDB	12.8	16.3	20.3	25.8	27.5	30.7	32.5	32.4	30.3	25.0	20.4	13.9
	10%	WB	8.6	12.1	16.0	21.0	23.6	26.0	26.8	26.6	25.3	20.8	16.4	10.1
		MCDB	10.8	14.2	18.5	23.8	26.5	29.7	31.9	31.6	29.2	24.1	18.9	12.5
Mean Daily Temperature Range	5% DB	MDBR	5.5	6.0	6.6	7.5	7.5	6.8	7.7	7.5	7.6	7.8	7.5	6.9
		MCDBR	11.0	11.5	12.4	12.0	11.7	9.5	10.3	9.9	9.9	10.9	11.6	11.6
		MCWBR	6.2	6.0	5.8	5.0	4.2	3.1	2.7	2.7	3.1	3.7	4.9	6.2
	5% WB	MCDBR	8.7	9.9	9.7	9.4	7.8	7.9	8.9	8.8	8.6	8.0	7.6	8.1
		MCWBR	5.3	5.8	5.4	4.8	3.6	3.2	2.9	2.9	3.1	3.5	4.0	5.0
Clear-Sky Solar Irradiance	taub		0.671	0.714	0.772	0.750	0.667	0.651	0.594	0.646	0.669	0.699	0.639	0.626
	taud		1.535	1.495	1.435	1.515	1.704	1.756	1.904	1.759	1.679	1.562	1.632	1.623
	Ebn at Noon		562	586	588	625	682	689	728	687	651	588	583	572
	Edh at Noon		245	275	308	292	242	228	196	226	238	253	220	216
All-Sky Solar Radiation	RadAvg		1.77	2.11	2.66	3.34	3.85	3.99	5.30	4.62	3.90	3.22	2.47	2.11
	RadStd		0.41	0.59	0.34	0.46	0.56	0.54	0.50	0.41	0.42	0.48	0.47	0.49

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	+0.50	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)		+0.39	N/A	N/A	+0.61	N/A	N/A	N/A	N/A	+167	+99

Nomenclature: See separate page