

GUIYANG, China

WMO: 578160

Lat: 26.5897N

Lon: 106.7276E

Elev: 4012

StdP: 12.69

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.3	28.6	20.1	17.5	33.7	22.6	19.7	33.4	17.9	58.4	15.6	52.7	5.6	40	0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.6	87.2	71.0	85.1	70.5	83.2	69.8	74.0	82.6	72.9	80.9	72.0	79.5	8.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.7	136.0	78.0	70.5	130.5	76.6	69.8	127.6	75.9	40.8	82.8	39.7	81.1	38.7	79.6	83.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	16.1	13.7	11.9	DB	24.9	90.7	2.9	2.4	22.8	92.4	21.1	93.8	19.4	95.1	17.3	96.8
(5)				WB	23.8	75.5	2.8	2.4	21.7	77.2	20.1	78.6	18.5	80.0	16.4	81.7

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	40.3	45.0	52.5	61.8	67.2	71.4	75.1	74.7	69.5	61.4	53.6	43.9	(6)
(7)		DBStd	13.62	7.79	9.57	8.83	8.08	5.69	4.56	3.42	3.98	5.60	6.18	7.17	6.44	(7)
(8)		HDD50	852	316	200	75	8	0	0	0	0	1	44	208		(8)
(9)		HDD65	3097	766	562	400	154	43	6	0	1	21	147	344	653	(9)
(10)		CDD50	4422	15	59	153	362	533	643	777	766	586	355	153	20	(10)
(11)		CDD65	1194	0	1	12	58	111	199	312	303	158	36	4	0	(11)
(12)		CDH74	6219	0	13	66	299	548	865	1716	1771	797	137	7	0	(12)
(13)		CDH80	1344	0	1	8	53	92	149	399	466	161	15	0	0	(13)
(14)	Wind	WSAvg	5.8	5.8	6.3	6.1	6.4	5.9	5.5	5.8	5.5	5.6	5.4	5.6	5.6	(14)
(15)	Precipitation	PrecAvg	43.4	0.9	0.9	1.6	3.1	6.7	8.2	7.6	5.2	3.1	3.7	1.6	0.8	(15)
(16)		PrecMax	57.9	1.9	2.5	3.6	7.1	11.0	13.1	19.5	13.0	6.6	7.6	3.6	1.9	(16)
(17)		PrecMin	28.5	0.2	0.2	0.4	1.1	2.3	2.2	1.2	0.9	0.7	1.0	0.2	0.2	(17)
(18)		PrecStd	7.1	0.4	0.6	0.7	1.6	2.5	2.4	4.3	2.8	1.7	1.8	0.9	0.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.1	76.1	80.5	85.1	86.0	86.7	89.7	90.0	87.0	82.3	74.5	66.4	(19)
(20)		0.4%	MCWB	54.0	55.8	60.5	64.3	69.6	72.8	73.2	71.5	69.7	67.3	61.7	55.7	(20)
(21)		2%	DB	60.0	69.5	75.0	80.9	82.6	83.9	86.3	87.2	84.3	77.8	70.1	60.7	(21)
(22)		2%	MCWB	51.2	55.7	60.1	64.8	67.1	70.4	72.0	71.0	69.2	64.8	59.0	51.5	(22)
(23)		5%	DB	55.3	63.9	69.8	77.4	79.8	81.5	84.2	84.9	81.6	74.4	67.0	57.1	(23)
(24)		5%	MCWB	49.1	54.1	59.2	64.1	66.3	70.4	71.6	70.8	68.1	64.0	58.3	49.3	(24)
(25)		10%	DB	51.3	58.8	65.3	73.6	77.0	79.0	82.1	82.5	78.8	71.2	64.2	53.5	(25)
(26)		10%	MCWB	46.5	52.7	57.1	63.3	66.0	69.6	71.1	70.2	67.3	62.9	57.0	47.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	55.2	58.7	63.9	69.4	73.0	74.9	75.5	75.0	72.9	69.2	64.4	56.7	(27)
(28)		0.4%	MCDWB	61.5	69.3	74.1	79.8	81.7	83.1	84.7	84.9	82.8	78.3	69.9	63.9	(28)
(29)		2%	WB	52.6	56.7	61.6	67.3	70.6	73.5	74.0	73.5	71.5	67.3	62.2	53.7	(29)
(30)		2%	MCDWB	58.5	65.1	70.8	76.0	78.4	80.4	82.5	82.7	80.4	74.3	67.1	59.3	(30)
(31)		5%	WB	50.0	54.8	59.9	65.8	69.1	72.2	72.9	72.4	70.2	65.9	60.0	50.9	(31)
(32)		5%	MCDWB	54.5	62.5	68.2	74.2	76.2	78.5	80.8	80.8	77.7	72.3	65.7	55.5	(32)
(33)		10%	WB	46.7	52.5	58.0	64.1	67.8	71.0	71.9	71.4	69.0	64.2	57.9	48.1	(33)
(34)		10%	MCDWB	50.8	59.5	65.0	71.9	74.2	76.7	79.3	79.2	75.8	69.6	63.1	52.1	(34)
(35)	Mean Daily Temperature Range		MDBR	9.6	12.0	13.3	14.1	13.4	11.5	12.6	13.6	13.3	11.4	11.6	10.6	(35)
(36)		5% DB	MCDBR	19.0	21.8	21.1	19.8	19.1	16.2	16.8	18.0	17.9	18.4	17.3	19.6	(36)
(37)		5% DB	MCWBR	11.2	10.2	9.1	7.5	7.5	6.1	5.5	5.4	6.0	7.6	8.1	10.6	(37)
(38)		5% WB	MCDWR	15.9	19.9	19.5	17.9	15.8	13.4	15.2	16.0	15.4	15.2	14.6	15.9	(38)
(39)		5% WB	MCWBR	10.3	10.0	9.2	7.9	7.8	6.2	5.8	5.7	6.2	7.0	7.6	9.6	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.573	0.581	0.682	0.649	0.549	0.528	0.486	0.531	0.536	0.614	0.595	0.603	(40)	
(41)		taud	1.646	1.661	1.508	1.619	1.906	2.004	2.139	1.982	1.929	1.673	1.648	1.592	(41)	
(42)		Ebn at Noon	206	220	207	220	244	247	258	246	240	209	199	189	(42)	
(43)		Edh at Noon	70	74	91	84	63	56	49	57	59	72	69	72	(43)	
(44)	All-Sky Solar Radiation	RadAvg	509	745	940	1184	1239	1142	1474	1406	1155	771	721	527	(44)	
(45)		RadStd	120	158	132	175	183	174	120	126	134	136	116	104	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (6 neighbors)	+0.47	N/A	N/A	+0.95	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page