

GUIYANG, China

WMO: 578160

Lat: 26.5897N

Lon: 106.7276E

Elev: 1223

StdP: 87.47

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -3.2	(c) -1.9	(d) -6.6	(e) 2.5	(f) 0.9	(g) -5.2	(h) 2.8	(i) 0.8	(j) 8.0	(k) 14.7	(l) 7.0	(m) 11.5	(n) 2.5	(o) 40	(p) 0.368

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 7.0	(c) 30.6	(d) 21.7	(e) 29.5	(f) 21.4	(g) 28.4	(h) 21.0	(i) 23.3	(j) 28.1	(k) 22.7	(l) 27.2	(m) 22.2	(n) 26.4	(o) 3.8	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.0	19.4	25.6	21.4	18.6	24.8	21.0	18.2	24.4	77.0	28.2	74.4	27.3	72.2	26.4	28.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 7.2	(b) 6.1	(c) 5.3	(e) -3.9	(f) 32.6	(g) 1.6	(h) 1.3	(i) -5.1	(j) 33.6	(k) -6.1	(l) 34.3	(m) -7.0	(n) 35.1	(o) -8.2	(p) 36.0		
(a) 7.2	(b) 6.1	(c) 5.3	(e) -4.6	(f) 24.2	(g) 1.6	(h) 1.3	(i) -5.7	(j) 25.1	(k) -6.6	(l) 25.9	(m) -7.5	(n) 26.7	(o) -8.6	(p) 27.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	15.4	4.6	7.2	11.4	16.6	19.6	21.9	23.9	23.7	20.9	16.3	12.0	6.6
	DBStd	7.57	4.33	5.32	4.91	4.49	3.16	2.53	1.90	2.21	3.11	3.44	3.98	3.58
	HDD10.0	473	176	111	42	4	0	0	0	0	0	1	24	116
	HDD18.3	1721	426	312	222	86	24	3	0	1	12	82	191	363
	CDD10.0	2457	8	33	85	201	296	357	432	426	326	197	85	11
	CDD18.3	663	0	1	7	32	62	111	173	168	88	20	2	0
	CDH23.3	3455	0	7	37	166	304	481	953	984	443	76	4	0
	CDH26.7	747	0	1	4	29	51	83	222	259	89	8	0	0
Wind	WSAvg	2.6	2.6	2.8	2.7	2.8	2.7	2.4	2.6	2.4	2.5	2.4	2.5	2.5
Precipitation	PrecAvg	1102	22	22	41	79	171	209	192	131	80	94	40	21
	PrecMax	1471	47	64	92	181	280	332	495	329	167	192	92	48
	PrecMin	723	6	5	10	29	58	56	31	24	18	25	4	5
	PrecStd	181	10	16	19	41	63	62	110	70	43	46	23	12
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	18.4	24.5	26.9	29.5	30.0	30.4	32.0	32.2	30.6	27.9	23.6	19.1
		MCWB	12.2	13.2	15.8	18.0	20.9	22.7	22.9	21.9	20.9	19.6	16.5	13.1
	2%	DB	15.5	20.9	23.9	27.2	28.1	28.8	30.2	30.7	29.0	25.5	21.1	15.9
		MCWB	10.7	13.2	15.6	18.2	19.5	21.3	22.2	21.7	20.7	18.2	15.0	10.8
	5%	DB	12.9	17.7	21.0	25.2	26.6	27.5	29.0	29.4	27.6	23.6	19.4	13.9
		MCWB	9.5	12.3	15.1	17.8	19.0	21.3	22.0	21.5	20.0	17.8	14.6	9.6
	10%	DB	10.7	14.9	18.5	23.1	25.0	26.1	27.8	28.1	26.0	21.8	17.9	11.9
		MCWB	8.0	11.5	13.9	17.4	18.9	20.9	21.7	21.2	19.6	17.2	13.9	8.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.9	14.8	17.7	20.8	22.8	23.9	24.2	23.9	22.7	20.7	18.0	13.7
		MCDB	16.4	20.7	23.4	26.5	27.6	28.4	29.3	29.4	28.2	25.7	21.0	17.7
	2%	WB	11.4	13.7	16.5	19.6	21.4	23.1	23.3	23.1	21.9	19.6	16.8	12.1
		MCDB	14.7	18.4	21.6	24.5	25.8	26.9	28.1	28.2	26.9	23.5	19.5	15.2
	5%	WB	10.0	12.6	15.5	18.8	20.6	22.3	22.7	22.4	21.2	18.9	15.6	10.5
		MCDB	12.5	17.0	20.1	23.4	24.5	25.8	27.1	27.1	25.4	22.4	18.7	13.1
	10%	WB	8.2	11.4	14.4	17.9	19.9	21.7	22.2	21.9	20.6	17.9	14.4	9.0
		MCDB	10.4	15.3	18.3	22.2	23.4	24.8	26.3	26.2	24.4	20.9	17.3	11.2
Mean Daily Temperature Range	5% DB	MDBR	5.3	6.7	7.4	7.8	7.4	6.4	7.0	7.6	7.4	6.3	6.4	5.9
		MCDBR	10.5	12.1	11.7	11.0	10.6	9.0	9.3	10.0	10.0	10.2	9.6	10.9
		MCWBR	6.2	5.6	5.0	4.2	4.2	3.4	3.0	3.0	3.3	4.2	4.5	5.9
	5% WB	MCDBR	8.8	11.0	10.8	9.9	8.8	7.5	8.4	8.9	8.5	8.5	8.1	8.8
		MCWBR	5.7	5.5	5.1	4.4	4.3	3.5	3.2	3.2	3.4	3.9	4.2	5.3
Clear-Sky Solar Irradiance	taub	0.573	0.581	0.682	0.649	0.549	0.528	0.486	0.531	0.536	0.614	0.595	0.603	
	taud	1.646	1.661	1.508	1.619	1.906	2.004	2.139	1.982	1.929	1.673	1.648	1.592	
	Ebn at Noon	650	694	653	695	769	780	813	775	758	658	626	597	
	Edh at Noon	221	234	288	264	198	178	155	181	186	228	219	226	
All-Sky Solar Radiation	RadAvg	1.60	2.35	2.96	3.73	3.91	3.60	4.65	4.43	3.64	2.43	2.27	1.66	
	RadStd	0.38	0.50	0.42	0.55	0.58	0.55	0.38	0.40	0.42	0.43	0.36	0.33	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (6 neighbors)	+0.26	N/A	N/A	+0.53	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page