

LINGLING, China

WMO: 578660

Lat: 26.2259N

Lon: 111.6165E

Elev: 174

StdP: 99.25

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.6	0.5	-7.6	2.0	6.7	-4.9	2.6	6.2	8.0	8.2	7.1	6.8	2.7	20	0.375

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	35.7	25.5	34.6	25.4	33.6	25.3	27.3	31.1	26.8	31.1	26.3	30.8	3.0	250

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.7	22.8	28.4	25.8	21.6	28.3	25.2	20.8	28.4	88.3	30.8	85.6	31.2	83.5	31.1	30.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.3	5.5	DB	-1.5	37.5	1.2	1.2	-2.4	38.3	-3.1	39.0	-3.8	39.7	-4.7	40.6	(4)
(5)			WB	-2.6	27.9	1.2	1.0	-3.5	28.6	-4.2	29.2	-4.9	29.8	-5.8	30.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	18.7	6.6	8.9	13.0	19.0	23.3	26.6	29.4	28.5	25.0	20.0	14.4	8.8
	DBStd	8.64	4.10	5.14	4.85	4.53	3.28	2.73	2.22	2.64	3.52	3.54	4.15	3.36
	HDD10.0	293	122	77	22	1	0	0	0	0	0	0	9	62
	HDD18.3	1307	364	267	176	46	3	0	0	0	2	23	131	296
	CDD10.0	3460	17	47	117	272	412	497	601	574	450	310	139	25
	CDD18.3	1433	1	3	13	67	156	247	342	316	202	75	12	0
	CDH23.3	14378	1	19	71	463	1203	2432	4277	3637	1804	407	64	1
CDH26.7	5969	0	2	8	117	390	929	2074	1652	691	94	11	0	
Wind	WSAvg	2.6	2.6	2.8	2.7	2.7	2.5	2.4	2.6	2.5	2.6	2.5	2.6	2.6
Precipitation	PrecAvg	1352	65	91	128	209	219	167	87	123	65	76	79	48
	PrecMax	1938	134	209	255	442	473	280	244	304	183	164	196	98
	PrecMin	950	5	21	43	93	77	45	5	3	0	1	2	0
	PrecStd	252	37	45	58	85	101	64	58	72	54	47	57	30
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.5	25.8	27.7	31.9	33.5	34.8	37.1	37.3	35.7	31.9	28.4	21.3
		MCWB	15.6	17.9	20.6	22.1	24.0	25.6	25.3	25.5	25.1	22.9	20.0	14.2
	2%	DB	17.7	23.0	25.3	29.8	31.9	33.3	35.7	35.9	34.0	29.2	25.1	18.2
		MCWB	12.2	16.4	18.9	22.1	23.5	25.5	25.6	25.4	25.0	21.3	18.2	12.2
	5%	DB	15.1	20.2	23.2	27.8	30.5	32.2	34.6	34.6	32.3	27.3	22.9	16.0
		MCWB	10.6	15.1	17.8	21.2	23.2	25.3	25.5	25.4	24.4	20.2	17.0	10.6
	10%	DB	12.6	16.8	20.7	26.1	28.9	31.1	33.6	33.2	30.6	25.6	20.7	14.0
		MCWB	9.0	12.6	16.1	20.6	23.1	25.2	25.5	25.4	23.8	19.4	15.4	9.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.3	18.8	21.7	24.1	26.8	27.8	28.5	27.8	26.6	24.5	21.3	16.5
		MCDB	20.3	24.6	26.4	28.8	30.2	30.2	31.3	31.1	31.8	29.8	26.0	19.1
	2%	WB	13.5	17.2	20.2	23.1	25.5	26.8	27.5	27.1	26.0	22.9	19.6	13.8
		MCDB	16.5	22.2	24.2	27.7	29.4	30.4	31.2	31.3	30.8	26.6	23.8	17.0
	5%	WB	11.1	15.5	18.6	22.3	24.7	26.2	26.9	26.6	25.4	21.9	18.2	11.8
		MCDB	14.1	19.8	22.2	26.7	28.6	30.1	31.3	31.1	30.1	25.3	21.5	14.4
	10%	WB	9.3	13.1	16.8	21.4	23.8	25.7	26.3	26.1	24.7	20.8	16.6	10.4
		MCDB	12.2	16.2	20.2	25.2	27.5	29.6	31.1	30.9	29.3	24.1	19.3	13.0
Mean Daily Temperature Range	5% DB	MDBR	4.7	5.3	5.7	6.5	6.7	6.0	6.8	6.9	6.7	6.5	6.3	5.7
		MCDBR	9.9	11.2	10.4	9.9	9.6	7.7	8.6	9.1	9.4	9.6	10.0	10.5
		MCWBR	5.5	6.0	5.3	4.1	3.7	2.7	2.3	2.2	2.7	3.4	4.3	5.3
	5% WB	MCDBR	8.5	10.4	9.1	8.4	7.3	6.6	7.6	7.6	8.0	7.8	8.1	7.8
		MCWBR	5.1	6.1	5.5	4.4	3.7	3.0	2.9	2.6	2.7	3.6	4.2	4.6
Clear-Sky Solar Irradiance	taub	0.691	0.719	0.790	0.753	0.653	0.623	0.563	0.651	0.692	0.745	0.668	0.665	
	taud	1.502	1.494	1.416	1.520	1.741	1.823	1.989	1.743	1.635	1.492	1.593	1.563	
	Ebn at Noon	559	591	582	626	693	709	753	686	640	564	572	554	
	Edh at Noon	258	279	316	291	233	214	181	230	250	275	233	234	
All-Sky Solar Radiation	RadAvg	1.67	1.99	2.45	3.17	3.65	3.93	5.14	4.49	3.75	3.06	2.46	2.03	
	RadStd	0.41	0.53	0.37	0.44	0.55	0.59	0.58	0.35	0.38	0.42	0.43	0.49	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.39	N/A	N/A	+0.55	N/A	N/A	N/A	N/A	+145	+83
(47) Regional (7 neighbors)		+0.27	N/A	N/A	+0.48	N/A	N/A	N/A	N/A	+119	+71

Nomenclature: See separate page