

DUSHAN, China

WMO: 579220

Lat: 25.8325N

Lon: 107.5481E

Elev: 3332

StdP: 13.01

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	27.3	29.9	20.1	17.1	35.1	23.1	19.7	35.2	16.4	51.3	14.5	47.9	5.0	340	0.347

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.3	85.7	72.1	84.0	71.8	82.3	71.3	75.0	80.9	74.1	80.0	73.4	79.2	6.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
73.6	141.6	77.6	72.6	136.9	77.0	71.8	133.0	76.3	41.3	81.1	40.4	80.2	39.6	79.5	84.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.7	13.7	12.0		DB	25.5	89.2	2.8	1.4	23.5	90.2	21.8	91.0	20.3	91.9	18.2	92.9
				WB	24.0	76.8	2.7	1.9	22.0	78.1	20.4	79.2	18.9	80.3	16.9	81.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.7	41.7	46.2	53.0	62.1	68.3	72.5	75.1	74.8	70.3	63.0	55.1	45.7
	DBStd	13.17	7.96	9.61	8.40	7.50	5.22	3.74	2.80	3.27	4.94	5.82	6.93	6.60
	HDD50	722	280	176	63	7	0	0	0	0	0	1	29	166
	HDD65	2830	723	530	382	140	28	2	0	0	13	108	304	600
	CDD50	4630	22	68	157	370	567	674	779	768	609	403	181	32
	CDD65	1263	0	2	11	53	130	226	314	303	172	46	6	0
	CDH74	5577	0	9	36	192	510	843	1512	1588	752	127	8	0
	CDH80	963	0	0	2	26	63	103	278	355	129	7	0	0
Wind	WSAvg	5.4	5.1	5.8	6.0	6.3	5.9	5.6	5.8	4.6	4.8	4.9	5.1	5.0
Precipitation	PrecAvg	52.3	1.1	1.4	2.1	5.0	8.1	9.2	8.0	5.9	3.8	4.2	2.4	1.1
	PrecMax	65.6	2.2	3.5	6.1	13.0	15.4	17.8	20.1	12.6	8.9	10.7	9.8	3.2
	PrecMin	38.1	0.1	0.2	0.3	0.9	4.6	4.4	0.5	1.3	0.3	0.2	0.0	0.0
	PrecStd	6.4	0.5	0.8	1.3	2.5	2.7	3.5	4.0	2.9	2.2	2.8	2.1	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	65.3	74.6	78.8	83.2	84.4	85.2	87.9	88.1	86.3	80.8	75.0	68.3
		MCWB	55.6	59.7	64.2	66.6	69.9	72.2	73.3	72.2	70.6	66.7	61.7	57.5
	2%	DB	60.3	68.9	73.2	79.0	81.7	82.8	85.3	85.8	83.5	77.5	71.1	62.8
		MCWB	53.0	58.7	62.9	67.2	68.4	72.2	73.1	72.5	70.1	65.9	60.4	53.6
	5%	DB	56.9	64.0	68.6	75.6	79.4	80.9	83.2	83.8	81.3	74.7	68.3	59.1
		MCWB	52.0	57.2	61.2	65.9	68.2	71.7	72.9	72.3	69.5	64.7	59.6	51.4
	10%	DB	53.4	60.1	64.8	72.4	76.7	78.7	81.1	81.8	78.5	72.0	65.6	55.7
		MCWB	49.5	55.4	59.4	65.1	67.9	71.2	72.5	72.0	68.5	64.2	58.8	49.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.5	62.2	66.3	71.1	74.6	76.4	76.3	75.5	73.8	70.3	65.8	59.6
		MCDB	61.9	70.1	74.0	76.1	79.7	80.9	81.8	83.2	80.3	75.7	70.3	65.4
	2%	WB	55.2	59.9	64.2	69.4	72.7	74.7	75.0	74.4	72.7	68.7	64.0	56.5
		MCDB	59.2	66.3	69.8	74.9	77.6	79.2	80.8	81.7	78.8	73.6	68.2	60.9
	5%	WB	53.1	57.9	62.5	67.7	71.3	73.6	74.1	73.6	71.7	67.4	62.3	53.4
		MCDB	56.0	63.4	67.8	73.1	76.3	78.1	79.9	80.5	77.2	72.0	66.2	57.2
	10%	WB	49.7	55.7	60.4	66.4	70.0	72.6	73.3	72.8	70.7	66.1	60.1	50.4
		MCDB	52.8	60.3	64.4	71.5	74.5	76.9	79.0	79.2	75.9	70.4	64.2	54.6
Mean Daily Temperature Range	5% DB	MDBR	9.0	10.5	11.2	11.8	11.5	9.7	10.3	12.1	12.2	11.0	11.5	10.7
		MCDBR	16.1	16.7	16.9	16.2	15.8	13.2	14.3	15.9	16.2	15.4	16.4	18.2
		MCWBR	9.6	7.7	7.8	6.4	5.9	4.8	4.4	5.0	5.1	5.9	7.6	9.7
	5% WB	MCDBR	12.7	14.7	14.9	13.6	11.5	10.2	11.3	13.2	12.1	11.4	11.4	13.5
		MCWBR	8.6	7.6	7.8	6.9	5.8	4.6	4.3	5.0	4.7	5.4	6.9	8.3
Clear-Sky Solar Irradiance	taub	0.563	0.570	0.672	0.643	0.536	0.518	0.483	0.528	0.545	0.616	0.559	0.578	
	taud	1.684	1.710	1.544	1.654	1.976	2.063	2.169	2.011	1.922	1.680	1.747	1.662	
	Ebn at Noon	211	224	210	222	247	250	259	247	239	210	211	199	
	Edh at Noon	68	71	88	81	58	53	48	56	60	72	63	67	
All-Sky Solar Radiation	RadAvg	526	724	901	1134	1212	1136	1443	1406	1206	876	782	600	
	RadStd	128	154	129	164	158	157	110	108	130	127	138	104	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.45	N/A	N/A	+0.83	+0.68	+0.70	N/A	N/A	N/A	N/A
Regional (5 neighbors)		N/A	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page