

RONGJIANG, China

WMO: 579320

Lat: 25.9274N

Lon: 108.5123E

Elev: 942

StdP: 14.20

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	34.0	36.4	24.5	19.2	42.5	27.7	22.4	42.6	13.4	54.7	11.5	55.4	1.7	40	0.302

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	95.9	77.9	93.9	77.4	91.8	77.0	80.2	89.6	79.5	88.4	78.8	87.3	4.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.2	151.8	82.8	77.4	147.7	82.1	76.8	144.8	81.7	44.9	90.2	44.0	88.6	43.2	87.5	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.0	9.6	7.7	31.8	99.8	2.1	1.5	30.3	100.9	29.0	101.8	27.8	102.6	26.3	103.7
			30.4	82.3	2.2	2.3	28.8	83.9	27.6	85.3	26.3	86.5	24.7	88.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	67.1	47.4	51.7	58.8	68.2	74.7	79.7	82.8	82.5	77.7	69.5	60.6	51.1
	DBStd	13.64	6.79	8.43	7.80	7.13	5.02	3.95	3.25	3.70	5.25	5.75	6.26	5.53
	HDD50	272	132	72	14	1	0	0	0	0	0	0	4	49
	HDD65	1814	547	380	224	46	1	0	0	0	1	23	159	433
	CDD50	6521	50	120	286	547	766	890	1016	1007	831	605	321	82
	CDD65	2591	0	8	32	142	303	440	551	542	382	163	27	1
	CDH74	22349	3	64	212	977	2139	3808	5726	5359	3070	863	119	9
	CDH80	8781	0	12	51	310	776	1371	2440	2335	1233	239	13	1
Wind	WSAvg	2.5	2.4	2.8	2.8	2.9	2.6	2.4	2.6	2.4	2.1	2.3	2.1	2.1
Precipitation	PrecAvg	46.3	1.3	1.5	2.1	4.7	7.4	8.3	5.9	5.6	2.8	3.5	2.3	1.1
	PrecMax	57.8	3.3	3.3	5.7	9.3	12.0	14.0	14.6	15.7	9.2	10.8	6.9	3.4
	PrecMin	32.8	0.1	0.0	0.7	1.6	2.0	3.4	1.0	0.7	0.1	0.8	0.1	0.0
	PrecStd	7.1	0.7	0.8	1.3	1.9	2.5	3.5	3.4	3.7	1.9	2.5	1.8	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.9	81.6	85.7	91.3	94.0	95.1	98.4	98.1	96.5	90.1	82.1	73.7
		MCWB	61.0	65.6	69.5	73.7	74.9	77.8	78.9	77.8	77.0	72.7	68.9	62.5
	2%	DB	65.2	74.9	79.7	87.0	90.8	92.5	95.8	95.9	93.4	86.0	77.6	66.8
		MCWB	56.6	62.9	66.9	71.6	73.9	77.5	78.5	77.9	76.0	71.8	65.6	56.7
	5%	DB	60.6	69.8	74.9	83.6	87.9	90.0	93.2	93.7	90.6	82.4	73.9	62.7
		MCWB	53.7	60.8	63.9	70.8	73.6	77.2	78.2	77.9	75.4	69.8	64.1	54.2
	10%	DB	56.5	64.1	70.4	80.1	84.6	87.4	90.8	91.1	87.2	78.8	70.2	59.0
		MCWB	51.7	57.1	62.4	69.2	73.1	76.7	77.9	77.5	74.1	68.5	63.0	52.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.1	66.1	70.8	75.5	79.0	80.8	81.6	81.0	79.2	76.1	71.0	63.9
		MCDB	70.1	79.0	83.0	85.7	88.2	89.7	91.5	92.2	89.5	85.2	78.5	72.3
	2%	WB	58.2	63.6	68.1	73.7	77.2	79.7	80.4	80.0	78.2	74.1	68.8	58.9
		MCDB	64.2	73.6	77.4	83.6	85.8	87.6	89.4	90.3	87.8	81.4	74.9	64.2
	5%	WB	55.0	61.3	66.1	72.1	75.9	78.8	79.5	79.2	77.3	72.5	66.3	56.2
		MCDB	58.6	69.3	73.0	81.0	83.4	86.0	88.1	88.8	85.9	78.5	71.4	60.6
	10%	WB	52.3	58.3	63.7	70.8	74.8	78.0	78.8	78.4	76.3	70.8	64.1	53.5
		MCDB	56.3	63.1	69.0	78.3	81.3	84.3	87.0	87.1	83.8	76.3	68.4	57.6
Mean Daily Temperature Range	5% DB	MDBR	9.7	11.7	12.9	14.3	14.5	12.9	14.4	15.5	15.6	13.5	13.2	12.1
		MCDBR	19.8	22.6	22.7	21.1	22.1	18.1	19.6	20.4	21.2	20.4	20.0	21.6
		MCWBR	10.6	10.4	9.2	7.2	6.6	4.7	4.3	4.6	5.3	6.9	8.8	11.2
	5% WB	MCDBR	16.0	19.8	19.1	17.9	15.4	13.7	16.0	17.2	16.7	15.6	15.7	17.9
MCWBR		9.4	9.6	8.8	6.9	5.7	4.4	4.5	5.0	4.7	6.5	7.8	9.9	
Clear-Sky Solar Irradiance	taub	0.661	0.674	0.777	0.746	0.624	0.594	0.550	0.612	0.649	0.728	0.649	0.666	
	taud	1.541	1.557	1.423	1.521	1.805	1.896	2.020	1.834	1.720	1.518	1.617	1.550	
	Ebn at Noon	185	198	188	200	226	232	242	227	213	183	187	176	
	Edh at Noon	79	83	100	92	69	63	56	67	73	85	72	75	
All-Sky Solar Radiation	RadAvg	494	639	808	1008	1119	1102	1432	1393	1192	904	756	592	
	RadStd	120	149	119	153	169	148	124	108	136	123	152	125	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.63	N/A	N/A	+1.03	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page