

CHENZHOU, China

WMO: 579720

Lat: 25.7355N

Lon: 112.9773E

Elev: 369

StdP: 96.97

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-0.7	0.4	-5.5	2.5	6.5	-3.5	3.0	4.9	7.0	8.2	5.6	8.6	1.3	0	0.343

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.8	36.0	24.9	34.9	24.8	33.9	24.7	26.5	32.0	26.1	31.5	25.7	31.0	2.4	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.2	21.3	28.6	24.7	20.7	28.3	24.4	20.2	28.1	85.4	32.0	83.6	31.5	81.9	31.1	30.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
8.7	6.4	5.0	-1.7	37.4	1.2	1.3	-2.6	38.3	-3.3	39.0	-3.9	39.7	-4.8	40.6	
			DB												
			WB	-2.7	27.5	1.3	1.4	-3.6	28.5	-4.4	29.3	-5.2	30.1	-6.2	31.1

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	6.9	9.3	13.6	19.5	23.8	27.1	29.7	28.6	25.2	20.3	14.7	9.0
	DBStd	8.78	4.70	5.76	5.30	4.78	3.49	2.95	2.28	2.68	3.60	3.79	4.53	3.71
	HDD10.0	300	123	78	23	1	0	0	0	0	0	0	11	63
	HDD18.3	1266	356	257	164	43	3	0	0	0	2	24	126	291
	CDD10.0	3594	27	59	136	287	426	514	612	577	455	318	151	32
	CDD18.3	1517	1	5	18	79	171	264	353	319	207	84	16	1
	CDH23.3	15661	4	38	117	605	1446	2783	4519	3666	1861	514	107	2
	CDH26.7	6730	0	4	14	166	505	1164	2282	1682	743	146	22	0
Wind	WSAvg	1.7	1.4	1.6	1.7	2.1	1.8	2.0	2.3	1.6	1.4	1.3	1.2	1.3
Precipitation	PrecAvg	1564	69	84	159	181	215	245	160	169	89	65	75	52
	PrecMax	2126	198	171	362	309	397	354	350	317	169	254	216	154
	PrecMin	1070	11	14	80	61	107	134	29	55	28	1	1	6
	PrecStd	248	40	42	59	62	62	61	82	73	36	57	49	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.4	26.9	28.5	32.2	34.0	35.4	37.5	37.6	35.8	32.3	29.4	22.8
		MCWB	16.7	18.3	20.0	22.3	23.3	25.2	25.0	24.9	24.5	22.4	20.2	14.8
	2%	DB	20.0	24.2	26.3	30.3	32.5	34.1	36.1	36.0	34.1	30.2	26.4	19.6
		MCWB	13.7	17.0	18.7	21.8	23.1	25.0	25.0	24.8	24.3	21.3	18.4	13.5
	5%	DB	17.3	21.8	24.4	28.6	31.1	32.9	35.1	34.7	32.6	28.1	23.8	17.1
		MCWB	12.0	15.9	18.1	21.1	23.0	24.8	24.9	24.9	24.1	20.1	17.1	11.5
	10%	DB	14.0	18.9	22.3	26.9	29.6	31.8	34.0	33.3	31.0	26.2	21.3	14.6
		MCWB	9.9	14.3	16.9	20.5	22.8	24.7	24.9	25.0	23.8	19.6	16.0	10.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	19.2	21.3	23.7	25.9	26.7	27.2	27.1	26.2	24.3	21.3	17.7
		MCDB	22.6	25.9	26.9	29.5	30.8	31.4	33.1	32.9	31.6	28.9	26.7	20.8
	2%	WB	14.9	17.5	20.0	22.8	24.9	26.1	26.5	26.5	25.5	23.1	19.7	14.6
		MCDB	19.0	23.2	24.6	28.5	29.5	31.2	32.3	31.9	30.9	27.5	24.4	17.5
	5%	WB	12.5	16.2	18.7	22.1	24.2	25.6	26.0	26.0	25.0	22.0	18.4	12.5
		MCDB	16.2	21.3	23.4	27.2	29.0	30.7	31.7	31.3	30.1	25.7	22.2	15.9
	10%	WB	10.3	14.5	17.5	21.2	23.6	25.2	25.6	25.6	24.4	21.0	16.9	10.7
		MCDB	13.7	18.5	21.6	25.9	28.2	30.2	31.2	30.7	29.3	24.4	20.5	13.8
Mean Daily Temperature Range	5% DB	MDBR	5.3	5.8	6.3	6.9	6.9	6.2	6.8	6.8	6.8	6.8	6.9	6.3
		MCDBR	12.1	11.6	10.9	9.9	9.6	7.6	8.3	8.9	9.4	10.6	11.6	12.0
		MCWBR	6.7	6.0	5.1	3.9	3.3	2.3	2.0	2.1	2.5	3.6	4.9	6.3
	5% WB	MCDBR	10.5	10.8	9.3	8.6	7.8	6.8	7.5	7.7	7.9	8.1	9.1	9.1
		MCWBR	6.4	6.1	5.2	4.1	3.3	2.6	2.5	2.5	2.7	3.7	4.6	5.5
Clear-Sky Solar Irradiance	taub	0.708	0.752	0.841	0.805	0.680	0.646	0.599	0.677	0.707	0.744	0.660	0.663	
	taud	1.476	1.437	1.338	1.427	1.674	1.754	1.869	1.672	1.597	1.486	1.597	1.562	
	Ebn at Noon	549	570	552	594	675	693	726	668	631	567	582	559	
	Edh at Noon	266	296	343	320	250	229	204	247	261	278	233	236	
All-Sky Solar Radiation	RadAvg	1.89	2.17	2.49	3.08	3.67	3.97	5.09	4.52	3.90	3.34	2.65	2.28	
	RadStd	0.48	0.52	0.42	0.43	0.51	0.57	0.53	0.35	0.37	0.51	0.46	0.53	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	-1.18	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (4 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page