

GANZHOU, China

WMO: 579930

Lat: 25.8705N

Lon: 115.0142E

Elev: 440

StdP: 14.46

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 33.4	(c) 35.4	(d) 18.2	(e) 14.0	(f) 44.7	(g) 23.4	(h) 18.0	(i) 44.1	(j) 10.2	(k) 50.2	(l) 9.4	(m) 49.1	(n) 3.2	(o) 340	(p) 0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 13.7	(c) 97.2	(d) 77.2	(e) 95.5	(f) 77.3	(g) 93.8	(h) 77.3	(i) 80.4	(j) 90.1	(k) 79.8	(l) 89.3	(m) 79.1	(n) 88.4	(o) 5.6	(p) 200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.2	149.0	83.7	77.4	145.0	83.4	76.8	142.1	83.2	44.5	90.3	43.8	89.7	43.1	88.5	84.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 10.2	(b) 9.1	(c) 7.7	(e) 30.2	(f) 99.9	(g) 1.8	(h) 1.9	(i) 28.9	(j) 101.3	(k) 27.8	(l) 102.4	(m) 26.8	(n) 103.4	(o) 25.5	(p) 104.8		
(a) 10.2	(b) 9.1	(c) 7.7	(e) 28.2	(f) 81.3	(g) 2.2	(h) 1.5	(i) 26.6	(j) 82.4	(k) 25.3	(l) 83.2	(m) 24.1	(n) 84.0	(o) 22.5	(p) 85.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	68.7	47.9	52.4	58.8	69.4	76.7	81.9	86.1	85.0	79.9	72.0	61.6	51.2		
	DBStd	14.73	7.65	9.71	8.66	7.40	5.29	4.59	3.47	3.58	5.34	5.81	6.98	6.31		
	HDD50	297	135	79	19	1	0	0	0	0	0	0	4	59		
	HDD65	1762	533	368	232	41	1	0	0	0	0	12	144	431		
	CDD50	7108	69	147	292	583	827	956	1119	1086	898	681	354	96		
	CDD65	3097	1	16	40	174	363	506	654	621	449	228	43	2		
	CDH74	32252	8	95	230	1148	2983	5461	8559	7609	4441	1481	228	9		
	CDH80	14038	0	9	32	303	1040	2314	4428	3629	1819	426	38	0		
(14) Wind	WSAvg	3.2	3.0	3.1	3.0	3.1	3.2	3.4	3.8	3.4	3.3	3.1	2.9	2.9		
(15) Precipitation	PrecAvg	56.1	2.6	3.7	6.4	7.0	8.5	8.1	4.5	5.6	3.3	2.3	2.4	1.8		
	PrecMax	85.9	9.6	10.6	19.3	17.7	15.3	19.0	13.7	12.6	10.4	8.5	8.7	7.3		
	PrecMin	37.3	0.1	0.0	0.9	1.2	1.4	0.7	0.2	0.3	0.2	0.0	0.0	0.0		
	PrecStd	12.0	2.2	2.4	3.2	3.3	3.2	4.1	2.9	2.9	2.3	2.0	2.0	1.7		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.6	81.2	83.7	89.9	94.1	96.6	99.8	99.6	96.4	91.9	84.2	74.5		
		MCWB	62.7	66.1	68.1	72.6	75.4	77.7	76.6	77.2	76.9	73.8	69.1	63.2		
	2%	DB	68.3	76.9	79.7	86.6	91.2	94.3	97.6	97.0	93.9	87.5	80.1	68.7		
		MCWB	58.8	64.1	66.9	71.7	74.5	77.6	77.3	77.2	76.9	71.7	67.0	58.2		
	5%	DB	64.0	72.8	76.2	83.6	88.7	92.2	95.8	95.2	91.7	84.8	76.2	64.7		
		MCWB	56.5	62.4	65.6	70.5	74.0	77.4	77.4	77.5	76.4	69.6	64.0	56.0		
	10%	DB	59.5	67.6	72.3	80.6	85.9	90.0	93.9	93.0	89.2	81.9	72.4	61.2		
		MCWB	52.8	59.9	63.7	69.7	73.5	77.1	77.4	77.6	75.5	68.8	62.9	53.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.4	68.3	71.4	75.7	79.5	80.7	81.2	81.3	80.1	76.8	72.2	66.7		
		MCDB	70.9	78.7	79.6	84.5	88.9	90.4	91.2	91.2	88.5	85.1	79.3	73.2		
	2%	WB	61.3	65.7	69.5	73.9	78.0	79.7	80.3	80.3	79.1	75.0	69.5	61.7		
		MCDB	67.2	74.8	76.5	82.1	86.4	89.0	90.4	90.0	87.8	82.6	76.9	65.6		
	5%	WB	57.5	63.4	67.2	72.7	76.8	79.0	79.7	79.6	78.2	73.3	67.5	57.7		
		MCDB	62.8	71.1	74.0	80.4	84.2	88.0	89.5	89.0	86.9	80.5	73.2	62.2		
	10%	WB	53.5	60.5	65.1	71.4	75.6	78.2	79.0	79.0	77.4	71.7	64.9	54.6		
		MCDB	58.8	67.5	71.5	78.6	82.6	86.7	88.6	87.9	85.8	78.9	70.6	59.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	11.9	12.0	12.8	12.9	11.9	13.7	13.5	12.9	13.8	13.5	12.9		
		MCDBR	19.9	20.9	19.5	17.8	17.8	15.5	16.4	17.0	16.5	18.3	20.2	20.2		
		MCWBR	10.8	9.6	8.8	6.2	5.1	3.7	3.3	3.5	3.6	5.2	7.7	10.3		
		MCDBR	16.8	17.9	15.7	14.4	13.5	12.9	14.4	14.4	14.3	13.8	15.0	14.1		
	5% WB	MCWBR	10.3	9.1	8.6	6.6	5.1	4.2	4.1	4.2	3.9	4.9	7.3	8.5		
(40) Clear-Sky Solar Irradiance	taub		0.674	0.721	0.812	0.788	0.669	0.633	0.588	0.652	0.669	0.700	0.637	0.622		
	taud		1.546	1.504	1.396	1.475	1.721	1.805	1.918	1.745	1.688	1.576	1.657	1.651		
	Ebn at Noon		182	187	181	192	216	223	233	218	208	189	190	188		
	Edh at Noon		79	88	103	97	75	69	62	73	75	80	69	68		
(44) All-Sky Solar Radiation	RadAvg		686	781	863	1045	1211	1303	1698	1527	1311	1160	892	802		
	RadStd		158	170	144	159	164	156	152	121	116	201	152	178		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.74	N/A	N/A	+0.86	N/A	N/A	N/A	+266	+203
(47) Regional (6 neighbors)		+0.54	N/A	N/A	+0.85	N/A	N/A	N/A	+230	+171

Nomenclature: See separate page