

XUZHOU, China

WMO: 580270

Lat: 34.2871N

Lon: 117.1587E

Elev: 138

StdP: 14.62

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) 21.0	(c) 23.8	(d) -1.6	(e) 5.1	(f) 30.8	(g) 3.0	(h) 6.4	(i) 31.5	(j) 14.2	(k) 36.0	(l) 12.7	(m) 35.9	(n) 2.8	(o) 270	(p) 0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 11.9	(c) 95.1	(d) 78.7	(e) 92.9	(f) 77.9	(g) 90.7	(h) 76.7	(i) 82.7	(j) 90.8	(k) 81.6	(l) 89.3	(m) 80.5	(n) 87.6	(o) 6.3	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
80.7	160.0	87.8	79.6	154.2	86.8	78.5	148.5	85.7	46.9	90.9	45.7	89.6	44.4	87.8	87.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.5	11.7	10.1	16.4	99.0	2.9	2.0	14.2	100.4	12.5	101.6	10.9	102.7	8.7	104.2
			14.1	84.4	3.0	1.1	11.9	85.2	10.2	85.8	8.5	86.4	6.3	87.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	60.1	34.5	39.7	49.7	60.8	70.6	78.5	82.4	80.7	72.9	62.6	49.2	38.1	(6)
	DBStd	17.67	5.39	6.62	7.38	6.92	5.77	4.77	4.70	4.82	4.98	5.95	7.14	5.80	(7)
	HDD50	1345	480	293	97	5	0	0	0	0	0	1	98	371	(8)
	HDD65	3735	945	708	478	160	16	0	0	0	4	116	474	834	(9)
	CDD50	5024	0	5	86	331	638	854	1004	952	686	392	74	2	(10)
	CDD65	1941	0	0	2	36	189	405	539	488	240	42	0	0	(11)
	CDH74	19253	0	1	16	294	1579	4115	6255	5179	1597	213	4	0	(12)
	CDH80	7557	0	0	2	60	489	1715	2802	2066	399	24	0	0	(13)
(14) Wind	WSAvg	4.7	4.2	5.0	5.7	5.6	5.4	5.3	4.7	4.4	4.0	3.8	4.0	4.1	(14)
(15) Precipitation	PrecAvg	32.6	0.5	0.7	1.2	2.2	2.5	3.5	9.7	5.3	3.7	1.9	0.9	0.6	(15)
	PrecMax	47.8	1.9	2.2	4.0	7.6	12.4	10.4	18.9	12.0	9.8	5.4	4.0	2.4	(16)
	PrecMin	19.7	0.0	0.0	0.1	0.2	0.1	0.3	1.8	0.4	0.8	0.0	0.0	0.0	(17)
	PrecStd	6.7	0.6	0.6	0.9	1.8	3.0	2.5	4.7	3.0	2.5	1.5	0.9	0.6	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	63.4	76.0	85.8	93.4	97.4	98.1	96.6	90.9	83.1	73.3	57.9	(19)
		MCWB	43.5	50.9	60.2	67.9	67.4	73.1	80.7	82.0	74.7	64.7	58.5	46.9	(20)
	2%	DB	49.6	57.9	70.9	81.0	88.7	93.8	95.4	93.3	86.9	79.3	67.6	53.5	(21)
		MCWB	41.0	46.5	56.6	65.5	67.7	72.1	80.9	81.5	73.4	63.4	55.1	45.9	(22)
	5%	DB	46.4	54.2	66.7	77.3	85.1	91.2	93.4	91.1	84.2	76.2	63.9	50.4	(23)
		MCWB	39.2	44.4	54.0	62.9	67.1	71.8	80.3	80.1	71.6	62.4	53.8	43.3	(24)
	10%	DB	43.6	50.6	62.4	73.5	82.2	88.8	91.1	88.9	81.9	73.0	60.7	47.5	(25)
		MCWB	37.3	42.7	51.2	60.5	66.0	71.4	79.5	79.0	69.7	61.4	52.9	41.4	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	46.4	53.9	63.0	71.9	74.4	79.9	84.6	83.8	80.6	70.7	62.5	51.9	(27)
		MCDB	50.5	60.9	73.3	81.1	82.6	88.8	92.6	91.9	87.2	76.1	67.0	53.8	(28)
	2%	WB	43.1	49.1	58.9	68.2	71.7	78.4	82.9	82.7	77.2	67.7	58.8	47.3	(29)
		MCDB	47.6	55.1	68.2	78.0	80.8	86.8	91.5	90.2	82.4	72.6	64.2	51.2	(30)
	5%	WB	40.3	46.1	55.7	64.8	70.0	76.9	81.9	81.7	74.8	65.6	56.3	44.8	(31)
		MCDB	45.1	52.0	63.8	73.8	79.8	84.8	90.2	88.8	80.4	72.4	61.3	48.8	(32)
	10%	WB	38.1	43.6	52.2	62.4	68.4	75.1	80.9	80.6	72.9	63.6	53.5	42.5	(33)
		MCDB	42.6	49.1	60.7	71.4	78.2	83.4	88.6	87.2	78.5	70.4	60.1	46.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	13.4	14.2	16.1	16.9	16.8	15.5	11.9	11.6	14.1	16.0	15.5	13.8	(35)
		MCDBR	18.6	20.3	22.4	21.8	21.6	19.9	15.0	13.6	16.7	20.3	21.3	18.5	(36)
	5% WB	MCWBR	11.9	12.0	12.4	10.6	8.2	6.3	4.8	4.7	5.3	7.9	11.0	11.3	(37)
		MCDWR	15.6	17.0	20.1	19.0	16.9	14.4	13.7	12.3	12.8	14.7	15.6	14.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.567	0.636	0.652	0.653	0.667	0.795	0.751	0.737	0.680	0.691	0.633	0.577	(40)
		taud	1.670	1.578	1.576	1.607	1.622	1.438	1.561	1.575	1.635	1.556	1.605	1.674	(41)
	Ebn at Noon		187	191	204	214	214	187	195	194	196	175	167	174	(42)
		Edh at Noon	62	75	82	83	82	99	87	84	76	76	66	59	(43)
(44) All-Sky Solar Radiation	RadAvg		735	883	1272	1510	1637	1572	1440	1389	1218	1024	781	684	(44)
	RadStd		86	145	113	132	131	138	162	184	152	125	110	82	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d) +0.54	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) +155	(m) N/A
Regional (9 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page