

XUZHOU, China

WMO: 580270

Lat: 34.2871N

Lon: 117.1587E

Elev: 42

StdP: 100.82

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 1	(b) -6.1	(c) -4.6	(d) -18.7	(e) 0.7	(f) -0.7	(g) -16.1	(h) 0.9	(i) -0.3	(j) 6.4	(k) 2.2	(l) 5.7	(m) 2.2	(n) 1.3	(o) 270	(p) 0.386

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 7	(b) 6.6	(c) 35.0	(d) 25.9	(e) 33.8	(f) 25.5	(g) 32.6	(h) 24.9	(i) 28.2	(j) 32.7	(k) 27.6	(l) 31.8	(m) 26.9	(n) 30.9	(o) 2.8	(p) 220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a) 27.0	(b) 22.9	(c) 31.0	(d) 26.4	(e) 22.0	(f) 30.4	(g) 25.8	(h) 21.2	(i) 29.8	(j) 91.2	(k) 32.7	(l) 88.4	(m) 32.0	(n) 85.5	(o) 31.0	(p) 30.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 6.0	(b) 5.2	(c) 4.5	(e) -8.7	(f) 37.2	(g) 1.6	(h) 1.1	(i) -9.9	(j) 38.0	(k) -10.8	(l) 38.7	(m) -11.7	(n) 39.3	(o) -12.9	(p) 40.1		
(a) 6.0	(b) 5.2	(c) 4.5	(e) -10.0	(f) 29.1	(g) 1.7	(h) 0.6	(i) -11.2	(j) 29.5	(k) -12.1	(l) 29.9	(m) -13.1	(n) 30.2	(o) -14.3	(p) 30.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.6	1.4	4.3	9.8	16.0	21.4	25.8	28.0	27.1	22.7	17.0	9.6	3.4		
	DBStd	9.81	3.00	3.68	4.10	3.84	3.21	2.65	2.61	2.68	2.77	3.31	3.97	3.22		
	HDD10.0	747	267	163	54	3	0	0	0	0	0	1	54	206		
	HDD18.3	2075	525	393	266	89	9	0	0	0	2	64	263	463		
	CDD10.0	2791	0	3	48	184	354	474	558	529	381	218	41	1		
	CDD18.3	1078	0	0	1	20	105	225	299	271	133	23	0	0		
	CDH23.3	10696	0	1	9	163	877	2286	3475	2877	887	118	2	0		
	CDH26.7	4198	0	0	1	33	272	953	1557	1148	222	13	0	0		
(14) Wind	WSAvg	2.1	1.9	2.2	2.5	2.5	2.4	2.4	2.1	2.0	1.8	1.7	1.8	1.8		
(15) Precipitation	PrecAvg	828	13	18	31	55	63	89	246	135	93	47	24	14		
	PrecMax	1215	47	57	102	192	314	263	481	304	248	136	101	62		
	PrecMin	501	0	0	2	6	2	8	46	10	20	1	0	0		
	PrecStd	169	14	16	22	45	77	63	119	76	63	37	24	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	12.5	17.4	24.5	29.9	34.1	36.4	36.7	35.9	32.7	28.4	22.9	14.4		
		MCWB	6.4	10.5	15.7	20.0	19.7	22.8	27.1	27.8	23.7	18.2	14.7	8.3		
	2%	DB	9.8	14.4	21.6	27.2	31.5	34.3	35.2	34.1	30.5	26.3	19.8	12.0		
		MCWB	5.0	8.1	13.7	18.6	19.8	22.3	27.2	27.5	23.0	17.4	12.9	7.7		
	5%	DB	8.0	12.3	19.3	25.2	29.5	32.9	34.1	32.8	29.0	24.6	17.7	10.2		
		MCWB	4.0	6.9	12.2	17.2	19.5	22.1	26.8	26.7	22.0	16.9	12.1	6.3		
	10%	DB	6.5	10.3	16.9	23.1	27.9	31.5	32.8	31.6	27.7	22.8	16.0	8.6		
		MCWB	3.0	5.9	10.7	15.8	18.9	21.9	26.4	26.1	21.0	16.4	11.6	5.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	8.0	12.2	17.2	22.2	23.5	26.6	29.2	28.8	27.0	21.5	16.9	11.1		
		MCDB	10.3	16.0	23.0	27.3	28.1	31.5	33.6	33.3	30.6	24.5	19.5	12.1		
	2%	WB	6.2	9.5	15.0	20.1	22.1	25.8	28.3	28.2	25.1	19.8	14.9	8.5		
		MCDB	8.7	12.8	20.1	25.6	27.1	30.4	33.0	32.4	28.0	22.6	17.9	10.7		
	5%	WB	4.6	7.9	13.1	18.2	21.1	24.9	27.7	27.6	23.8	18.6	13.5	7.1		
		MCDB	7.3	11.1	17.7	23.2	26.5	29.3	32.3	31.5	26.9	22.4	16.3	9.3		
	10%	WB	3.4	6.4	11.2	16.9	20.2	23.9	27.2	27.0	22.7	17.6	11.9	5.8		
		MCDB	5.9	9.5	16.0	21.9	25.7	28.6	31.5	30.7	25.8	21.3	15.6	7.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.4	7.9	9.0	9.4	9.3	8.6	6.6	6.4	7.8	8.9	8.6	7.7		
		MCDBR	10.3	11.3	12.5	12.1	12.0	11.1	8.3	7.5	9.3	11.3	11.8	10.3		
	5% WB	MCWBR	6.6	6.7	6.9	5.9	4.6	3.5	2.7	2.6	2.9	4.4	6.1	6.3		
		MCWBR	8.6	9.4	11.2	10.5	9.4	8.0	7.6	6.9	7.1	8.2	8.7	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.567	0.636	0.652	0.653	0.667	0.795	0.751	0.737	0.680	0.691	0.633	0.577		
	taud		1.670	1.578	1.576	1.607	1.622	1.438	1.561	1.575	1.635	1.556	1.605	1.674		
	Ebn at Noon		590	601	644	676	674	591	614	611	617	552	528	548		
	Edh at Noon		196	238	258	261	260	311	274	266	240	240	208	185		
(44) All-Sky Solar Radiation	RadAvg		2.32	2.78	4.01	4.76	5.16	4.96	4.54	4.38	3.84	3.23	2.46	2.16		
	RadStd		0.27	0.46	0.35	0.41	0.41	0.43	0.51	0.58	0.48	0.39	0.35	0.26		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.30	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+86	N/A
(47) Regional (9 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page