

BOXIAN, China

WMO: 581020

Lat: 33.7914N

Lon: 115.7353E

Elev: 40

StdP: 100.84

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.6	-4.1	-18.3	0.8	0.3	-15.4	1.0	0.5	7.1	5.9	6.2	3.8	1.5	340	0.399

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.2	35.6	25.7	34.4	25.3	33.2	24.9	28.3	32.9	27.7	32.0	27.0	30.9	3.2	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	23.0	31.2	26.5	22.2	30.6	25.9	21.3	29.9	92.1	33.1	88.9	32.0	85.6	31.0	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.5	5.6	5.0	-8.7	37.9	1.8	1.2	-10.0	38.8	-11.1	39.5	-12.1	40.2	-13.4	41.0		
			-10.0	29.1	1.7	0.8	-11.2	29.6	-12.2	30.1	-13.1	30.5	-14.4	31.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	16.0	1.8	4.8	10.4	16.5	21.7	26.4	28.2	27.1	22.8	17.5	10.1	3.9	(6)
		DBStd	9.74	3.07	3.84	4.21	3.92	3.26	2.78	2.65	2.73	2.97	3.48	4.24	3.19	
		HDD10.0	691	254	150	46	3	0	0	0	0	1	48	189		
		HDD18.3	1978	512	379	246	80	8	0	0	3	57	247	446		
		CDD10.0	2880	0	4	59	197	363	491	565	531	384	233	52	1	
		CDD18.3	1127	0	0	1	24	113	241	307	273	137	32	1	0	
		CDH23.3	11411	0	1	13	196	951	2566	3607	2916	979	178	6	0	
		CDH26.7	4729	0	0	1	41	319	1173	1683	1199	286	28	0	0	
(14)	Wind	WSAvg	2.4	2.3	2.5	2.9	2.9	2.7	2.5	2.4	2.3	2.1	2.1	2.3	2.3	(14)
(15)	Precipitation	PrecAvg	802	16	22	35	51	63	85	218	138	87	50	24	13	(15)
(16)		PrecMax	1473	66	71	100	153	284	208	560	591	236	146	92	54	(16)
(17)		PrecMin	473	0	0	1	3	2	4	57	23	5	0	0	0	(17)
(18)		PrecStd	217	17	20	24	45	66	56	119	104	57	42	22	13	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	13.7	18.5	25.2	30.4	34.2	37.1	37.2	36.1	33.6	29.3	24.0	15.8		(19)
(20)		0.4% MCWB	6.9	11.2	16.0	20.8	20.0	23.2	26.7	27.0	24.3	18.5	14.9	8.8		(20)
(21)		2% DB	11.0	15.5	22.2	27.6	31.9	35.4	35.8	34.4	31.2	27.1	20.9	12.7		(21)
(22)		2% MCWB	5.2	8.8	14.3	18.9	20.7	22.9	27.2	27.3	23.0	17.2	13.2	7.3		(22)
(23)		5% DB	8.8	13.3	20.0	25.6	30.0	33.8	34.6	33.1	29.6	25.3	18.6	10.7		(23)
(24)		5% MCWB	4.1	7.4	12.9	17.9	20.2	22.4	26.7	26.6	21.9	16.9	12.1	6.2		(24)
(25)		10% DB	7.0	11.2	17.6	23.5	28.3	32.4	33.3	31.8	28.2	23.5	16.4	8.9		(25)
(26)		10% MCWB	3.0	6.3	11.3	16.5	19.7	22.3	26.4	25.9	21.0	16.1	11.0	5.1		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	8.1	12.5	18.1	22.8	24.2	27.2	29.3	28.9	27.0	21.5	16.7	10.6		(27)
(28)		0.4% MCDB	11.7	17.3	23.1	28.2	28.8	31.8	34.3	33.7	30.4	24.9	22.2	13.2		(28)
(29)		2% WB	6.2	10.0	15.5	20.6	22.7	26.0	28.6	28.2	25.1	19.7	14.5	8.4		(29)
(30)		2% MCDB	9.8	14.0	20.7	25.8	28.1	31.1	33.4	32.6	28.9	23.4	18.6	11.4		(30)
(31)		5% WB	4.7	8.5	13.8	19.0	21.7	25.0	28.0	27.6	23.9	18.6	13.2	7.0		(31)
(32)		5% MCDB	8.0	12.1	18.7	23.9	27.2	30.2	32.5	31.5	27.1	22.9	17.1	9.6		(32)
(33)		10% WB	3.6	7.0	12.0	17.5	20.7	24.1	27.3	26.9	22.8	17.5	12.0	5.8		(33)
(34)		10% MCDB	6.4	10.3	16.6	22.4	26.1	29.4	31.7	30.4	26.4	21.8	15.6	8.3		(34)
(35)	Mean Daily Temperature Range	MDBR	7.7	8.3	9.0	9.5	9.5	9.3	7.2	6.8	8.1	8.8	8.3	7.6		(35)
(36)		5% DB MCDBR	11.3	11.7	12.2	12.3	12.4	11.9	8.9	8.2	10.0	11.4	11.7	10.9		(36)
(37)		5% WB MCWBR	7.1	6.7	6.4	6.1	4.8	3.6	2.8	2.8	3.4	4.3	5.9	6.5		(37)
(38)		5% WB MCDBR	10.0	10.2	11.2	11.3	10.0	9.0	8.0	7.4	7.5	8.7	9.4	8.8		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.592	0.655	0.662	0.664	0.677	0.792	0.746	0.752	0.702	0.714	0.649	0.595		(40)
(41)		taud	1.623	1.543	1.554	1.579	1.600	1.436	1.558	1.532	1.583	1.513	1.575	1.638		(41)
(42)		Ebn at Noon	572	589	639	669	668	594	618	602	603	538	520	536		(42)
(43)		Edh at Noon	207	248	264	268	266	312	275	278	253	252	216	194		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.23	2.69	3.90	4.65	5.00	4.93	4.58	4.34	3.71	3.11	2.41	2.10		(44)
(45)		RadStd	0.28	0.48	0.36	0.41	0.41	0.44	0.55	0.59	0.54	0.40	0.35	0.30		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	+0.31	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+83	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page