

HUIYIN, China

WMO: 581410

Lat: 33.6378N

Lon: 118.9269E

Elev: 45

StdP: 14.67

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.2	24.7	1.4	5.9	30.7	6.5	7.7	31.8	16.2	37.7	14.2	37.3	3.5	0	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	10.8	93.4	80.6	91.4	79.8	89.3	78.5	83.6	90.3	82.4	88.7	81.1	87.1	6.6	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.9	166.4	88.0	80.7	159.5	86.7	79.4	153.0	85.6	47.9	90.4	46.4	89.0	45.0	87.2	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	13.0	11.4	17.7	96.7	3.3	1.7	15.3	97.8	13.3	98.8	11.5	99.8	9.0	101.0
			15.1	84.8	3.6	1.7	12.5	86.0	10.4	87.0	8.4	87.9	5.8	89.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	35.4	39.3	48.5	59.4	68.9	76.4	81.9	80.8	72.6	62.9	51.0	39.7
	DBStd	17.03	5.58	6.51	6.82	6.70	5.45	4.60	4.56	4.41	4.60	5.59	7.10	6.18
	HDD50	1270	453	304	110	7	0	0	0	0	0	0	72	324
	HDD65	3677	918	719	513	191	22	0	0	0	3	105	422	784
	CDD50	4863	0	5	63	290	587	791	988	954	678	402	101	4
	CDD65	1795	0	0	1	24	144	341	523	489	231	41	1	0
	CDH74	16749	0	0	8	200	1111	2962	5854	5065	1375	172	2	0
	CDH80	6070	0	0	0	32	308	1056	2469	1900	291	14	0	0
Wind	WSAvg	5.2	4.9	5.7	6.5	6.1	5.9	5.5	5.3	5.1	4.4	4.1	4.8	4.8
Precipitation	PrecAvg	38.0	1.0	1.3	1.8	2.1	3.0	5.0	9.3	7.2	3.2	1.6	1.6	0.8
	PrecMax	52.2	3.3	3.1	5.6	4.3	5.7	10.4	15.9	12.9	7.7	8.1	5.2	2.4
	PrecMin	29.2	0.0	0.3	0.2	0.4	0.4	2.2	4.6	2.7	0.3	0.1	0.0	0.0
	PrecStd	6.1	0.9	0.7	1.2	0.9	1.4	2.3	2.7	2.4	2.0	1.5	1.3	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	54.4	63.9	73.8	83.9	90.8	94.4	96.0	94.9	89.8	82.0	72.5	60.2
		MCWB	45.8	52.2	59.6	68.5	69.5	73.3	82.9	83.3	79.0	66.9	58.9	51.4
	2%	DB	50.2	57.4	68.3	79.6	86.7	91.1	93.9	92.5	85.6	78.5	68.1	55.4
		MCWB	43.4	48.2	55.7	65.6	69.1	73.1	82.1	82.4	74.7	65.4	57.6	49.0
	5%	DB	47.0	53.1	64.2	75.6	83.2	88.5	91.9	90.2	83.2	75.6	65.2	52.1
		MCWB	41.1	45.0	52.8	62.7	67.3	72.7	81.6	80.9	73.2	63.8	56.6	45.8
	10%	DB	44.4	49.6	60.4	71.7	80.3	86.0	90.0	88.1	81.0	72.8	62.2	49.3
		MCWB	39.3	43.0	50.4	60.0	66.2	71.9	80.9	79.9	71.7	62.4	54.7	43.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	54.4	62.4	72.0	75.8	80.9	85.8	84.9	81.7	72.2	64.4	54.7
		MCDB	50.8	61.1	70.8	80.0	82.4	88.2	92.4	92.1	88.0	77.6	67.3	56.6
	2%	WB	45.1	49.8	58.1	68.1	72.2	78.7	84.2	83.3	78.1	69.0	60.9	49.6
		MCDB	48.5	54.9	66.3	76.6	80.0	85.7	90.8	90.0	82.8	73.7	65.6	53.9
	5%	WB	42.4	46.8	55.0	64.8	70.5	77.0	82.9	82.1	75.7	66.8	58.4	47.1
		MCDB	45.8	51.5	61.8	73.1	78.3	83.2	89.4	88.1	80.5	71.6	62.7	51.1
	10%	WB	40.1	44.0	51.8	62.0	68.7	75.1	81.7	81.0	74.0	64.8	55.8	44.7
		MCDB	43.8	48.5	59.1	69.3	76.6	81.6	88.1	86.4	78.7	70.4	61.0	48.8
Mean Daily Temperature Range	5% DB	MDBR	12.7	13.4	15.7	16.8	16.9	14.5	10.8	11.1	13.6	16.0	14.9	13.7
		MCDBR	17.2	19.5	21.5	22.1	21.5	19.3	13.3	12.8	15.5	19.3	18.5	17.0
		MCWBR	10.9	11.7	11.9	11.6	8.9	6.6	5.3	5.3	6.1	7.5	9.5	10.5
	5% WB	MCDBR	14.2	16.4	19.3	19.2	17.1	12.7	12.8	12.2	14.2	13.9	14.3	
		MCWBR	10.4	11.0	12.3	11.6	9.4	6.1	6.1	5.9	6.2	7.6	9.0	10.1
Clear-Sky Solar Irradiance	taub	0.569	0.631	0.655	0.651	0.664	0.768	0.741	0.714	0.642	0.662	0.632	0.577	
	taud	1.672	1.592	1.568	1.620	1.634	1.489	1.584	1.619	1.710	1.603	1.614	1.676	
	Ebn at Noon	189	193	205	215	215	193	197	199	206	183	170	176	
	Edh at Noon	62	75	83	82	82	94	85	81	71	73	66	59	
All-Sky Solar Radiation	RadAvg	748	892	1256	1496	1592	1499	1449	1412	1246	1042	792	703	
	RadStd	85	144	114	148	153	156	174	195	141	133	99	81	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page