

HUIYIN, China

WMO: 581410

Lat: 33.6378N

Lon: 118.9269E

Elev: 14

StdP: 101.16

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	-5.4	-4.1	-17.0	0.8	-0.7	-14.2	1.1	-0.1	7.2	3.2	6.3	2.9	1.6	0	0.390

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	6.0	34.1	27.0	33.0	26.6	31.9	25.8	28.7	32.4	28.0	31.5	27.3	30.6	3.0	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
27.7	23.8	31.1	27.0	22.8	30.4	26.4	21.9	29.8	93.5	32.5	90.1	31.6	86.8	30.7	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
6.8	5.8	5.1	-7.9	35.9	1.9	0.9	-9.3	36.6	-10.4	37.1	-11.4	37.6	-12.8	38.3		
			-9.4	29.3	2.0	0.9	-10.8	30.0	-12.0	30.5	-13.1	31.1	-14.6	31.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	15.5	1.9	4.1	9.2	15.2	20.5	24.6	27.7	27.1	22.6	17.2	10.5	4.3	(6)
		DBStd	9.46	3.10	3.62	3.79	3.72	3.03	2.55	2.53	2.45	2.56	3.11	3.95	3.43	
		HDD10.0	706	252	169	61	4	0	0	0	0	0	40	180		
		HDD18.3	2043	510	399	285	106	12	0	0	2	58	234	436		
		CDD10.0	2702	0	3	35	161	326	439	549	530	377	223	56	2	
		CDD18.3	997	0	0	1	13	80	189	291	272	128	23	1	0	
		CDH23.3	9305	0	0	4	111	617	1646	3252	2814	764	96	1	0	
		CDH26.7	3372	0	0	0	18	171	587	1372	1056	162	8	0	0	
(14)	Wind	WSAvg	2.3	2.2	2.5	2.9	2.7	2.6	2.4	2.3	1.9	1.8	2.2	2.2		(14)
(15)	Precipitation	PrecAvg	965	26	33	46	54	77	128	236	183	81	41	40	21	(15)
(16)		PrecMax	1327	83	78	142	109	145	263	405	328	196	206	133	61	(16)
(17)		PrecMin	741	1	8	6	11	11	55	118	68	7	2	0	0	(17)
(18)		PrecStd	156	22	18	30	24	36	58	68	61	50	39	33	17	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4% DB	12.4	17.7	23.2	28.9	32.7	34.7	35.6	35.0	32.1	27.8	22.5	15.7		(19)
(20)		0.4% MCWB	7.7	11.2	15.4	20.3	20.8	23.0	28.3	28.5	26.1	19.4	15.0	10.8		(20)
(21)		2% DB	10.1	14.1	20.2	26.4	30.4	32.8	34.4	33.6	29.8	25.8	20.1	13.0		(21)
(22)		2% MCWB	6.3	9.0	13.2	18.7	20.6	22.8	27.8	28.0	23.7	18.6	14.2	9.4		(22)
(23)		5% DB	8.3	11.7	17.9	24.2	28.5	31.4	33.3	32.3	28.5	24.2	18.4	11.2		(23)
(24)		5% MCWB	5.1	7.2	11.6	17.0	19.6	22.6	27.6	27.2	22.9	17.6	13.6	7.7		(24)
(25)		10% DB	6.9	9.8	15.8	22.1	26.8	30.0	32.2	31.2	27.2	22.6	16.8	9.6		(25)
(26)		10% MCWB	4.1	6.1	10.2	15.5	19.0	22.2	27.1	26.6	22.1	16.9	12.6	6.6		(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% WB	9.4	12.4	16.9	22.2	24.3	27.2	29.9	29.4	27.6	22.3	18.0	12.6		(27)
(28)		0.4% MCDB	10.5	16.1	21.5	26.6	28.0	31.2	33.5	33.4	31.1	25.3	19.6	13.7		(28)
(29)		2% WB	7.3	9.9	14.5	20.0	22.3	25.9	29.0	28.5	25.6	20.6	16.1	9.8		(29)
(30)		2% MCDB	9.2	12.7	19.1	24.8	26.6	29.8	32.7	32.2	28.2	23.1	18.7	12.2		(30)
(31)		5% WB	5.8	8.2	12.8	18.2	21.4	25.0	28.3	27.8	24.3	19.3	14.7	8.4		(31)
(32)		5% MCDB	7.7	10.8	16.5	22.9	25.7	28.5	31.9	31.2	27.0	22.0	17.0	10.6		(32)
(33)		10% WB	4.5	6.7	11.0	16.7	20.4	23.9	27.6	27.2	23.3	18.2	13.2	7.1		(33)
(34)		10% MCDB	6.5	9.2	15.0	20.7	24.8	27.5	31.2	30.2	26.0	21.4	16.1	9.3		(34)
(35)	Mean Daily Temperature Range	MDBR	7.0	7.4	8.7	9.3	9.4	8.1	6.0	6.2	7.5	8.9	8.3	7.6		(35)
(36)		5% DB MCDBR	9.5	10.8	11.9	12.3	11.9	10.7	7.4	7.1	8.6	10.7	10.3	9.5		(36)
(37)		5% WB MCWBR	6.1	6.5	6.6	6.5	4.9	3.7	2.9	2.9	3.4	4.2	5.3	5.8		(37)
(38)		5% WB MCDBR	7.9	9.1	10.7	10.7	9.5	7.1	7.1	6.8	6.8	7.9	7.7	7.9		(38)
(39)	Clear-Sky Solar Irradiance	taub	0.569	0.631	0.655	0.651	0.664	0.768	0.741	0.714	0.642	0.662	0.632	0.577		(40)
(41)		taud	1.672	1.592	1.568	1.620	1.634	1.489	1.584	1.619	1.710	1.603	1.614	1.676		(41)
(42)		Ebn at Noon	595	610	645	679	677	608	622	628	649	578	537	555		(42)
(43)		Edh at Noon	197	237	261	258	257	296	268	255	223	230	208	187		(43)
(44)	All-Sky Solar Radiation	RadAvg	2.36	2.81	3.96	4.72	5.02	4.72	4.57	4.45	3.93	3.29	2.50	2.21		(44)
(45)		RadStd	0.27	0.46	0.36	0.47	0.48	0.49	0.55	0.61	0.44	0.42	0.31	0.26		(45)

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)
(47)	Regional (7 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page