

FUYANG, China

WMO: 582030

Lat: 32.8776N

Lon: 115.7363E

Elev: 108

StdP: 14.64

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	21.6	24.7	4.3	6.9	32.4	9.0	8.8	33.7	18.7	39.2	16.2	40.2	3.5	0	0.404

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	12.4	95.6	80.0	93.4	79.1	91.3	78.3	83.9	91.2	82.8	89.7	81.6	88.0	7.9	200

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
82.2	168.1	88.4	81.0	161.5	87.3	79.8	155.3	86.1	48.3	91.6	47.0	89.8	45.6	88.2	87.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.8	14.3	12.3	15.6	99.1	4.2	1.9	12.6	100.5	10.2	101.6	7.8	102.7	4.8	104.1		
			14.0	84.9	4.0	1.6	11.1	86.0	8.8	87.0	6.6	87.9	3.7	89.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.9	36.0	41.2	50.8	61.3	70.8	78.4	82.6	80.9	73.1	63.5	51.0	40.1	
	DBStd	17.13	5.95	6.96	7.40	7.07	5.79	4.77	4.70	5.02	5.29	6.18	7.37	5.92	
	HDD50	1159	434	256	80	5	0	0	0	0	0	0	73	311	
	HDD65	3476	899	666	442	152	15	0	0	0	4	103	422	773	
	CDD50	5144	1	10	105	343	645	853	1012	956	694	419	102	4	
	CDD65	1985	0	0	3	40	195	403	547	491	248	56	2	0	
	CDH74	19736	0	2	26	352	1655	3986	6338	5222	1783	354	18	0	
	CDH80	8005	0	0	2	79	564	1680	2908	2172	535	64	1	0	
Wind	WSAvg	5.8	5.8	6.4	7.0	6.6	6.1	5.8	5.4	5.3	5.1	5.0	5.6	5.8	
Precipitation	PrecAvg	34.5	0.9	1.3	2.0	2.5	3.3	4.8	7.7	3.9	3.7	2.3	1.5	0.6	
	PrecMax	52.8	3.0	3.9	4.8	7.3	7.2	11.7	15.7	11.7	14.4	7.3	4.1	2.2	
	PrecMin	19.4	0.0	0.0	0.0	0.5	0.3	1.0	1.1	0.8	0.1	0.0	0.0	0.0	
	PrecStd	7.8	0.7	1.0	1.2	1.9	1.8	3.1	4.3	2.7	3.0	2.1	1.3	0.6	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	58.5	66.7	77.6	86.7	93.2	97.5	98.3	97.2	93.4	85.7	76.6	62.4	
		MCWB	47.0	53.8	64.0	70.6	69.4	74.7	81.7	81.2	76.8	67.0	59.0	48.9	
	2%	DB	53.3	60.6	72.0	82.0	89.6	94.0	96.0	94.1	88.5	81.3	71.1	56.5	
		MCWB	43.6	49.4	59.1	67.6	70.5	74.4	81.8	82.0	74.9	65.6	56.7	46.3	
	5%	DB	49.4	56.5	67.9	78.0	86.1	91.5	93.9	91.9	85.4	77.9	66.5	52.9	
		MCWB	41.6	47.2	56.9	65.4	70.3	74.2	81.5	81.0	72.6	63.2	55.6	44.8	
	10%	DB	45.9	52.6	63.6	74.3	82.7	88.8	91.5	89.4	82.8	74.6	62.6	49.5	
		MCWB	39.5	45.1	53.6	62.9	68.6	73.8	80.8	80.1	71.3	62.8	53.3	42.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	49.0	57.0	67.0	73.8	77.1	82.0	85.5	85.3	81.2	72.4	63.8	52.4
			MCDB	55.1	64.5	74.0	82.8	83.6	90.0	92.8	92.6	90.0	77.6	71.6	57.0
2%		WB	45.5	51.8	61.6	70.2	74.1	79.8	84.3	83.8	78.7	69.1	59.9	48.7	
		MCDB	51.2	58.2	69.5	78.6	82.4	87.0	92.1	90.5	84.1	76.0	66.4	53.9	
5%		WB	42.8	48.8	58.2	67.4	72.5	78.2	83.2	82.7	76.6	66.9	57.2	46.2	
		MCDB	48.1	54.5	66.1	75.4	81.3	85.5	90.7	88.9	81.5	73.8	63.5	50.8	
10%		WB	40.4	46.2	55.1	64.7	70.8	76.7	82.1	81.5	74.5	65.0	55.0	44.1	
		MCDB	44.9	51.3	61.6	72.2	79.3	84.1	89.2	87.1	79.5	71.6	61.2	48.4	
Mean Daily Temperature Range	5% DB	MDBR	14.1	14.6	16.2	17.6	17.6	15.8	12.4	12.4	14.9	16.7	16.2	14.7	
		MCDBR	21.1	21.9	22.9	23.2	23.4	20.8	15.6	15.2	18.6	22.2	22.7	21.3	
		MCWBR	13.3	13.1	12.9	12.2	8.7	6.5	5.2	5.6	6.5	8.7	11.2	12.5	
	5% WB	MCDBR	18.9	18.6	20.7	20.2	18.7	15.7	14.3	13.4	14.2	16.6	17.7	17.3	
		MCWBR	12.7	12.3	12.8	12.3	9.7	6.6	6.0	5.8	6.9	8.1	10.0	11.2	
Clear-Sky Solar Irradiance	taub	0.616	0.674	0.680	0.677	0.689	0.776	0.731	0.742	0.711	0.716	0.659	0.615		
	taud	1.588	1.519	1.523	1.569	1.594	1.473	1.591	1.557	1.576	1.513	1.565	1.610		
	Ebn at Noon	178	185	200	210	210	192	200	194	191	172	166	168		
	Edh at Noon	69	82	87	86	85	95	85	86	82	81	70	64		
All-Sky Solar Radiation	RadAvg	687	811	1198	1425	1519	1494	1461	1363	1162	967	763	662		
	RadStd	92	160	112	142	131	148	184	182	174	132	110	104		

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page